


# PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id  
**TB115**  
Component  
**Hydraulic System**  
Fluid  
**SHELL TELLUS 46 (--- LTR)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

## PROBLEMATIC TEST RESULTS

Sample Status		ATTENTION	ABNORMAL	---
Particles >4µm	ASTM D7647 >5000	▲ 9611	▲ 23155	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 20/15/10	▲ 22/19/16	---

Customer Id: GFL286  
Sample No.: PC0077044  
Lab Number: 02578822  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

## HISTORICAL DIAGNOSIS

### 11 Nov 2022 Diag: Kevin Marson

ISO




The filter change at the time of sampling has been noted. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. Oil Cleanliness are abnormally high. Particles >14µm are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >21µm are notably high. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report





Machine Id  
**TB115**  
Component  
**Hydraulic System**  
Fluid  
**SHELL TELLUS 46 (--- LTR)**



## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal.

### Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC0077044</b>	PC0062003	---
Sample Date	Client Info	<b>28 Jul 2023</b>	11 Nov 2022	---
Machine Age	hrs	<b>1105</b>	139	---
Oil Age	hrs	<b>0</b>	0	---
Oil Changed	Client Info	<b>N/A</b>	Not Changd	---
Sample Status		<b>ATTENTION</b>	ABNORMAL	---

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m) >20	<b>2</b>	<1	---
Chromium	ppm	ASTM D5185(m) >10	<b>0</b>	0	---
Nickel	ppm	ASTM D5185(m) >10	<b>0</b>	0	---
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	---
Silver	ppm	ASTM D5185(m)	<b>0</b>	0	---
Aluminum	ppm	ASTM D5185(m) >10	<b>&lt;1</b>	<1	---
Lead	ppm	ASTM D5185(m) >10	<b>0</b>	3	---
Copper	ppm	ASTM D5185(m) >75	<b>&lt;1</b>	<1	---
Tin	ppm	ASTM D5185(m) >10	<b>0</b>	0	---
Antimony	ppm	ASTM D5185(m)	<b>0</b>	0	---
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	---
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	---
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	---

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m) 0.0	<b>&lt;1</b>	<1	---
Barium	ppm	ASTM D5185(m) 0	<b>0</b>	0	---
Molybdenum	ppm	ASTM D5185(m) 0	<b>0</b>	0	---
Manganese	ppm	ASTM D5185(m)	<b>0</b>	0	---
Magnesium	ppm	ASTM D5185(m) 11	<b>41</b>	41	---
Calcium	ppm	ASTM D5185(m) 35	<b>20</b>	20	---
Phosphorus	ppm	ASTM D5185(m) 266	<b>352</b>	360	---
Zinc	ppm	ASTM D5185(m) 276	<b>311</b>	303	---
Sulfur	ppm	ASTM D5185(m) 1847	<b>765</b>	767	---
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	---

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	<1	---
Sodium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	---
Potassium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	0	---






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	<b>▲ 9611</b>	▲ 23155	---
Particles >6µm	ASTM D7647 >1300	<b>216</b>	▲ 4715	---
Particles >14µm	ASTM D7647 >160	<b>7</b>	▲ 321	---
Particles >21µm	ASTM D7647 >40	<b>2</b>	▲ 78	---
Particles >38µm	ASTM D7647 >10	<b>0</b>	4	---
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	<b>▲ 20/15/10</b>	▲ 22/19/16	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974* 0.36	<b>0.49</b>	0.40	---


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	---
Emulsified Water	scalar	Visual*	>0.1	NEG	---
Free Water	scalar	Visual*		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46.99	44.8	45.6
Visc @ 100°C	cSt	ASTM D7279(m)	6.76	7.6	7.8
Viscosity Index (VI)	Scale	ASTM D2270*	96	137	140

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Green Infrastructure and Partners Inc (GIPI) - 286 - Shoring & Foundations  
**Sample No.** : PC0077044 **Received** : 28 Aug 2023  
**Lab Number** : 02578822 **Diagnosed** : 29 Aug 2023  
**Unique Number** : 5631882 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: KV100, TAN Man, VI )  
 To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

151 Ram Forest Rd,  
 Stouffville, ON  
 CA L4A 2G8  
 Contact: Shannon Abbott  
 sabbott@gipi.com  
 T: (905)750-5900  
 F: