




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
731097
 Component
Natural Gas Engine
 Fluid
PETRO CANADA DURON GEO LD 15W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		GFL0085886	GFL0064293	GFL0054894
Sample Date	Client Info		06 Sep 2023	24 Mar 2023	22 Sep 2022
Machine Age	hrs	Client Info	5270	4260	3098
Oil Age	hrs	Client Info	1200	1200	1000
Oil Changed	Client Info		Changed	Changed	Changed
Sample Status			NORMAL	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >50	9	12	10
Chromium	ppm	ASTM D5185(m) >4	<1	<1	<1
Nickel	ppm	ASTM D5185(m) >2	0	<1	<1
Titanium	ppm	ASTM D5185(m)	0	<1	<1
Silver	ppm	ASTM D5185(m) >3	0	0	0
Aluminum	ppm	ASTM D5185(m) >9	2	2	3
Lead	ppm	ASTM D5185(m) >30	2	4	<1
Copper	ppm	ASTM D5185(m) >35	1	2	2
Tin	ppm	ASTM D5185(m) >4	<1	<1	<1
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 50	8	8	8
Barium	ppm	ASTM D5185(m) 5	0	0	0
Molybdenum	ppm	ASTM D5185(m) 50	55	55	51
Manganese	ppm	ASTM D5185(m) 0	<1	<1	<1
Magnesium	ppm	ASTM D5185(m) 560	559	598	557
Calcium	ppm	ASTM D5185(m) 1510	1524	1749	1571
Phosphorus	ppm	ASTM D5185(m) 780	668	803	742
Zinc	ppm	ASTM D5185(m) 870	879	961	928
Sulfur	ppm	ASTM D5185(m) 2040	1962	2095	2081
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >+100	4	4	4
Sodium	ppm	ASTM D5185(m)	8	10	8
Potassium	ppm	ASTM D5185(m) >20	<1	<1	1

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	11.0	12.0
Sulfation	Abs/.1mm	ASTM D7415*	>30	24.7	22.2

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	>25	17.3	18.2

VISUAL










	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*	NEG	NEG	NEG



OIL ANALYSIS REPORT

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	15.1	14.4	14.4	14.2

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **GFL Environmental - 209 - Hamilton**
Sample No. : GFL0085886 **Received** : 08 Sep 2023 **560 Seaman Street**
Lab Number : **02581130** **Diagnosed** : 08 Sep 2023 **Stoney Creek, ON**
Unique Number : 5642195 **Diagnostician** : Wes Davis **CA L8E 3X7**
Test Package : MOB 1 **Contact:** Fred Carleton

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

fred.carleton@gflenv.com
T: (289)925-6693
F: (905)664-9008