


# PROBLEM SUMMARY


Area  
**1313**  
Machine Id  
**RECLAIM FEEDER 3**  
Component  
**Gearbox**  
Fluid  
**PETRO CANADA ENDURATEX EP 460 (200 LTR)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>20000	▲ <b>114942</b>	▲ 89882	▲ 132961
Particles >6µm	ASTM D7647	>5000	▲ <b>17141</b>	▲ 7669	▲ 20717
Particles >14µm	ASTM D7647	>640	▲ <b>1059</b>	132	▲ 865
Particles >21µm	ASTM D7647	>160	▲ <b>261</b>	21	101
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ <b>24/21/17</b>	▲ 24/20/14	▲ 24/22/17

Customer Id: INCVOS  
Sample No.: PC0070099  
Lab Number: 02582970  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

### 20 Nov 2022 Diag: Wes Davis

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Oil Cleanliness are abnormally high. Particles >4µm are abnormally high. Particles >6µm are notably high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 12 Jul 2022 Diag: Wes Davis

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Oil Cleanliness are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >14µm are notably high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 09 Oct 2021 Diag: Wes Davis

ISO




We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Area  
**1313**  
Machine Id  
**RECLAIM FEEDER 3**  
Component  
**Gearbox**  
Fluid  
**PETRO CANADA ENDURATEX EP 460 (200 LTR)**



## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC0070099</b>	PC0057443	PC0040232
Sample Date	Client Info	<b>13 Aug 2023</b>	20 Nov 2022	12 Jul 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m) >200	<b>13</b>	13	13
Chromium	ppm	ASTM D5185(m) >15	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m) >15	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m) >25	<b>&lt;1</b>	0	<1
Lead	ppm	ASTM D5185(m) >100	<b>0</b>	0	<1
Copper	ppm	ASTM D5185(m) >200	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185(m) >25	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m) >5	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m) 55	<b>14</b>	18	16
Barium	ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m) 0	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185(m) 2	<b>&lt;1</b>	0	<1
Calcium	ppm	ASTM D5185(m) 6	<b>1</b>	0	1
Phosphorus	ppm	ASTM D5185(m) 240	<b>249</b>	258	232
Zinc	ppm	ASTM D5185(m) 3	<b>5</b>	1	5
Sulfur	ppm	ASTM D5185(m) 10310	<b>8921</b>	9205	9194
Lithium	ppm	ASTM D5185(m)	<b>4</b>	4	4

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >50	<b>6</b>	6	6
Sodium	ppm	ASTM D5185(m)	<b>&lt;1</b>	1	<1
Potassium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1

## FLUID CLEANLINESS


method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>20000	<b>▲ 114942</b>	▲ 89882	▲ 132961
Particles >6µm	ASTM D7647	>5000	<b>▲ 17141</b>	▲ 7669	▲ 20717
Particles >14µm	ASTM D7647	>640	<b>▲ 1059</b>	132	▲ 865
Particles >21µm	ASTM D7647	>160	<b>▲ 261</b>	21	101
Particles >38µm	ASTM D7647	>40	<b>5</b>	1	0
Particles >71µm	ASTM D7647	>10	<b>1</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>▲ 24/21/17</b>	▲ 24/20/14	▲ 24/22/17

## FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974* 0.5	<b>0.57</b>	0.61	0.56

# OIL ANALYSIS REPORT


## ▲ Particle Trend




## Viscosity @ 100°C




## Acid Number



## Viscosity @ 100°C



## Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	VLITE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	452	482	477
Visc @ 100°C	cSt	ASTM D7279(m)	30.41	31.7	31.4
Viscosity Index (VI)	Scale	ASTM D2270*	97	96	96

## SAMPLE IMAGES

Color




Bottom




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### ▲ Particle Count



### Acid Number



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0070099 **Received** : 15 Sep 2023  
**Lab Number** : 02582970 **Diagnosed** : 18 Sep 2023  
**Unique Number** : 5644035 **Diagnostician** : Wes Davis  
**Test Package** : IND 2 ( Additional Tests: KV100, PrtCount, TAN Man, VI )

**Vale - Voisey's Bay**  
 Voisey's Bay Mine Site, P.O. Box 7001, Str. C Happy Valley  
 Goose Bay, NL  
 CA A0P 1C0  
 Contact: Robert Feltham  
 robert.feltham@vale.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

T:  
F: x: