




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**731077**  
 Component  
**Natural Gas Engine**  
 Fluid  
**PETRO CANADA DURON GEO LD 15W40 (--- LTR)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>GFL0085906</b>	GFL0064323	GFL0061011
Sample Date	Client Info		<b>25 Sep 2023</b>	13 Apr 2023	08 Nov 2022
Machine Age	hrs	Client Info	<b>5551</b>	4401	3337
Oil Age	hrs	Client Info	<b>1200</b>	1200	1100
Oil Changed	Client Info		<b>Changed</b>	Changed	Changed
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>50	<b>10</b>	13	17
Chromium	ppm	ASTM D5185(m)	>4	<b>&lt;1</b>	1	2
Nickel	ppm	ASTM D5185(m)	>2	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	<1	<1
Silver	ppm	ASTM D5185(m)	>3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>9	<b>2</b>	2	4
Lead	ppm	ASTM D5185(m)	>30	<b>11</b>	2	1
Copper	ppm	ASTM D5185(m)	>35	<b>1</b>	2	2
Tin	ppm	ASTM D5185(m)	>4	<b>&lt;1</b>	<1	1
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	50	<b>8</b>	7	11
Barium	ppm	ASTM D5185(m)	5	<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	50	<b>75</b>	59	96
Manganese	ppm	ASTM D5185(m)	0	<b>0</b>	<1	1
Magnesium	ppm	ASTM D5185(m)	560	<b>522</b>	617	669
Calcium	ppm	ASTM D5185(m)	1510	<b>1663</b>	1698	1542
Phosphorus	ppm	ASTM D5185(m)	780	<b>686</b>	762	770
Zinc	ppm	ASTM D5185(m)	870	<b>889</b>	965	881
Sulfur	ppm	ASTM D5185(m)	2040	<b>2082</b>	2120	2236
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>+100	<b>4</b>	12	7
Sodium	ppm	ASTM D5185(m)		<b>8</b>	9	7
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1

## INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844*		<b>0</b>	0	0
Nitration	Abs/cm	ASTM D7624*	>20	<b>10.8</b>	11.9	9.9
Sulfation	Abs/.1mm	ASTM D7415*	>30	<b>24.4</b>	23.9	22.3

## FLUID DEGRADATION


	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	ASTM D7414*	>25	<b>18.7</b>	19.1	16.9

## VISUAL

	method	limit/base	current	history1	history2	
Emulsified Water	scalar	Visual*	>0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG











# OIL ANALYSIS REPORT



FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	15.1	<b>14.0</b>	13.8	14.3

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **GFL Environmental - 209 - Hamilton**  
**Sample No.** : GFL0085906 **Received** : 28 Sep 2023 **560 Seaman Street**  
**Lab Number** : 02585749 **Diagnosed** : 28 Sep 2023 **Stoney Creek, ON**  
**Unique Number** : 5646814 **Diagnostician** : Wes Davis **CA L8E 3X7**  
**Test Package** : MOB 1

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

Contact: Fred Carleton  
 fred.carleton@gflenv.com  
 T: (289)925-6693  
 F: (905)664-9008