


# FUEL REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**MIDSHIPCRANE**

Component  
**Diesel Fuel**  
Fluid

**No.2 DIESEL FUEL (LOW-SULPHUR) (--- GAL)**

## DIAGNOSIS

### Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. Resample at the next service interval to monitor.

### Corrosion

{not applicable}

### Contaminants

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. There is no indication of any contamination in the diesel fuel.

### Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel, low sulfur (US EPA/CGSB-3.517-3 type B).

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC</b>	PC	PC
Sample Date	Client Info	<b>05 Oct 2023</b>	06 May 2023	05 Feb 2023
Machine Age	hrs	<b>0</b>	0	0
Sample Status		<b>NORMAL</b>	ATTENTION	SEVERE

## PHYSICAL PROPERTIES

method	limit/base	current	history1	history2		
Specific Gravity	ASTM D1298*	0.839	<b>0.843</b>	0.844	0.856	
Fuel Color	text	Visual Screen*	<b>Yellow</b>	Red	Purpl	
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	<b>2.8</b>	3	3.9
Pensky-Martens Flash Point	°C	ASTM D7215*	52	<b>62.3</b>	63.3	67.3

## SULFUR CONTENT

method	limit/base	current	history1	history2		
Sulfur	ppm	ASTM D5185(m)	250	<b>20</b>	124	406

## DISTILLATION

method	limit/base	current	history1	history2		
Initial Boiling Point	°C	ASTM D2887*	165	<b>173</b>	174	177
5% Distillation Point	°C	ASTM D2887*		<b>197</b>	197	203
10% Distill Point	°C	ASTM D2887*	201	<b>209</b>	209	217
15% Distillation Point	°C	ASTM D2887*		<b>218</b>	218	228
20% Distill Point	°C	ASTM D2887*	216	<b>227</b>	227	239
30% Distill Point	°C	ASTM D2887*	230	<b>242</b>	243	259
40% Distill Point	°C	ASTM D2887*	243	<b>255</b>	258	277
50% Distill Point	°C	ASTM D2887*	255	<b>268</b>	272	294
60% Distill Point	°C	ASTM D2887*	267	<b>281</b>	287	313
70% Distill Point	°C	ASTM D2887*	280	<b>294</b>	303	333
80% Distill Point	°C	ASTM D2887*	295	<b>309</b>	320	355
85% Distillation Point	°C	ASTM D2887*		<b>320</b>	333	369
90% Distill Point	°C	ASTM D2887*	310	<b>331</b>	346	383
95% Distillation Point	°C	ASTM D2887*		<b>350</b>	367	405
Final Boiling Point	°C	ASTM D2887*	341	<b>372</b>	387	420

## IGNITION QUALITY

method	limit/base	current	history1	history2	
API Gravity	ASTM D1298*	37.7	<b>36</b>	36	33
Cetane Index	ASTM D4737*	<40.0	<b>49</b>	49	48






## CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185(m)	<1.0	<b>0</b>	0	0
Sodium	ppm	ASTM D5185(m)	<0.1	<b>0</b>	0	0
Potassium	ppm	ASTM D5185(m)	<0.1	<b>&lt;1</b>	0	0
Water	%	ASTM D6304*	<0.05	<b>0.004</b>	0.004	0.014
ppm Water	ppm	ASTM D6304*	<500	<b>44.3</b>	41.0	142.2

## FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>2500	<b>1604</b>	▲ 3334	● 24298
Particles >6µm	ASTM D7647	>640	<b>237</b>	▲ 781	● 7174
Particles >14µm	ASTM D7647	>80	<b>5</b>	▲ 25	● 281
Particles >21µm	ASTM D7647	>20	<b>1</b>	▲ 4	● 51
Particles >38µm	ASTM D7647	>4	<b>0</b>	▲ 0	● 2
Particles >71µm	ASTM D7647	>3	<b>0</b>	▲ 0	● 0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	<b>18/15/10</b>	▲ 19/17/12	● 22/20/15




# FUEL REPORT



HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	0	0	0
Nickel	ppm	ASTM D5185(m)	<0.1	0	0	0
Lead	ppm	ASTM D5185(m)	<0.1	0	0	0
Vanadium	ppm	ASTM D5185(m)	<0.1	0	0	0
Iron	ppm	ASTM D5185(m)	<0.1	<1	<1	<1
Calcium	ppm	ASTM D5185(m)	<0.1	0	<1	<1
Magnesium	ppm	ASTM D5185(m)	<0.1	<1	<1	<1
Phosphorus	ppm	ASTM D5185(m)	<0.1	0	<1	<1
Zinc	ppm	ASTM D5185(m)	<0.1	0	<1	<1

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC  
**Lab Number** : 02590153  
**Unique Number** : 5659219  
**Test Package** : FUEL ( Additional Tests: CC Flash, GC-PercFuel, PrtCount )  
**Received** : 18 Oct 2023  
**Diagnosed** : 23 Oct 2023  
**Diagnostician** : Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**Suncor - Terra Nova Projects**  
 Scotia Centre, 235 Water Street  
 St. John's, NL  
 CA A1C 1B6  
 Contact: Deanne Badcock  
 dbadcock@suncor.com  
 T: (709)778-3843  
 F: (709)724-2784