


Machine Id  
**SIEMENS PINNACLE NG 1**

Component  
**Natural Gas Engine**

Fluid  
**PETRO CANADA SENTRON LD 5000 (--- GAL)**



## DIAGNOSIS

### ▲ Recommendation

The oil change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### ▲ Fluid Condition

The i-pH level is abnormally low. The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>PC0073818</b>	PC0074650	PC0074656
Sample Date	Client Info			<b>08 Sep 2023</b>	17 Jul 2023	31 May 2023
Machine Age	hrs	Client Info		<b>8077</b>	6812	5691
Oil Age	hrs	Client Info		<b>1265</b>	1121	1040
Oil Changed	Client Info			<b>Changed</b>	Changed	Changed
Sample Status				<b>ABNORMAL</b>	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>50	<b>3</b>	2	2
Chromium	ppm	ASTM D5185(m)	>4	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	>2	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	>3	<b>&lt;1</b>	<1	<1
Aluminum	ppm	ASTM D5185(m)	>9	<b>1</b>	2	2
Lead	ppm	ASTM D5185(m)	>30	<b>1</b>	<1	<1
Copper	ppm	ASTM D5185(m)	>35	<b>1</b>	<1	<1
Tin	ppm	ASTM D5185(m)	>4	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0


ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	2	<b>1</b>	2	2
Barium	ppm	ASTM D5185(m)	3	<b>&lt;1</b>	<1	<1
Molybdenum	ppm	ASTM D5185(m)	0	<b>&lt;1</b>	1	<1
Manganese	ppm	ASTM D5185(m)	0	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m)	4	<b>14</b>	19	21
Calcium	ppm	ASTM D5185(m)	1727	<b>2079</b>	1996	1990
Phosphorus	ppm	ASTM D5185(m)	272	<b>308</b>	312	311
Zinc	ppm	ASTM D5185(m)	333	<b>389</b>	388	395
Sulfur	ppm	ASTM D5185(m)	3415	<b>2892</b>	2895	2888
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>+100	<b>2</b>	2	2
Sodium	ppm	ASTM D5185(m)		<b>1</b>	1	1
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		<b>0</b>	0	0
Nitration	Abs/cm	ASTM D7624*	>20	<b>5.7</b>	5.7	5.7
Sulfation	Abs/.1mm	ASTM D7415*	>30	<b>19.4</b>	18.6	18.5

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	>25	<b>12.2</b>	10.9	10.9
Acid Number (AN)	mg KOH/g	ASTM D974*	1.1	<b>2.38</b>	2.22	2.45
Base Number (BN)	mg KOH/g	ASTM D2896*	4.9	<b>3.53</b>	3.81	3.89
i-pH	Scale 0-14	ASTM D7946*	<4.5	<b>▲ 4.48</b>	5.12	5.19












# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	124	129	126
Visc @ 100°C	cSt	ASTM D7279(m)	13.48	13.8	13.7
Viscosity Index (VI)	Scale	ASTM D2270*	104	103	105

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0073818 **Received** : 19 Oct 2023  
**Lab Number** : 02590245 **Diagnosed** : 20 Oct 2023  
**Unique Number** : 5659311 **Diagnostician** : Kevin Marson  
**Test Package** : MOB 2 ( Additional Tests: i-pH, KV40, TAN Auto, TAN Man, VI )

**Martin Energy Group Canada**  
 1050 Boyde Lane RR#1  
 Linwood, ON  
 CA N0B 2A0  
 Contact: Allen Steiner  
 asteiner@martinenergygroup.com  
 T: (226)545-0230  
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.