

OIL ANALYSIS REPORT

Sample Rating Trend



CR219

Component Diesel Engine

Fluid PETRO CANADA SUPREME SYNTHETIC 5W40 (28 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC	PC0072914	PC0064802
Sample Date		Client Info		25 Oct 2023	01 Mar 2023	22 Sep 2022
Machine Age	hrs	Client Info		0	8700	3160
Oil Age	hrs	Client Info		0	0	500
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				NORMAL	ABNORMAL	ABNORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Fuel		WC Method	>5	<1.0	0.8	0.8
Glycol		WC Method		NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>100	22	16	30
Chromium	ppm	ASTM D5185(m)	>20	<1	4	10
Nickel	ppm	ASTM D5185(m)	>4	0	<1	<1
Titanium	ppm	ASTM D5185(m)		0	<1	<1
Silver	ppm	ASTM D5185(m)	>3	<1	0	0
Aluminum	ppm	ASTM D5185(m)	>20	2	<1	2
Lead	ppm	ASTM D5185(m)	>40	<1	3	6
Copper	ppm	ASTM D5185(m)	>330	2	2	10
Tin	ppm	ASTM D5185(m)	>15	0	6	4
Antimony	ppm	ASTM D5185(m)		0	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	190	28	4	29
Barium	ppm	ASTM D5185(m)	0	<1	0	0
Molybdenum	ppm	ASTM D5185(m)	79	57	2	31
Manganese	ppm	ASTM D5185(m)		0	<1	<1
Magnesium	ppm	ASTM D5185(m)	564	1065	994	965
Calcium	ppm	ASTM D5185(m)	993	836	1147	1025
Phosphorus	ppm	ASTM D5185(m)	763	998	1234	1095
Zinc	ppm	ASTM D5185(m)	835	1166	1330	1177
Sulfur	ppm	ASTM D5185(m)	2536	2740	2845	2867
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	3	8	4 37
Sodium	ppm	ASTM D5185(m)		5	1	13
Potassium	ppm	ASTM D5185(m)	>20	<1	0	0
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	>3	0.4	0	0
Nitration	Abs/cm	ASTM D7624*	>20	9.1	4.8	6.2
Sulfation	Abs/.1mm	ASTM D7415*	>30	20.6	16.3	17.5



60 · 50 · 40 ·


Nov21/20


Feb22/21

Aug23/21

Sep2/21

OIL ANALYSIS REPORT





Mar1/23

Laboratory

Sample No. Lab Number

Unique Number Test Package

Sep22/22

FLUID DEGRA	DATION	method	limit/ba	se current	history1	history2
Dxidation	Abs/.1mm	ASTM D7414*	>25	18.6	8.0	13.0
Base Number (BN)	mg KOH/g	ASTM D2896*	6.9	9.43		
VISUAL		method	limit/ba	ise current	history1	history2
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/ba	se current	history1	history2
/isc @ 40°C	cSt	ASTM D7279(m)	91.3	82.7	81.9	95.1
/isc @ 100°C	cSt	ASTM D7279(m)	14.8	13.6	1 1.0	13.2
/iscosity Index (VI)	Scale	ASTM D2270*	170	168	<mark>▲</mark> 121	137
GRAPHS						
Iron (ppm)				Lead (ppm)	
Severe				80 - Severe		
				_ 60-		
Abnormal				Abnormal		
				20-		
				0		
Nov21/20 Feb22/21 Aug23/21	Sep2/21	Sep22/22 Mar1/23	0ct25/23	Nov21/20 Feb22/2	Aug23/21 Sep2/21	Sep 22/22 Mar1/23
-	05	Sel	00		A	S ≤
Aluminum (ppm)				Chromium	(ppm)	
Severe				40 - Severe		
				= 30-		
Abnormal				20 Abnormal		
				10-		\sim
				0		
Nov21/20 Feb22/21 Aug23/21	Sep2/21	Sep22/22 Mar1/23	0ct25/23	Nov21/20 Feb22/21	Aug23/21 Sep2/21	Sep 22/22 Mar 1/23
		Se Se	õ	—		se Se
Copper (ppm)				Silicon (ppi ⁸⁰ Severe		
Severe Abhormai				60 -		
				틆 40 -		
				Abnormal		\wedge
				20	/	
21	21	33	8	21	21-12	3 2
Nov21/20 Feb22/21	Sep2/21	Sep 22/22 Mar1/23	0ct25/23	Nov21/20	Aug23/21 - Sep2/21 -	Sep 22/22 Mar1/23
Viscosity @ 100°C	2	0	0	≥ – Base Numl		03
Abnormal				10.0		
Base				Base		
Abnormal		\sim		<u> </u>		
\sim		¥		Base Base 6.0 - 4.0 - 2.0 -		
Ť						
3/21	2/21	2/22	5/23	2/21	3/21	2/22
Nov21/20 Feb22/21 Aug23/21	Sep2/21	Sep22/22 Mar1/23	0ct25/23	Nov21/20 Feb22/21	Aug23/21 Sep2/21	Sep22/22 Mar1/23
02592009	Received Diagnose Diagnost Tests: KV	l : 26 ed : 30 ician : We (40, VI)	Oct 2023 Oct 2023 es Davis	N L7L 5H9 Green In	15	1 Ram Forest R Stouffville, C CA L4A 20 Contact: Bill Actor
			7			bacton@gipi.co

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

CALA

ISO 17025:2017 Accredited Laboratory

F:

Page 2 of 2