



INACTIVE 166182

DIAGNOSTICS

Component **Hydraulic System** ESSO NUTO H ISO 68 (114 LTR)

COMPONENT CONDITION SUMMARY







1992 April 95 Jun 1993 Acr/201 De-7017 L-5044 - 501

Sample Rating Trend

🔺 PQ 250. 200 150 Abnormal 100 50 0 0ct26/23 0ct26/23

RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE	NORMAL	ABNORMAL		
PQ		ASTM D8184*		🔺 54				
Iron	ppm	ASTM D5185(m)	>20	🛑 105	2	2		
Chromium	ppm	ASTM D5185(m)	>20	<u> </u>	0	<1		
Particles >6µm		ASTM D7647	>1300	e 145727	178	A 3941		
Particles >14µm		ASTM D7647	>160	e 5552	20	<u> </u>		
Particles >21µm		ASTM D7647	>40	🔺 141	6	126		
Oil Cleanliness		ISO 4406 (c)	>/17/14	e 25/24/20	17/15/11	1 /19/16		

Customer Id: CANDRY Sample No.: PC0069857 Lab Number: 02595017 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Bill Quesnel CLS,OMA II,MLA-III,LLA-I +1 (289)291-4641 x4641 Bill.Quesnel@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 aloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Filter			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.			
Resample			?	Resample in 30-45 days to monitor this situation.			
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.			
Check Dirt Access			?	We advise that you check all areas where contaminants can enter the system.			
Filter Fluid			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.			

HISTORICAL DIAGNOSIS

24 Jan 2008 Diag:



Resample at the next service interval to monitor.All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The condition of oil is suitable for further service.



view report

22 Oct 2007 Diag:

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.All component wear rates are normal. There is a moderate amount of particulates (5 to >100 microns in size) present in the oil. The condition of oil is suitable for further service.

28 Aug 2007 Diag:

NORMAL



Resample at the next service interval to monitor.All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The condition of oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Area INACTIVE Machine Id 166182

Component Hydraulic System Fluid ESSO NUTO H ISO 68 (114 LTR)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

🛑 Wear

Iron ppm levels are severe. PQ levels are abnormal. Chromium ppm levels are abnormal. Cylinder or oil pump wear indicated. Cylinder liner, rod or spool wear is indicated. The high ferrous density (PQ) index indicates that abnormal wear is occurring.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.



SAMPLE INFORMATION method PC0069857 Client Info WC753895 WC754173 Sample Number 26 Oct 2023 Sample Date Client Info 24 Jan 2008 22 Oct 2007 0 Machine Age mths **Client Info** 0 0 Oil Age mths Client Info n 0 0 Oil Changed Client Info N/A N/A N/A SEVERE Sample Status NORMAL ABNORMAL WEAR METALS PQ ASTM D8184* **6** 54 2 Iron ASTM D5185(m) >20 105 2 ppm 30 Chromium ppm ASTM D5185(m) >20 0 <1 Nickel ASTM D5185(m) >20 7 0 0 ppm 0 Titanium ppm ASTM D5185(m) 0 0 Silver ASTM D5185(m) 0 0 ppm <1 Aluminum ASTM D5185(m) >20 0 <1 0 ppm ASTM D5185(m) >20 3 Lead <1 4 ppm Copper ppm ASTM D5185(m) >20 1 33 35 ASTM D5185(m) >20 0 <1 Tin ppm 1 Antimony ppm ASTM D5185(m) 0 Vanadium ASTM D5185(m) 0 0 0 ppm Beryllium ASTM D5185(m) 0 ppm Cadmium ASTM D5185(m) 0 ppm **ADDITIVES** ASTM D5185(m) 0 <1 0 0 Boron maa ASTM D5185(m) O Barium ppm <1 <1 <1 3 Molybdenum ppm ASTM D5185(m) 0 <1 <1 0 0 Manganese ppm ASTM D5185(m) 1 Magnesium ASTM D5185(m) 5 0 <1 <1 ppm 27 29 Calcium ASTM D5185(m) 50 49 ppm Phosphorus ASTM D5185(m) 330 313 341 362 ppm 420 396 394 Zinc ppm ASTM D5185(m) 423 Sulfur ASTM D5185(m) 3100 687 2514 2665 ppm Lithium ppm ASTM D5185(m) <1 CONTAMINANTS history1 Silicon ASTM D5185(m) >15 <1 4 5 ppm Sodium ppm ASTM D5185(m) <1 1 <1 Potassium ASTM D5185(m) >20 0 0 0 ppm FLUID CLEANLINESS Particles >4µm ASTM D7647 202248 937 13191 Particles >6µm ASTM D7647 >1300 145727 178 3941 Particles >14µm ASTM D7647 >160 5552 20 388 6 Particles >21µm ASTM D7647 >40 126 141 Particles >38µm ASTM D7647 4 >10 1 10

Particles >71µm

Oil Cleanliness

ASTM D7647 >3

ISO 4406 (c) >--/17/14

0

25/24/20

0

17/15/11

21/19/16



491,520 122 880

122,000

1

30,720

7,680

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920

1,920</t

250

Ê 200


·왕 김 150년

100 50

OIL ANALYSIS REPORT

cle Count	FLUID DEGRAD	ATION	method	limit/base	current	history1
		mg KOH/g	ASTM D974*	.40	0.40	0.198
	20 🛔 VISUAL		method	limit/base	current	history1
	White Metal Vellow Metal	scalar	Visual*	NONE	NONE	NONE
	14 Yellow Metal	scalar	Visual*	NONE	NONE	NONE
		scalar	Visual*	NONE	NONE	NONE
	Silt	scalar	Visual*	NONE	NONE	NONE
14µ 21µ 38µ 7	6 Debris	scalar	Visual*	NONE	NONE	NONE
14µ 21µ 30µ 7	Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
	Appearance	scalar	Visual*	NORML	NORML	NORML
	Odor	scalar	Visual*	NORML	NORML	NORML
	Emulsified Water	scalar	Visual*	>0.05	NEG	NEG
	Free Water	scalar	Visual*		NEG	NEG
	FLUID PROPER	RTIES	method	limit/base	current	history1
	Visc @ 40°C	cSt	ASTM D7279(m)	68.8	65.9	46.3
Apr5/01 Dec18/02 Jun13/04 Jan12/06 Mar5/07	Visc @ 100°C	cSt	ASTM D7279(m)	8.7	9	
Apr5/01 Dec18/02 Jan12/06 Mar5/07	Viscosity Index (VI)	Scale	ASTM D2270*	97	111	
/S	SAMPLE IMAG	ES	method	limit/base	current	history1
mium el	Color					
- ~~ ~	Bottom					

🔺 PQ 250 200 150 Ы 100 50 Π. 0ct26/23



: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : PC0069857 Received :08 Nov 2023 : 02595017 Diagnosed : 10 Nov 2023 : 5672096 Diagnostician : Bill Quesnel Test Package : IND 2 (Additional Tests: KV100, PQ, VI) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Dryden Fibre Box 3001, 1 Duke Street Dryden, ON CA P8N 2Z7 Contact: Adebukola Adekanye AADEKANYE@DRYDENFIBRE.CA T: (807)223-9950 F: (807)223-9176

0.34

NONE

NONE NONE

NONE

VLITE

NONE

NORML

NORML

NEG

NEG

47.9

Unique Number