


# PROBLEM SUMMARY


Area  
**TEAM 3**  
Machine Id  
**166125**  
Component  
**Hydraulic System**  
Fluid  
**PETRO CANADA HYDREX AW 46 (3900 LTR)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	SEVERE	NORMAL
Particles >4µm	ASTM D7647 >5000	▲ 31217	● 105211	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 22/17/12	● 24/20/12	---

Customer Id: CANDRY  
Sample No.: PC0069913  
Lab Number: 02595203  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

### 27 Sep 2023 Diag: Wes Davis

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 08 Aug 2023 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

view report



### 19 Jul 2023 Diag: Wes Davis

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

view report



Area  
**TEAM 3**  
Machine Id  
**166125**  
Component  
**Hydraulic System**  
Fluid  
**PETRO CANADA HYDREX AW 46 (3900 LTR)**



## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC0069913</b>	PC0069890	PC0074812
Sample Date	Client Info	<b>05 Oct 2023</b>	27 Sep 2023	08 Aug 2023
Machine Age	mths	Client Info	0	0
Oil Age	mths	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	SEVERE	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>20	<1	<1
Chromium	ppm	ASTM D5185(m)	>20	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	0
Titanium	ppm	ASTM D5185(m)		0	0
Silver	ppm	ASTM D5185(m)		<1	0
Aluminum	ppm	ASTM D5185(m)	>20	0	<1
Lead	ppm	ASTM D5185(m)	>20	<1	0
Copper	ppm	ASTM D5185(m)	>20	1	1
Tin	ppm	ASTM D5185(m)	>20	0	0
Antimony	ppm	ASTM D5185(m)		0	0
Vanadium	ppm	ASTM D5185(m)		0	0
Beryllium	ppm	ASTM D5185(m)		0	0
Cadmium	ppm	ASTM D5185(m)		0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0	<1	<1
Barium	ppm	ASTM D5185(m)	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	0	<1
Calcium	ppm	ASTM D5185(m)	50	13	13
Phosphorus	ppm	ASTM D5185(m)	330	324	325
Zinc	ppm	ASTM D5185(m)	430	280	290
Sulfur	ppm	ASTM D5185(m)	760	898	825
Lithium	ppm	ASTM D5185(m)		<1	<1

## CONTAMINANTS






method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	<1	<1
Sodium	ppm	ASTM D5185(m)		0	<1
Potassium	ppm	ASTM D5185(m)	>20	0	0

## FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>5000	<b>31217</b>	105211	---
Particles >6µm	ASTM D7647	>1300	<b>811</b>	5634	---
Particles >14µm	ASTM D7647	>160	<b>33</b>	37	---
Particles >21µm	ASTM D7647	>40	<b>6</b>	11	---
Particles >38µm	ASTM D7647	>10	<b>1</b>	1	---
Particles >71µm	ASTM D7647	>3	<b>1</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>22/17/12</b>	24/20/12	---

## FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.70	<b>0.37</b>	0.34







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	VLITE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46.4	45.5	45.6
Visc @ 100°C	cSt	ASTM D7279(m)	6.92	7.4	7.3
Viscosity Index (VI)	Scale	ASTM D2270*	104	126	125

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0069913 **Received** : 08 Nov 2023  
**Lab Number** : 02595203 **Diagnosed** : 09 Nov 2023  
**Unique Number** : 5672282 **Diagnostician** : Wes Davis  
**Test Package** : IND 2 ( Additional Tests: KV100, TAN Man, VI )

**Dryden Fibre**  
 Box 3001, 1 Duke Street  
 Dryden, ON  
 CA P8N 2Z7  
 Contact: Adebukola Adekanye  
 AADEKANYE@DRYDENFIBRE.CA  
 T: (807)223-9950  
 F: (807)223-9176

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.