



# COOLANT REPORT

Sample Rating Trend


PH



Machine Id  
**OR483**

Component  
**Coolant**  
Fluid

**EXTENDED LIFE COOLANT (--- GAL)**



## DIAGNOSIS

### Recommendation

Nous recommandons la vidange du système et le remplissage avec un mélange 50/50 d'antigel longue durée et d'eau. Échantillonner de nouveau l'équipement au prochain intervalle de vidange afin d'en surveiller la condition.

### Corrosion

Les concentrations de tous les métaux sont normales indiquant qu'il n'y a pas de corrosion dans le système de refroidissement.

### Contaminants

Il n'y a aucun indice de contamination dans l'agent de refroidissement.

### Coolant Condition

Le niveau de nitrite est acceptable. Le pH est bas et peut entraîner la formation de rouille. La réserve d'alcalinité de ce fluide est acceptable.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>GFL0089225</b>	GFL0061620	GFL0061602
Sample Date	Client Info	<b>11 Nov 2023</b>	27 Sep 2023	12 Jun 2023
Machine Age	hrs	<b>11770</b>	11453	10900
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	NORMAL	NORMAL

## PHYSICAL TEST RESULTS

method	limit/base	current	history1	history2
Specific Gravity	ASTM D1298*	<b>1.071</b>	1.070	1.070
pH	Scale 0-14	<b>6.88</b>	7.08	7.29
Nitrites	ppm	<b>1600</b>	520	1000
Reserve Alkalinity	Scale 0-20	<b>2.8</b>	3.3	3.5
Percentage Glycol	%	<b>53.2</b>	52.6	52.5
Freezing Point	°C	<b>-43</b>	-40	-40
Carboxylate		---	---	---

## CORROSION INHIBITORS

method	limit/base	current	history1	history2
Silicon	ppm	<b>53</b>	64	78
Phosphorus	ppm	<b>86</b>	66	98
Boron	ppm	<b>438</b>	496	536
Molybdenum	ppm	<b>157</b>	178	178

## CORROSION

method	limit/base	current	history1	history2
Iron	ppm	<b>2</b>	1	5
Aluminum	ppm	<b>2</b>	<1	2
Copper	ppm	<b>2</b>	3	6
Lead	ppm	<b>0</b>	0	<1
Tin	ppm	<b>0</b>	0	0
Silver	ppm	<b>&lt;1</b>	<1	1
Zinc	ppm	<b>2</b>	1	4

## CARRIER SALTS


method	limit/base	current	history1	history2
Sodium	ppm	<b>7529</b>	6898	3567
Potassium	ppm	<b>2270</b>	2200	1365

## SCALE POTENTIAL

method	limit/base	current	history1	history2
Calcium	ppm	<b>6</b>	3	11
Magnesium	ppm	<b>2</b>	2	3
Hardness	mg/L CaCO3	<b>20</b>	16	40



## VISUAL

method	limit/base	current	history1	history2
Coolant Color	Visual*	Orange/R <b>Red</b>	Orange	Red
Coolant Appearance	Visual*	<b>Clear</b>	Clear	Clear











# COOLANT REPORT



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 GFL Environmental - 784 - Saint-Hyacinthe  
**Sample No.** : GFL0089225 **Received** : 15 Nov 2023 3525 Boul. Laurier Est.,  
**Lab Number** : 02596706 **Diagnosed** : 16 Nov 2023 Saint-Hyacinthe, QC  
**Unique Number** : 5681786 **Diagnostician** : Kevin Marson CA J2R 2B2  
**Test Package** : COOL

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

Contact: Nadine Authier nauthier@matrec.ca T: (450)773-9689 F: