

OIL ANALYSIS REPORT

Sample Rating Trend



Area Tractors Machine Id UTL003 Component

Component Front Differential

Fluid PETRO CANADA DURATRAN (--- LTR)

DIAGNOSIS

Recommendation

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The condition of the oil is acceptable for the time in service.


			Jan2023	Nov2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC0075072	PC0067304	
Sample Date		Client Info		14 Nov 2023	25 Jan 2023	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>.2	NEG	NEG	
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>500	72	213	
Chromium	ppm	ASTM D5185(m)	>10	<1	1	
Nickel	ppm	ASTM D5185(m)	>10	<1	<1	
Titanium	ppm	ASTM D5185(m)		0	2	
Silver	ppm	ASTM D5185(m)		<1	0	
Aluminum	ppm	ASTM D5185(m)	>25	4	24	
Lead	ppm	ASTM D5185(m)	>25	2	4	
Copper	ppm	ASTM D5185(m)	>100	46	128	
Tin	ppm	ASTM D5185(m)	>10	1	6	
Antimony	ppm	ASTM D5185(m)	>5	<1	2	
Vanadium	ppm	ASTM D5185(m)		0	<1	
Beryllium	ppm	ASTM D5185(m)		0	0	
Cadmium	ppm	ASTM D5185(m)		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	110	9	100	
Barium	ppm	ASTM D5185(m)	0.0	<1	0	
Molybdenum	ppm	ASTM D5185(m)	0.0	<1	3	
Manganese	ppm	ASTM D5185(m)	1	<1	2	
Magnesium	ppm	ASTM D5185(m)	13	14	35	
Calcium	ppm	ASTM D5185(m)	3610	2091	3399	
Phosphorus	ppm	ASTM D5185(m)	1192	852	1178	
Zinc	ppm	ASTM D5185(m)	1455	946	1319	
Sulfur	ppm	ASTM D5185(m)	2641	2967	2816	
Lithium	ppm	ASTM D5185(m)		6	24	
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>75	18	107	
Sodium	ppm	ASTM D5185(m)		12	27	
Potassium	ppm	ASTM D5185(m)	>20	7	10	



OIL ANALYSIS REPORT







VISUAL		method				history2	
White Metal	scalar	Visual*	NONE	NONE	NONE		
ellow Metal	scalar	Visual*	NONE	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE	NONE		
Debris	scalar	Visual*	NONE	VLITE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE		
ppearance	scalar	Visual*	NORML	NORML	NORML		
Ddor	scalar	Visual*	NORML	NORML	NORML		
Emulsified Water	scalar	Visual*	>.2	NEG	NEG		
ree Water	scalar	Visual*		NEG	NEG		
FLUID PROPE	RTIES	method	limit/base	current	history1	history2	
/isc @ 40°C	cSt	ASTM D7279(m)	55.14	63.9	57.7		
/isc @ 100°C	cSt	ASTM D7279(m)	9.38	10.8	8.8		
iscosity Index (VI)	Scale	ASTM D2270*	153	160	128		
SAMPLE IMAG	FS	method	limit/base	current	history1	history2	
		method					
ala.						/	
Color						no image	
					6		
ottom					C° Co	no image	
GRAPHS							
Iron (ppm)				Lead (ppm)			
Severe			200				
Abnormal			<u>6</u> 100	Abnormal			
8			8				
Jan25/2			Nov14/23	Jan25/23			
Aluminum (ppm)				Chromium (p	pm)		
It				40 Severe			
Severe Abnormal			<u></u> 20	Abnormal			
- 23				8			
Jan 25,			Nov14/23	Jan 25/23			
Copper (ppm)				Silicon (ppm)			
Severe			400 E and	-			
Abnormal			<u>§</u> 200	Abnormal			
Jan 25/23 -			Nov14/23	Jan 25/23			
in-			Nai	in .			
Viscosity @ 40°C			4000	Additives			
Abnormal				calcium			
Abnormal			<u>6</u> 2000	www.www.www.znc			
12			4/23				
Jan 25/			Nov14/22	Jan 25/			
VearCheck - C8-11 2C0075072	75 Apple Receive		lington, ON L Nov 2023	.7L 5H9 La	akeshore Gold T	immins We	
	Diagnos		Nov 2023 Nov 2023			Timmins, O	
	Diagnost		s Davis			CA	
MOB 1 (Additional					Contact: Ac	lam Kosciela	

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Laboratory

Sample No. Lab Number

Unique Number Test Package

CALA

ISO 17025:2017 Accredited Laboratory

T:

F:

adam.koscielak@HFSinclair.com