



Machine Id  
**WEICHAI J-BEND WEICHAI**  
Component  
**Propane Engine**  
Fluid  
**PETRO-CANADA SENTRON VTP 10W40 (--- GAL)**

**DIAGNOSIS**

**Recommendation**

Check for low coolant level. The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

**Wear**

Copper ppm levels are abnormal. Bearing wear is indicated.

**Contamination**

Water treatment chemicals present, indicating slow coolant leak. Test for glycol is negative. There is no indication of any contamination in the oil.

**Fluid Condition**

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear. The condition of the oil is acceptable for the time in service (see recommendation).

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>PC0078878</b>	PC0073831	---
Sample Date	Client Info			<b>01 Nov 2023</b>	28 Aug 2023	---
Machine Age	hrs	Client Info		<b>11457</b>	10910	---
Oil Age	hrs	Client Info		<b>546</b>	0	---
Oil Changed	Client Info			<b>Changed</b>	Changed	---
Sample Status				<b>ABNORMAL</b>	ABNORMAL	---

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.1	<b>NEG</b>	NEG	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>100	<b>5</b>	4	---
Chromium	ppm	ASTM D5185(m)	>25	<b>0</b>	0	---
Nickel	ppm	ASTM D5185(m)	>5	<b>&lt;1</b>	<1	---
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Silver	ppm	ASTM D5185(m)	>5	<b>&lt;1</b>	0	---
Aluminum	ppm	ASTM D5185(m)	>20	<b>3</b>	2	---
Lead	ppm	ASTM D5185(m)	>25	<b>3</b>	2	---
Copper	ppm	ASTM D5185(m)	>35	<b>▲ 59</b>	▲ 46	---
Tin	ppm	ASTM D5185(m)	>8	<b>0</b>	0	---
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	---
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<b>14</b>	17	---
Barium	ppm	ASTM D5185(m)	0	<b>0</b>	0	---
Molybdenum	ppm	ASTM D5185(m)	0	<b>0</b>	<1	---
Manganese	ppm	ASTM D5185(m)	0	<b>0</b>	<1	---
Magnesium	ppm	ASTM D5185(m)	5	<b>7</b>	7	---
Calcium	ppm	ASTM D5185(m)	1239	<b>1098</b>	1080	---
Phosphorus	ppm	ASTM D5185(m)	677	<b>620</b>	638	---
Zinc	ppm	ASTM D5185(m)	797	<b>816</b>	791	---
Sulfur	ppm	ASTM D5185(m)	2660	<b>2373</b>	2372	---
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	---


CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>50	<b>11</b>	8	---
Sodium	ppm	ASTM D5185(m)		<b>▲ 328</b>	▲ 222	---
Potassium	ppm	ASTM D5185(m)	>20	<b>12</b>	0	---

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		<b>0</b>	0	---
Nitration	Abs/cm	ASTM D7624*	>20	<b>6.7</b>	5.1	---
Sulfation	Abs/.1mm	ASTM D7415*	>30	<b>18.4</b>	16.3	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	>25	<b>11.1</b>	8.5	---
Acid Number (AN)	mg KOH/g	ASTM D974*	1.59	<b>0.77</b>	0.87	---

# OIL ANALYSIS REPORT

### ▲ Non-ferrous Metals




VISUAL	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	104.1	99.2	103
Visc @ 100°C	cSt	ASTM D7279(m)	15.1	14.1	14.6
Viscosity Index (VI)	Scale	ASTM D2270*	151	145	146

### GRAPHS

### ▲ Glycol Contamination



### Iron (ppm)




### Lead (ppm)



### Viscosity @ 40°C




### Aluminum (ppm)




### Chromium (ppm)




### Viscosity @ 100°C




### ▲ Copper (ppm)




### Silicon (ppm)




### Viscosity @ 40°C



### Viscosity @ 100°C



### Acid Number



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0078878 **Received** : 24 Nov 2023  
**Lab Number** : 02598782 **Diagnosed** : 24 Nov 2023  
**Unique Number** : 5683862 **Diagnostician** : Kevin Marson  
**Test Package** : MOB 2 ( Additional Tests: KV40, TAN Man, VI )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**Martin Energy Group Canada**  
 1050 Boyde Lane RR#1  
 Linwood, ON  
 CA N0B 2A0  
 Contact: J Wagler  
 jwagler@martinenergygroup.com

T:  
F: