

Machine Id  
**KENWORTH 2049**

Component  
**Diesel Engine**

Fluid  
**PETRO CANADA DURON SHP 10W30 (--- GAL)**

**DIAGNOSIS**

**Recommendation**

Resample at the next service interval to monitor.

**Wear**

Metal levels are typical for a new component breaking in.

**Contamination**

Elevated aluminum (Al) and/or lead (Pb) and potassium (K) levels in your metals analysis are likely a result of solder flux release into the lubricant and is common on new equipment/components. There is no indication of any contamination in the oil.

**Fluid Condition**

The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>PC0075841</b>	PC0075843	---
Sample Date	Client Info			<b>24 Nov 2023</b>	08 Sep 2023	---
Machine Age	kms	Client Info		<b>25500</b>	624	---
Oil Age	kms	Client Info		<b>25500</b>	624	---
Oil Changed	Client Info			<b>Changed</b>	Changed	---
Sample Status				<b>NORMAL</b>	NORMAL	---

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>5		<b>&lt;1.0</b>	<1.0	---
Water	WC Method	>0.2		<b>NEG</b>	NEG	---
Glycol	WC Method			<b>NEG</b>	NEG	---



WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>100	<b>24</b>	46	---
Chromium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	---
Nickel	ppm	ASTM D5185(m)	>4	<b>&lt;1</b>	<1	---
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Silver	ppm	ASTM D5185(m)	>3	<b>&lt;1</b>	<1	---
Aluminum	ppm	ASTM D5185(m)	>20	<b>21</b>	9	---
Lead	ppm	ASTM D5185(m)	>40	<b>&lt;1</b>	2	---
Copper	ppm	ASTM D5185(m)	>330	<b>17</b>	69	---
Tin	ppm	ASTM D5185(m)	>15	<b>&lt;1</b>	<1	---
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	---
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	---
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	2	<b>4</b>	32	---
Barium	ppm	ASTM D5185(m)	0	<b>&lt;1</b>	1	---
Molybdenum	ppm	ASTM D5185(m)	50	<b>56</b>	21	---
Manganese	ppm	ASTM D5185(m)	0	<b>&lt;1</b>	1	---
Magnesium	ppm	ASTM D5185(m)	950	<b>940</b>	774	---
Calcium	ppm	ASTM D5185(m)	1050	<b>1132</b>	1352	---
Phosphorus	ppm	ASTM D5185(m)	995	<b>967</b>	807	---
Zinc	ppm	ASTM D5185(m)	1180	<b>1191</b>	922	---
Sulfur	ppm	ASTM D5185(m)	2600	<b>2384</b>	2434	---
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	<b>6</b>	12	---
Sodium	ppm	ASTM D5185(m)		<b>2</b>	4	---
Potassium	ppm	ASTM D5185(m)	>20	<b>51</b>	34	---

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	>3	<b>0.1</b>	0	---
Nitration	Abs/cm	ASTM D7624*	>20	<b>9.4</b>	9.3	---
Sulfation	Abs./1mm	ASTM D7415*	>30	<b>20.7</b>	21.2	---

# OIL ANALYSIS REPORT











FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs./1mm	ASTM D7414*	>25	<b>16.9</b>	16.1	---

VISUAL		method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.2	<b>NEG</b>	NEG	---
Free Water	scalar	Visual*		<b>NEG</b>	NEG	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	80.1	<b>77.4</b>	79.5	---
Visc @ 100°C	cSt	ASTM D7279(m)	12.00	<b>11.5</b>	11.8	---
Viscosity Index (VI)	Scale	ASTM D2270*	144	<b>140</b>	142	---

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0075841 **Received** : 28 Nov 2023  
**Lab Number** : **02599254** **Diagnosed** : 28 Nov 2023  
**Unique Number** : 5684334 **Diagnostician** : Wes Davis  
**Test Package** : MOB 1 ( Additional Tests: KV40, VI )

**B FREGEAU & FILS INC**  
 402 RUE ST DENIS  
 ST ALEXANDRE, QC  
 CA J0J 1S0  
 Contact: Steve M.  
 stevem@bfregeau.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.