


# PROBLEM SUMMARY


Sample Rating Trend



Machine Id  
**PRESS #7 (S/N MP-45441)**  
Component  
**Hydraulic System**  
Fluid  
**PETRO CANADA HYDREX AW 68 (2000 GAL)**

## COMPONENT CONDITION SUMMARY

### ▲ Non-ferrous Metals



## RECOMMENDATION

Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ATTENTION</b>	ATTENTION	ABNORMAL
Copper	ppm	ASTM D5185(m)	>20	<b>▲ 80</b>	▲ 77	50

**Customer Id:** EXTWOO  
**Sample No.:** PC0076126  
**Lab Number:** 02600530  
**Test Package:** IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

## HISTORICAL DIAGNOSIS

### 02 Jun 2023 Diag: Kevin Marson

#### WEAR



Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. Copper ppm levels are noted. All other component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed).

view report




### 03 Nov 2022 Diag: Kevin Marson

#### ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Component wear rates appear to be normal (unconfirmed). Oil Cleanliness are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >14µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed). The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 22 Jun 2022 Diag: Kevin Marson

#### WEAR



Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. Copper ppm levels are noted. All other component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed).


view report



Machine Id  
**PRESS #7 (S/N MP-45441)**

Component  
**Hydraulic System**

Fluid  
**PETRO CANADA HYDREX AW 68 (2000 GAL)**



**DIAGNOSIS**

**Recommendation**

Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

**Wear**

Copper ppm levels are noted. All other component wear rates are normal.

**Contamination**

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed).

**SAMPLE INFORMATION**

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC0076126</b>	PC0076129	PC0062187
Sample Date	Client Info	<b>30 Nov 2023</b>	02 Jun 2023	03 Nov 2022
Machine Age	yrs	Client Info	0	0
Oil Age	yrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ATTENTION</b>	ATTENTION	ABNORMAL

**CONTAMINATION**

method	limit/base	current	history1	history2
Water	WC Method >0.05	<b>NEG</b>	NEG	NEG

**WEAR METALS**

method	limit/base	current	history1	history2	
PQ	ASTM D8184*	<b>0</b>	0	0	
Iron	ppm	ASTM D5185(m) >20	<b>39</b>	35	23
Chromium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>&lt;1</b>	0	0
Aluminum	ppm	ASTM D5185(m) >20	<b>8</b>	8	6
Lead	ppm	ASTM D5185(m) >20	<b>9</b>	8	4
Copper	ppm	ASTM D5185(m) >20	<b>▲ 80</b>	▲ 77	50
Tin	ppm	ASTM D5185(m) >20	<b>1</b>	1	<1
Antimony	ppm	ASTM D5185(m)	<b>0</b>	<1	<1
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

**ADDITIVES**


method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m) 0	<b>&lt;1</b>	<1	<1
Barium	ppm	ASTM D5185(m) 0	<b>&lt;1</b>	<1	<1
Molybdenum	ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m) 0	<b>&lt;1</b>	1	<1
Magnesium	ppm	ASTM D5185(m) 0	<b>59</b>	60	59
Calcium	ppm	ASTM D5185(m) 50	<b>100</b>	103	88
Phosphorus	ppm	ASTM D5185(m) 330	<b>563</b>	588	440
Zinc	ppm	ASTM D5185(m) 430	<b>527</b>	511	518
Sulfur	ppm	ASTM D5185(m) 760	<b>1816</b>	1791	1464
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	1

**CONTAMINANTS**

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >15	<b>3</b>	3	2
Sodium	ppm	ASTM D5185(m)	<b>4</b>	4	2
Potassium	ppm	ASTM D5185(m) >20	<b>0</b>	<1	<1

# OIL ANALYSIS REPORT

## ▲ Non-ferrous Metals




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>3304</b>	4387	▲ 19744
Particles >6µm	ASTM D7647	>1300	<b>672</b>	779	▲ 4556
Particles >14µm	ASTM D7647	>160	<b>48</b>	47	▲ 192
Particles >21µm	ASTM D7647	>40	<b>12</b>	8	34
Particles >38µm	ASTM D7647	>10	<b>1</b>	0	2
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	1
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>19/17/13</b>	19/17/13	▲ 21/19/15

FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974*	0.60	<b>0.69</b>	0.71	0.58


VISUAL	method	limit/base	current	history1	history2
White Metal	scalar Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar Visual*	>0.05	<b>NEG</b>	NEG	NEG
Free Water	scalar Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D7279(m)	67.4	<b>66.3</b>	61.2	64.5
Visc @ 100°C	cSt ASTM D7279(m)	8.9	<b>9</b>	9	8.8
Viscosity Index (VI)	Scale ASTM D2270*	105	<b>110</b>	123	109


## SAMPLE IMAGES




## Particle Count




## Acid Number



## Viscosity @ 100°C



## Viscosity @ 40°C



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0076126 **Received** : 04 Dec 2023  
**Lab Number** : **02600530** **Diagnosed** : 05 Dec 2023  
**Unique Number** : 5685610 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: KV100, PQ, VI )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**EXTRUDEX ALUMINIUM**  
 411 CHRISLEA ROAD  
 WOODBRIDGE, ON  
 CA L4L 8N4  
 Contact: Daljeet Munday  
 dmunday@extrudex.com  
 T: (416)745-4444  
 F: (416)745-0925