


# PROBLEM SUMMARY


Area  
**1311**  
Machine Id  
**CRUSHER LUBE SYSTEM**  
Component  
**Gear Lube System**  
Fluid  
**PETRO CANADA ENDURATEX EP 320 (1703 LTR)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

Particle Trend



## RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE
Particles >4µm	ASTM D7647	>20000	🔴 253066	🔴 198745	🟡 158581
Particles >6µm	ASTM D7647	>5000	🔴 202713	🔴 134527	🔴 82768
Particles >14µm	ASTM D7647	>640	🔴 34794	🔴 6625	514
Particles >21µm	ASTM D7647	>160	🔴 2636	🟡 227	6
Oil Cleanliness	ISO 4406 (c)	>21/19/16	🔴 25/25/22	🔴 25/24/20	🔴 24/24/16

Customer Id: INCVOS  
Sample No.: PC0058539  
Lab Number: 02601053  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

### 10 Oct 2023 Diag: Wes Davis

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 02 Sep 2023 Diag: Wes Davis

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 21 Jun 2023 Diag: Wes Davis

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





Area  
**1311**  
Machine Id  
**CRUSHER LUBE SYSTEM**

Component  
**Gear Lube System**  
Fluid  
**PETRO CANADA ENDURATEX EP 320 (1703 LTR)**



**DIAGNOSIS**

**Recommendation**  
We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

**Wear**  
All component wear rates are normal.

**Contamination**  
There is a high amount of particulates (2 to 100 microns in size) present in the oil.

**Fluid Condition**  
The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

**SAMPLE INFORMATION**

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC0058539</b>	PC0058536	PC0070103
Sample Date	Client Info	<b>18 Nov 2023</b>	10 Oct 2023	02 Sep 2023
Machine Age	days	<b>0</b>	0	0
Oil Age	days	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>SEVERE</b>	SEVERE	SEVERE

**CONTAMINATION**

method	limit/base	current	history1	history2
Water	WC Method >0.1	<b>NEG</b>	NEG	NEG

**WEAR METALS**

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185(m) >150	<b>77</b>	41	26
Chromium	ppm ASTM D5185(m) >10	<b>0</b>	0	0
Nickel	ppm ASTM D5185(m) >10	<b>3</b>	2	2
Titanium	ppm ASTM D5185(m)	<b>&lt;1</b>	0	<1
Silver	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	0
Aluminum	ppm ASTM D5185(m) >25	<b>13</b>	8	5
Lead	ppm ASTM D5185(m) >100	<b>9</b>	9	8
Copper	ppm ASTM D5185(m) >50	<b>24</b>	20	16
Tin	ppm ASTM D5185(m) >10	<b>4</b>	3	3
Antimony	ppm ASTM D5185(m) >5	<b>0</b>	0	0
Vanadium	ppm ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm ASTM D5185(m)	<b>0</b>	0	0

**ADDITIVES**

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m) 55	<b>11</b>	10	11
Barium	ppm ASTM D5185(m) 0	<b>&lt;1</b>	<1	0
Molybdenum	ppm ASTM D5185(m) 0	<b>0</b>	0	0
Manganese	ppm ASTM D5185(m) 0	<b>&lt;1</b>	0	<1
Magnesium	ppm ASTM D5185(m) 0	<b>10</b>	6	5
Calcium	ppm ASTM D5185(m) 0	<b>11</b>	7	5
Phosphorus	ppm ASTM D5185(m) 240	<b>193</b>	201	222
Zinc	ppm ASTM D5185(m) 1	<b>4</b>	4	5
Sulfur	ppm ASTM D5185(m) 13700	<b>7790</b>	8002	8149
Lithium	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	<1






**CONTAMINANTS**

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >50	<b>34</b>	20	12
Sodium	ppm ASTM D5185(m)	<b>4</b>	3	2
Potassium	ppm ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1

**FLUID CLEANLINESS**

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	<b>253066</b>	198745	158581
Particles >6µm	ASTM D7647 >5000	<b>202713</b>	134527	82768
Particles >14µm	ASTM D7647 >640	<b>34794</b>	6625	514
Particles >21µm	ASTM D7647 >160	<b>2636</b>	227	6
Particles >38µm	ASTM D7647 >40	<b>6</b>	2	1
Particles >71µm	ASTM D7647 >10	<b>1</b>	1	1
Oil Cleanliness	ISO 4406 (c) >21/19/16	<b>25/25/22</b>	25/24/20	24/24/16

# OIL ANALYSIS REPORT




## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D974* 0.4	<b>0.70</b>	0.71	0.63
VISUAL				
method	limit/base	current	history1	history2
White Metal	scalar Visual* NONE	<b>VLITE</b>	NONE	NONE
Yellow Metal	scalar Visual* NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar Visual* NONE	<b>NONE</b>	NONE	NONE
Silt	scalar Visual* NONE	<b>NONE</b>	NONE	NONE
Debris	scalar Visual* NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar Visual* NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar Visual* NORML	<b>NORML</b>	NORML	NORML
Odor	scalar Visual* NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar Visual* >0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar Visual*	<b>NEG</b>	NEG	NEG

## FLUID PROPERTIES

method	limit/base	current	history1	history2
Visc @ 40°C cSt	ASTM D7279(m) 325	<b>319</b>	320	320
Visc @ 100°C cSt	ASTM D7279(m) 25.22	<b>24.8</b>	24.7	24.7
Viscosity Index (VI) Scale	ASTM D2270* 100	<b>99</b>	98	98

## SAMPLE IMAGES



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0058539  
**Lab Number** : **02601053**  
**Unique Number** : 5694138  
**Test Package** : IND 2 ( Additional Tests: KV100, TAN Man, VI )

**Vale - Voisey's Bay**  
 Voisey's Bay Mine Site, P.O. Box 7001, Str. C Happy Valley  
 Goose Bay, NL  
 CA A0P 1C0  
 Contact: Robert Feltham  
 robert.feltham@vale.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

T:  
F: x: