

FUEL REPORT

Sample Rating Trend

ISO

X



Component Diesel Fuel

No.2 DIESEL FUEL (LOW-SULPHUR) (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. Laboratory test indicate that this fuel is suitable for use and meets all test requirements. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you filter this fluid before use. Resample in 30-45 days to monitor this situation.

Corrosion

{not applicable}

Contaminants

There is a high amount of particulates (2 to 100 microns in size) present in the fuel. The water content is negligible.

Fuel Condition


The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels. All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel, low sulfur (US EPA/CGSB-3.517-3 type B).

AL)			Apr2023	Dec2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC	PC	
Sample Date		Client Info		06 Dec 2023	05 Apr 2023	
Machine Age	hrs	Client Info		0	0	
Sample Status	1113			SEVERE	ATTENTION	
-				SEVENE	ATTENTION	
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.847	0.843	
Fuel Color	text	Visual Screen*	Yllow	Yllow	Yllow	
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.9	2.7	
Pensky-Martens Flash Point	°C	ASTM D7215*	52	62	63.1	
SULFUR CON	ΓENT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	250	40	43	
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	174	175	
5% Distillation Point	°C	ASTM D2887*		199	198	
10% Distill Point	°C	ASTM D2887*	201	211	209	
15% Distillation Point	°C	ASTM D2887*		219	217	
20% Distill Point	°C	ASTM D2887*	216	227	225	
30% Distill Point	°C	ASTM D2887*	230	242	239	
40% Distill Point	°C	ASTM D2887*	243	254	252	
50% Distill Point	°C	ASTM D2887*	255	267	265	
60% Distill Point	°C	ASTM D2887*	267	279	278	
70% Distill Point	°C	ASTM D2887*	280	292	292	
80% Distill Point	°C	ASTM D2887*	295	306	308	
85% Distillation Point	°C	ASTM D2887*	200	317	319	
90% Distill Point	°C	ASTM D2887*	310	327	331	
95% Distillation Point	°C	ASTM D2887*	010	344	350	
Final Boiling Point	°C	ASTM D2887*	341	356	377	
IGNITION QUA		method	limit/base			
				current	history1	history2
API Gravity		ASTM D1298*	37.7	35	36	
Cetane Index		ASTM D4737*	<40.0	47	48	
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0	0	
Sodium	ppm	ASTM D5185(m)	<0.1	0	<1	
Potassium	ppm	ASTM D5185(m)	<0.1	<1	0	
Water	%	ASTM D6304*	<0.05	0.002	0.014	
ppm Water	ppm	ASTM D6304*	<500	25	145.9	
FLUID CLEANL	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	e 34239	2461	
Particles >6µm		ASTM D7647	>640	e 8151	<u> </u>	
Particles >14µm		ASTM D7647	>80	<u> </u>	23	
Particles >21µm		ASTM D7647	>20	🛑 184	3	
Particles >38µm		ASTM D7647	>4	<u> </u>	0	
Particles >71µm		ASTM D7647	>3	1	0	
Oil Cleanliness		ISO 4406 (c)	>18/16/13	e 22/20/16	▲ 18/17/12	

Contact/Location: Deanne Badcock - TERHAM



FUEL REPORT



190°0

30°

70°

50°0

50°C

ŧ0°C

30°C

20°C

Dec6/23 -

0%

20%

Gas Chromatography (GCD)

300

g 250

200

150




0



history1

0



: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Laboratory CALA Sample No. : PC Received : 07 Dec 2023 Lab Number : 02601728 Diagnosed : 11 Dec 2023 ISO 17025:2017 Diagnostician : Kevin Marson Accredited : 5694813 Unique Number Laboratory Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PrtCount) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

40%

70% 80% 90%

> Suncor - Terra Nova Projects Scotia Centre, 235 Water Strret St. John`s, NL CA A1C 1B6 Contact: Deanne Badcock dbadcock@suncor.com T: (709)778-3843 F: (709)724-2784

Report Id: TERHAM [WCAMIS] 02601728 (Generated: 12/11/2023 06:55:07) Rev: 1

Contact/Location: Deanne Badcock - TERHAM