


# PROBLEM SUMMARY


Area  
**Vessel**  
Machine Id  
**KAT 02 (AUTOFREEZERS)**  
Component  
**Hydraulic System**  
Fluid  
**SHELL TELLUS S4 VX 32 (500 LTR)**

Sample Rating Trend




## COMPONENT CONDITION SUMMARY

▲ Particle Trend



Additives



## RECOMMENDATION

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	NORMAL	NORMAL
Particles >4µm	ASTM D7647	>5000	▲ 31577	---	---
Particles >6µm	ASTM D7647	>1300	▲ 4793	---	---
Particles >14µm	ASTM D7647	>160	▲ 162	---	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 22/19/15	---	---

Customer Id: KATSHESH  
Sample No.: PC0080311  
Lab Number: 02601826  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

## HISTORICAL DIAGNOSIS

### 08 Nov 2022 Diag: Kevin Marson

NORMAL



Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MOB 2 test kits, this testkit includes Particle Count to determine the ISO cleanliness of the fluid. All component wear rates are normal. There is no indication of any contamination in the component (unconfirmed). Additive levels indicate the addition of a different brand, or type of oil. The condition of the oil is acceptable for the time in service.

view report



### 24 Jul 2022 Diag: Kevin Marson

NORMAL



Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MOB 2 test kits, this testkit includes Particle Count to determine the ISO cleanliness of the fluid. All component wear rates are normal. There is no indication of any contamination in the component (unconfirmed). Additive levels indicate the addition of a different brand, or type of oil. The condition of the oil is acceptable for the time in service.

view report



### 22 Dec 2021 Diag: Kevin Marson

NORMAL




Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the sample. Additive levels indicate the addition of a different brand, or type of oil. The condition of the sample is acceptable for the time in service.

view report



Area  
**Vessel**  
Machine Id  
**KAT 02 (AUTOFREEZERS)**  
Component  
**Hydraulic System**  
Fluid  
**SHELL TELLUS S4 VX 32 (500 LTR)**



## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC0080311</b>	PC0031769	PC0018569
Sample Date	Client Info	<b>22 Nov 2023</b>	08 Nov 2022	24 Jul 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

method	limit/base	current	history1	history2	
Water	WC Method	>0.05	<b>NEG</b>	NEG	NEG

## WEAR METALS

method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185(m)	>20	<b>17</b>	11	8
Chromium	ppm	ASTM D5185(m)	>10	<b>1</b>	<1	<1
Nickel	ppm	ASTM D5185(m)	>10	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	<1	<1
Silver	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>10	<b>&lt;1</b>	0	0
Lead	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1
Copper	ppm	ASTM D5185(m)	>20	<b>1</b>	1	<1
Tin	ppm	ASTM D5185(m)	>10	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	0
Barium	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185(m)		<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)		<b>0</b>	<1	0
Magnesium	ppm	ASTM D5185(m)		<b>3</b>	3	3
Calcium	ppm	ASTM D5185(m)		<b>23</b>	23	23
Phosphorus	ppm	ASTM D5185(m)		<b>302</b>	332	307
Zinc	ppm	ASTM D5185(m)		<b>242</b>	238	242
Sulfur	ppm	ASTM D5185(m)		<b>1059</b>	1108	1128
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1






## CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185(m)	>15	<b>1</b>	<1	<1
Sodium	ppm	ASTM D5185(m)		<b>5</b>	4	3
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1

## FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>5000	<b>▲ 31577</b>	---	---
Particles >6µm	ASTM D7647	>1300	<b>▲ 4793</b>	---	---
Particles >14µm	ASTM D7647	>160	<b>▲ 162</b>	---	---
Particles >21µm	ASTM D7647	>40	<b>30</b>	---	---
Particles >38µm	ASTM D7647	>10	<b>1</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>1</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>▲ 22/19/15</b>	---	---


# OIL ANALYSIS REPORT



FLUID DEGRADATION						
	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	<b>0.27</b>	---	---	
VISUAL						
	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	NONE	
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	
Precipitate	scalar	Visual*	NONE	NONE	NONE	
Silt	scalar	Visual*	NONE	NONE	NONE	
Debris	scalar	Visual*	NONE	NONE	NONE	
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	
Appearance	scalar	Visual*	NORML	NORML	NORML	
Odor	scalar	Visual*	NORML	NORML	NORML	
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG	
Free Water	scalar	Visual*		NEG	NEG	

FLUID PROPERTIES						
	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	33.8	<b>30.0</b>	29.9	36.0
Visc @ 100°C	cSt	ASTM D7279(m)	9.93	<b>5.9</b>	5.9	5.9
Viscosity Index (VI)	Scale	ASTM D2270*	300	<b>145</b>	146	106

SAMPLE IMAGES						
	method	limit/base	current	history1	history2	
Color						
Bottom						



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Ocean Choice International - Katsheshuk II  
**Sample No.** : PC0080311 **Received** : 08 Dec 2023 1315 Topsail Rd, P.O. Box 8190  
**Lab Number** : **02601826** **Diagnosed** : 11 Dec 2023 St. John's, NL  
**Unique Number** : 5694911 **Diagnostician** : Wes Davis CA A1B 3N4  
**Test Package** : IND 2 ( Additional Tests: KV100, VI ) Contact: Chief Engineer  
 katengine@oceanchoice.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.