


ESSO ZERICE S 68 (250 LTR)

PROBLEM SUMMARY

Area Vessel Machine Id KAT 014 (Refrigeration Compressors #1 & #2) Component Compressor Fluid

VISCOSITY

Sample Rating Trend



RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS									
Sample Status				ABNORMAL	ABNORMAL	ATTENTION			
Particles >4µm		ASTM D7647	>10000	<u> </u>					
Particles >6µm		ASTM D7647	>2500	<u> </u>					
Particles >14µm		ASTM D7647	>320	<u> </u>					
Oil Cleanliness		ISO 4406 (c)	>20/18/15	A 23/21/16					
Visc @ 100°C	cSt	ASTM D7279(m)	6.5	4.8	4 .7	9.8			

Customer Id: KATSHESH Sample No.: PC0080267 Lab Number: 02601876 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 <u>gloria.gonzalez@wearcheck.com</u>

RECOMMENDE	ED ACTIONS			
Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.
Resample			?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS



18 Oct 2023 Diag: Kevin Marson

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 46 range, advise investigate. The condition of the oil is acceptable for the time in service.



view report

08 Nov 2022 Diag: Kevin Marson



Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. Additive levels indicate the addition of a different brand, or type of oil. The condition of the oil is acceptable for the time in service.

24 Jul 2022 Diag: Kevin Marson





Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The oil viscosity is lower than typical, possibly indicating the addition of lighter grade oil. The condition of the oil is acceptable for the time in service.









OIL ANALYSIS REPORT

Area Vessel Machine Id KAT 014 (Refrigeration Compressors #1 & #2)

Compressor Fluid

ESSO ZERICE S 68 (250 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear


All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The oil viscosity is lower than typical, possibly indicating the addition of lighter grade oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



SAMPLE INFOR		method	limit/base	current	history1	history2	
Sample Number		Client Info		PC0080267	PC0018596	PC0031768	
Sample Date		Client Info		22 Nov 2023	18 Oct 2023	08 Nov 2022	
Machine Age	mths	Client Info	0 0		0	0	
Oil Age	mths	Client Info		0 0		0	
Oil Changed		Client Info		N/A		N/A	
Sample Status				ABNORMAL AB		ATTENTION	
WEAR METAL	R METALS method		limit/base current		history1	history2	
Iron	ppm	ASTM D5185(m)	>50	9	7	23	
Chromium	ppm	ASTM D5185(m)	>5	0	0	0	
Nickel	ppm	ASTM D5185(m)		<1	0	<1	
Titanium	ppm	ASTM D5185(m)		0	0	0	
Silver	ppm	ASTM D5185(m)		<1	<1	0	
Aluminum	ppm	ASTM D5185(m)	>15	0	0	0	
Lead	ppm	ASTM D5185(m)	>65	<1	<1	0	
Copper	ppm	ASTM D5185(m)	>65	2	1	1	
Tin	ppm	ASTM D5185(m)	>10	0	0	0	
Antimony	ppm	ASTM D5185(m)		<1	0	0	
Vanadium	ppm	ASTM D5185(m)		0	0	0	
Beryllium	ppm	ASTM D5185(m)		0	0	0	
Cadmium	ppm	ASTM D5185(m)		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		1	2	<1	
Barium	ppm	ASTM D5185(m)		0	<1	0	
Molybdenum	ppm	ASTM D5185(m)		0	0	0	
Manganese	ppm	ASTM D5185(m)		0	0	<1	
Magnesium	ppm	ASTM D5185(m)		0	0	4	
Calcium	ppm	ASTM D5185(m)		<1	0	4 2	
Phosphorus	ppm	ASTM D5185(m)		<1	<1	A 311	
Zinc	ppm	ASTM D5185(m)		1	<1	A 339	
Sulfur	ppm	ASTM D5185(m)		17	12	🔺 2352	
Lithium	ppm	ASTM D5185(m)		<1	1	<1	
CONTAMINAN	ITS	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>35	2	1	3	
Sodium	ppm	ASTM D5185(m)		8	<1	<1	
Potassium	ppm	ASTM D5185(m)	>20	24	0	0	
Water	%	ASTM D6304*	>0.1	0.002			
ppm Water	ppm	ASTM D6304*	>1000	17			
FLUID CLEAN	LINESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647	>10000	<u> 66101</u>			
Particles >6µm		ASTM D7647	>2500	<u> </u>			
Particles >14µm		ASTM D7647	>320	4 41			
Particles >21µm		ASTM D7647	>80	46			

ASTM D7647 >20

ASTM D7647 >4

1

0

ISO 4406 (c) >20/18/15 🔺 23/21/16

Particles >38µm

Particles >71µm

Oil Cleanliness



491,520 122,880

(TE 1000) 120 30 8

70 60 50 of particles (년 201

0.10 80.08 KOH/8 Ê 0.06 Pi 0.02 0.00

12000

OIL ANALYSIS REPORT

A	9NU311C3							
1,520-	Particle Count	FLUID DEGRAI		method	limit/base	current	history1	history2
2,880	Severe -24	Acid Number (AN)	mg KOH/g	ASTM D974*		0.08		
7,680	Abnormal -20 -18 -16 -14 -12 -10	VISUAL		method	limit/base	current	history1	history2
1,920 · 480 ·		White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
120	14	Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
30.	-12	Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
8.		Silt	scalar	Visual*	NONE	NONE	VLITE	NONE
2.		Debris	scalar	Visual*	NONE	NONE	NONE	VLITE
0 ₄		Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
11-	Viscosity @ 100°C	Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
10-		Odor	scalar	Visual*	NORML	NORML	NORML	NORML
9.		Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	NEG
cSt (100°C)	Abnormal Base	Free Water	scalar	Visual*		NEG	NEG	NEG
	d Abnormal	FLUID PROPE	RTIES	method	limit/base	current	history1	history2
4.		Visc @ 40°C	cSt	ASTM D7279(m)	64	57.9	44.8	64.0
3.	52 53 53		cSt	ASTM D7279(m)		4.8	4 .7	9.8
	Jul24/22 Nov8/22 Oct18/23	Viscosity Index (VI)	Scale	ASTM D2270*				136
	Particle Trend	SAMPLE IMAC	ES	method	limit/base	current	history1	history2
70k		-						
60k · 50k · 40k ·	4μm 6μm 14μm	Color						
30k - aquini 20k - 10k - 0k	Abnormal	Bottom						
	Jul24/22 Nov8/22 Oct18/23							
	Acid Number							
0.10								
₹0.08·								
2 20.06								
0.04								
0.02								
ξ 0.02.								
0.00	23	1						
	Jul24/22 Nov8/22 0ct18/23							
	Water (KF)							
12000	Sovere							
10000.								
8000.								
6000.								
4000.								
2000	Abnormal							
0.								
	Juil24/22 Nov8/22 Oct18/23							
	, 2							

