


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
1420
Machine Id
1420-5671-4005 - BALL MILL TRUNNION/PINION LUBE
Component
Bulk Fluid Tank
Fluid
PETRO CANADA ENDURATEX EP 320 (1000 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PC0058537	PC0070104	PC0070130
Sample Date	Client Info	30 Nov 2023	07 Oct 2023	02 Sep 2023
Machine Age	mths Client Info	0	0	0
Oil Age	mths Client Info	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	ABNORMAL	ATTENTION

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185(m)	<1	<1	<1
Chromium	ppm ASTM D5185(m)	0	0	0
Nickel	ppm ASTM D5185(m)	<1	<1	0
Titanium	ppm ASTM D5185(m)	0	0	0
Silver	ppm ASTM D5185(m)	<1	<1	0
Aluminum	ppm ASTM D5185(m)	0	0	<1
Lead	ppm ASTM D5185(m)	<1	0	0
Copper	ppm ASTM D5185(m)	<1	2	2
Tin	ppm ASTM D5185(m)	0	0	0
Antimony	ppm ASTM D5185(m)	0	0	0
Vanadium	ppm ASTM D5185(m)	0	0	0
Beryllium	ppm ASTM D5185(m)	0	0	0
Cadmium	ppm ASTM D5185(m)	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m) 55	44	52	49
Barium	ppm ASTM D5185(m) 0	<1	<1	0
Molybdenum	ppm ASTM D5185(m) 0	0	0	<1
Manganese	ppm ASTM D5185(m) 0	0	0	0
Magnesium	ppm ASTM D5185(m) 0	0	<1	<1
Calcium	ppm ASTM D5185(m) 0	2	1	1
Phosphorus	ppm ASTM D5185(m) 240	224	245	258
Zinc	ppm ASTM D5185(m) 1	5	5	6
Sulfur	ppm ASTM D5185(m) 13700	5477	6081	6259
Lithium	ppm ASTM D5185(m)	5	4	4






CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m)	1	2	1
Sodium	ppm ASTM D5185(m)	1	2	2
Potassium	ppm ASTM D5185(m) >20	0	<1	<1

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	2181	2582	▲ 9799
Particles >6µm	ASTM D7647 >1300	398	246	769
Particles >14µm	ASTM D7647 >160	28	24	60
Particles >21µm	ASTM D7647 >40	8	15	19
Particles >38µm	ASTM D7647 >10	3	11	2
Particles >71µm	ASTM D7647 >3	3	▲ 10	1
Oil Cleanliness	ISO 4406 (c) >19/17/14	18/16/12	19/15/12	▲ 20/17/13

OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.4	0.39	0.39	0.32

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*		NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	325	327	328	328
Visc @ 100°C	cSt	ASTM D7279(m)	25.22	25.1	25.1	25.2
Viscosity Index (VI)	Scale	ASTM D2270*	100	99	98	99

SAMPLE IMAGES



Color

Bottom



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0058537
Lab Number : **02602036**
Unique Number : 5695121
Test Package : IND 2 (Additional Tests: KV100, TAN Man, VI)

Vale - Voisey's Bay
 Voisey's Bay Mine Site, P.O. Box 7001, Str. C Happy Valley
 Goose Bay, NL
 CA A0P 1C0
 Contact: Robert Feltham
 robert.feltham@vale.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
F: