


## **OIL ANALYSIS REPORT**

## Area DIESEL GENERATING UNITS Machine Id CUMMINS AUXILIARY GENERATOR #1 (CAL007) (S/N 33217103)

Component Auxiliary Engine

Fluid

MOBIL DELVAC 1300 SUPER15W40 (500 LTR)



Sample Rating Trend




NORMAL


DIAGNOSIS	SAMPLE INFOF	RMATION	method	limit/base	current	history1	history2
Recommendation	Sample Number		Client Info		PC0010706	PC0011646	
Resample at the next service interval to monitor.	Sample Date		Client Info		09 Aug 2023	01 May 2023	
Wear	Machine Age	hrs	Client Info		5789	5157	
All component wear rates are normal.	Oil Age	hrs	Client Info		5789	236	
Contamination	Oil Changed		Client Info		N/A	Not Changd	
There is no indication of any contamination in the	Sample Status				NORMAL	NORMAL	
oil.							
Fluid Condition	CONTAMINA	ION	method	limit/base	current	history1	history2
The condition of the oil is acceptable for the time in	Fuel		WC Method	>4.0	<1.0	<1.0	
service.	Water		WC Method	>0.1	NEG	NEG	
	Glycol		WC Method		NEG	NEG	
	WEAR METAL	_S	method	limit/base	current	history1	history2
	Iron	ppm	ASTM D5185(m)	>100	3	2	
	Chromium	ppm	ASTM D5185(m)	>20	0	0	
	Nickel	ppm	ASTM D5185(m)	>2	0	<1	
	Titanium	ppm	ASTM D5185(m)	>2	0	0	
	Silver	ppm	ASTM D5185(m)		<1	0	
	Aluminum	ppm	ASTM D5185(m)	>20	<1	<1	
	Lead	ppm	ASTM D5185(m)	>40	3	<1	
	Copper	ppm	ASTM D5185(m)	>330	<1	<1	
	Tin	ppm	ASTM D5185(m)	>15	0	0	
	Antimony	ppm	ASTM D5185(m)		0	0	
	Vanadium	ppm	ASTM D5185(m)		0	0	
	Beryllium	ppm	ASTM D5185(m)		0	0	
	Cadmium	ppm	ASTM D5185(m)		0	0	
	ADDITIVES		method	limit/base	current	history1	history2
	Boron	ppm	ASTM D5185(m)	0	46	51	
	Barium	ppm	ASTM D5185(m)	0	<1	0	
	Molybdenum	ppm	ASTM D5185(m)	0	43	42	
	Manganese	ppm	ASTM D5185(m)		0	<1	
	Magnesium	ppm	ASTM D5185(m)	0	564	556	
	Calcium	ppm	ASTM D5185(m)		1708	1670	
	Phosphorus	ppm	ASTM D5185(m)		766	836	
	Zinc	ppm	ASTM D5185(m)		923	888	
	Sulfur	ppm	ASTM D5185(m)		2172	2248	
	Lithium	ppm	ASTM D5185(m)		<1	<1	
	CONTAMINA	NTS	method	limit/base	current	history1	history2
	Silicon	ppm	ASTM D5185(m)	>25	5	6	
	Sodium	ppm	ASTM D5185(m)		2	2	
	Potassium	ppm	ASTM D5185(m)	>20	0	0	
	INFRA-RED		method	limit/base	current	history1	history2
	Soot %	%	ASTM D7844*		0	0	
	Nitration	Abs/cm	ASTM D7624*	>20	7.4	6.0	
	Sulfation	Abs/.1mm	ASTM D7415*	>30	21.9	21.6	



## **OIL ANALYSIS REPORT**

FLUID DEGRADATION method





I LOID DEGNAL		methou	mmbase	Guircin	Thatory	motory
Oxidation	Abs/.1mm	ASTM D7414*	>25	20.4	19.3	
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML	NORML	
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	
Free Water	scalar	Visual*		NEG	NEG	
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	114	97.1	96.9	
Visc @ 100°C	cSt	ASTM D7279(m)	15.0	13.1	13.0	
Viscosity Index (VI)	Scale	ASTM D2270*	137	132	131	
GRAPHS						
Iron (ppm)				Lead (ppm)		
<sup>00</sup>			10	Severe		
200 - Severe			E 5	T		
00 - Abnormal			E 3	Abnormal		
0				, <u> </u>		
May1/23			Aug9/23	May1/23		Aur.9.03
			Au			V
Aluminum (ppm)			6	Chromium (p	pm)	
40 Severe			4	Savara		
Abnormal			L L L L L L L L L L L L L L L L L L L	Abnormal		
			2	) - Abnormal		
0						23
May 1/23			Aug9/23	May 1/23		Aur.9.03
Copper (ppm)				Silicon (ppm)		
100 Severe				Severe		
300			6	1		
200 -			4 dd	Automati		
0			2			
				~		56/6
May1/23			Aug9/23	May1/2		C.0.60114
Viscosity @ 100°C				Soot %		
Abnormal			15.			
15 Base			<sub>وم</sub> ا0.	) - Gevere		
Abnormal			Soo	Abnormal		

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Ocean Choice International - MV Calvert

Aug9/23 -

: 18 Dec 2023

0.0

May1/23



Lab Number : 02603688 Diagnosed : 18 Dec 2023 ISO 17025:2017 Accredited Laboratory Unique Number : 5696773 Diagnostician : Wes Davis Test Package : MOB 1 (Additional Tests: KV40, VI, Visual) Contact: Calvert Engine Control Room To discuss this sample report, contact Customer Service at 1-800-268-2131. calvertengine@oceanchoice.com Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Recieved

Abnormal

: PC0010706

cSt (

Laboratory

Sample No.

10 May1/23

CALA

1315 Topsail Rd, P.O. Box 8190

ua9/23

T:

F:

St. John`s, NL

CA A1B 3N4