


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
Cranes [450231373]
Machine Id
Crane - Fwd Hydraulic Reservoir (S/N Sample Tag MA-04003-S4)
Component
Hydraulic System
Fluid
PETRO CANADA ATF DEXRON III/MERCON (800 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PC0078235	PC	PC0053011
Sample Date	Client Info	27 Dec 2023	13 Aug 2023	02 May 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	NORMAL	SEVERE

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.05	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	0	0	0
Iron	ppm ASTM D5185(m) >20	<1	3	2
Chromium	ppm ASTM D5185(m) >10	0	0	0
Nickel	ppm ASTM D5185(m) >10	<1	0	<1
Titanium	ppm ASTM D5185(m)	0	0	0
Silver	ppm ASTM D5185(m)	0	0	0
Aluminum	ppm ASTM D5185(m) >10	<1	<1	<1
Lead	ppm ASTM D5185(m) >20	2	4	4
Copper	ppm ASTM D5185(m) >20	3	6	6
Tin	ppm ASTM D5185(m) >10	<1	<1	<1
Antimony	ppm ASTM D5185(m)	0	0	<1
Vanadium	ppm ASTM D5185(m)	0	0	0
Beryllium	ppm ASTM D5185(m)	0	0	0
Cadmium	ppm ASTM D5185(m)	0	0	0






ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m) 130	94	76	75
Barium	ppm ASTM D5185(m) 1.0	0	<1	<1
Molybdenum	ppm ASTM D5185(m) 0.0	0	<1	0
Manganese	ppm ASTM D5185(m)	0	0	<1
Magnesium	ppm ASTM D5185(m) 1.0	2	2	<1
Calcium	ppm ASTM D5185(m) 20	75	63	60
Phosphorus	ppm ASTM D5185(m) 280	237	289	277
Zinc	ppm ASTM D5185(m) 10	38	115	92
Sulfur	ppm ASTM D5185(m) 440	775	851	806
Lithium	ppm ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >15	2	4	7
Sodium	ppm ASTM D5185(m)	<1	2	2
Potassium	ppm ASTM D5185(m) >20	<1	1	1

OIL ANALYSIS REPORT




FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	718	1406	61792	29634
Particles >6µm	ASTM D7647	>1300	207	374	3897	767
Particles >14µm	ASTM D7647	>160	18	6	16	2
Particles >21µm	ASTM D7647	>40	4	0		
Particles >38µm	ASTM D7647	>10	1	0		
Particles >71µm	ASTM D7647	>3	1	0		
Oil Cleanliness	ISO 4406 (c)	>19/17/14	17/15/11	18/16/12	23/22/19	

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.16	0.92	0.83	0.82

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	VLITE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	LIGHT
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG	.5%
Free Water	scalar	Visual*		NEG	NEG	5%

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	34.26	25.3	23.1	23.4
Visc @ 100°C	cSt	ASTM D7279(m)	7.7	5.3	4.9	5
Viscosity Index (VI)	Scale	ASTM D2270*	210	148	140	145

SAMPLE IMAGES



Color

Bottom



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0078235
Lab Number : **02605556**
Unique Number : 5698641
Test Package : MAR 2 (Additional Tests: KV100, PQ, TAN Man, VI)
Received : 28 Dec 2023
Diagnosed : 02 Jan 2024
Diagnostician : Kevin Marson

Suncor - Terra Nova Projects
 Scotia Centre, 235 Water Street
 St. John's, NL
 CA A1C 1B6
 Contact: Josh Hynes
 joshynes@suncor.com
 T: (709)778-3575
 F: (709)724-2835

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.