

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

[450231373] MA-04003 FWD CRANE Component

Unknown Component NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. Please provide more complete information on your next sample.

Wear

Component wear rates appear to be normal (unconfirmed).

Contamination

There is no indication of any contamination in the component(unconfirmed).

Fluid Condition

The AN level is acceptable for this fluid. The condition of the sample is suitable for further service.

			Jun2021	Dec2023		
SAMPLE INFORM	ΙΑΤΙΟΝ	method	limit/base	current	history1	history2
Sample Number		Client Info		PC0078228	PC0030447	
Sample Date		Client Info		27 Dec 2023	02 Jun 2021	
Vachine Age	hrs	Client Info		0	02 3011 2021	
Oil Age	hrs	Client Info		0	0	
Oil Changed	1113	Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
CONTAMINATI	ON	method	limit/base	current	history1	history2
Water		WC Method		NEG	NEG	
WEAR METALS	S	method	limit/base	current	history1	history2
PQ		ASTM D8184*		0	0	
ron	ppm	ASTM D5185(m)		23	2	
Chromium	ppm	ASTM D5185(m)		0	0	
Nickel	ppm	ASTM D5185(m)		<1	<1	
Titanium	ppm	ASTM D5185(m)		0	0	
Silver	ppm	ASTM D5185(m)		1	<1	
Aluminum	ppm	ASTM D5185(m)		- <1	<1	
_ead	ppm	ASTM D5185(m)		<1	5	
Copper	ppm	ASTM D5185(m)		2	5	
Fin	ppm	ASTM D5185(m)		0	<1	
Antimony	ppm	ASTM D5185(m)		0	0	
Vanadium	ppm	ASTM D5185(m)		0	0	
Beryllium	ppm	ASTM D5185(m)		0	0	
Cadmium	ppm	ASTM D5185(m)		0	0	
ADDITIVES	ppm	method	limit/base	current	history1	history2
			iiiiii/base			
Boron	ppm	ASTM D5185(m)		179	88	
Barium	ppm	ASTM D5185(m)		0	<1	
Molybdenum	ppm	ASTM D5185(m)		0	<1	
Manganese	ppm	ASTM D5185(m)		<1	<1	
Magnesium	ppm	ASTM D5185(m)		2	<1	
Calcium	ppm	ASTM D5185(m)		30	51	
Phosphorus	ppm	ASTM D5185(m)		805	263	
Zinc	ppm	ASTM D5185(m)		54	90	
Sulfur	ppm	ASTM D5185(m)		13691	832	
Lithium	ppm	ASTM D5185(m)		5	<1	
CONTAMINAN [®]	TS	method	limit/base	current	history1	history2
	ppm	ASTM D5185(m)		4	3	
	ppm			-	0	
Silicon	ppm	ASTM D5185(m)		2	2	
Silicon Sodium Potassium		ASTM D5185(m) ASTM D5185(m)	>20	2 <1	2	
Silicon Sodium	ppm ppm		>20 limit/base			



OIL ANALYSIS REPORT


cSt (40°C)


Laboratory


Sample No.

Lab Number

Unique Number Test Package







	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	Visual*	NONE	NONE	NONE	
	Yellow Metal	scalar	Visual*	NONE	NONE	NONE	
	Precipitate	scalar	Visual*	NONE	NONE	NONE	
	Silt	scalar	Visual*	NONE	NONE	NONE	
	Debris	scalar	Visual*	NONE	NONE	NONE	
	Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	
	Appearance	scalar	Visual*	NORML	NORML	NORML	
	Odor	scalar	Visual*	NORML	NORML	NORML	
	Emulsified Water	scalar	Visual*		NEG	NEG	
	Free Water	scalar	Visual*		NEG	NEG	
	FLUID PROPE	RTIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D7279(m)		101	23.4	
	Visc @ 100°C	cSt	ASTM D7279(m)		12.1	4.9	
	Viscosity Index (VI)	Scale	ASTM D2270*		110	137	
	SAMPLE IMAG		method	limit/base	current		history?
	SAIVIFLE IIVIAG	ES	methoa	IIIIII/Dase	current	history1	history2
	Color						no image
	Bottom						no image
	GRAPHS						
	Ferrous Alloys				PQ		
	iron			22			
	second chromium			20	Severe		-
bpm	IO-			180	^D		
	5			160) -		
				E 14	₽╉┤		
	Jun2/21			120 Dec27/23	1		
	Non-ferrous Metals	5		10	Abnormal		
	¹⁰ T			80	•		
	8 - copper			60	•		
ppm	6 and a substantial and a substantial subs			4	D		
	2 -	ALALASIA STRUCTURE OF THE OWNER OWN	States of the local division in the local di	2	D		
	Jun2/2			Dec27/22	Jun2/21		Dec27/23
	Viscosity @ 40°C				Acid Numbe	r	
12	Abnormal			(B/HC			
	Abnormal			¥1.0 Ēn			
nor lan	50			² e 0.1	,		
4	10-			Acid Number (mg KOH/g) 1: 1: 1: 1: 1: 1: 1: 1: 1: 1: 1: 1: 1: 1	2		
1	20			1.0 YC			
	Jun2/2			Dec27/23	Jun2/2		Dec27/23
	: 02605590	Recieved Diagnos Diagnost Tests: KV	d : 28 l ed : 02 d ician : Kew /100, VI)	Dec 2023 Jan 2024 rin Marson	.7L 5H9	Contac	
_	$f_{\text{accorditation}}(m) m$				nallah		700)778 2575

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

CALA

ISO 17025:2017 Accredited Laboratory

b

. T: (709)778-3575

F: (709)724-2835