

PROBLEM SUMMARY


Aft Machinery Space


Thruster Aft Starboard - Seal Oil System (S/N Sample Tag CL-06003-S3)


Component Sealing System

PETRO CANADA ENERGOL GR-XP ISO 150 (65 LTR)

COMPONENT CONDITION SUMMARY








Vater

Scale

ASTM D2270'

Sample Rating Trend



WEAR

RECOMMENDATION

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you drain the fluid from the component if this has not already been done. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS Sample Status SEVERE ABNORMAL ABNORMAL Chromium ASTM D5185(m) >3 17 0 0 ppm Water % ASTM D6304* 0.378 ppm Water ppm ASTM D6304* 3783 Particles >4µm ASTM D7647 >5000 148164 21592 28148 ASTM D7647 >1300 3089 Particles >6µm 38031 6179 Particles >14µm ASTM D7647 >160 1586 83 ▲ 184 ASTM D7647 20 28 Particles >21µm >40 261 **Oil Cleanliness** ISO 4406 (c) >19/17/14 24/22/18 22/19/14 22/20/15 NORML Appearance scalar Visual* WGOIL NORML NORML Emulsified Water scalar Visual* **1%** NEG NEG Free Water scalar Visual* 1% NEG NEG

6 🔺

94

Viscosity Index (VI)

Customer Id: TERHAM Sample No.: PC Lab Number: 02611113 Test Package: MAR 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 <u>gloria.gonzalez@wearcheck.com</u>



Page 1 of 4

95

RECOMMENDED ACTIONS								
Action	Status	Date	Done By	Description				
Change Fluid	MISSED	Jan 26 2024	?	We recommend that you drain the fluid from the component if this has not already been done.				
Resample	MISSED	Jan 26 2024	?	Resample in 30-45 days to monitor this situation.				
Check Breathers	MISSED	Jan 26 2024	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.				
Check Dirt Access	MISSED	Jan 26 2024	?	We advise that you check all areas where contaminants can enter the system.				
Check Seals	MISSED	Jan 26 2024	?	Check seals and/or filters for points of contaminant entry.				

HISTORICAL DIAGNOSIS



ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the fluid. The AN level is acceptable for this fluid. The fluid is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



view report

14 Aug 2023 Diag: Kevin Marson

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the fluid. The AN level is acceptable for this fluid. The fluid is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

19 Jul 2023 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor.All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.





OIL ANALYSIS REPORT

Aft Machinery Space Thruster Aft Starboard - Seal Oil System (S/N Sample Tag CL-06003-S3) Component Sealing System

Fluid PETRO CANADA ENERGOL GR-XP ISO 150 (65 LTR)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you drain the fluid from the component if this has not already been done. Resample in 30-45 days to monitor this situation.

• Wear


Chromium ppm levels are severe.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the fluid. There is a moderate concentration of water present in the fluid. Free water present. Abnormal water content and sodium(Na) level indicate possible sea water contamination.

Fluid Condition

The AN level is acceptable for this fluid. The fluid is no longer serviceable as a result of the abnormal and/or severe wear.



SAMPLE INFOR	RMATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC	PC	PC
Sample Date		Client Info		04 Jan 2024	14 Sep 2023	14 Aug 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	ABNORMAL	ABNORMAL
WEAR META	LS	method	limit/base	current	history1	history2
PQ		ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m)	>100	34	4	9
Chromium	ppm	ASTM D5185(m)	>3	• 7	0	0
Nickel	ppm	ASTM D5185(m)	>8	2	<1	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	<1	0
Aluminum	ppm	ASTM D5185(m)	>3	<1	0	<1
Lead	ppm	ASTM D5185(m)	-	<1	0	0
Copper	ppm	ASTM D5185(m)	>3	1	<1	<1
Tin	ppm	ASTM D5185(m)	-	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
	ppm		line it //s a s a	-		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<1	8	11
Barium	ppm	ASTM D5185(m)		0	<1	0
Molybdenum	ppm	ASTM D5185(m)		0	0	<1
Manganese	ppm	ASTM D5185(m)		0	0	<1
Magnesium	ppm	ASTM D5185(m)		4	2	<1
Calcium	ppm	ASTM D5185(m)		6	8	4
Phosphorus	ppm	ASTM D5185(m)		138	176	268
Zinc	ppm	ASTM D5185(m)		10	8	8
Sulfur	ppm	ASTM D5185(m)		8796	14368	13115
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINA	NTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	9	8	1
Sodium	ppm	ASTM D5185(m)		A 20	2	<1
Potassium	ppm	ASTM D5185(m)	>20	2	0	<1
Water	%	ASTM D6304*		A 0.378		
opm Water	ppm	ASTM D6304*		A 3783		
FLUID CLEAN	ILINESS	method	limit/base	current	history1	history2
TEORD GEE/			5000	4 404 C 4	A 21592	<u> </u>
		ASTM D7647	>5000	🛑 148164	<u> </u>	20140
Particles >4µm		ASTM D7647 ASTM D7647		148164 38031	▲ 3089	▲ 6179
Particles >4µm Particles >6µm						
Particles >4μm Particles >6μm Particles >14μm		ASTM D7647	>1300 >160	38031	▲ 3089	6 179
Particles >4µm Particles >6µm Particles >14µm Particles >21µm		ASTM D7647 ASTM D7647	>1300 >160	380311586	▲ 3089 83	▲ 6179▲ 184
Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm Particles >71µm		ASTM D7647 ASTM D7647 ASTM D7647	>1300 >160 >40 >10	 38031 1586 261 	▲ 30898320	 ▲ 6179 ▲ 184 28





Jul18/18


eh20/1

OIL ANALYSIS REPORT

FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
Acid Number (AN)		ASTM D974*	0.9	0.27	0.48	0.53
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	WGOIL	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*		1%	NEG	NEG
Free Water	scalar	Visual*		1%	NEG	NEG
FLUID PROPER	RTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	149	143	146	145
Visc @ 100°C	cSt	ASTM D7279(m)	14.5	11.6	14.2	14.3
Viscosity Index (VI)	Scale	ASTM D2270*		54	94	95
SAMPLE IMAG	ES	method	limit/base	current	history1	history2
Color						
Bottom						







: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Laboratory CALA Sample No. : PC Recieved : 25 Jan 2024 Lab Number : 02611113 Diagnosed : 26 Jan 2024 ISO 17025:2017 Accredited Laboratory Unique Number : 5720208 Diagnostician : Kevin Marson Test Package : MAR 2 (Additional Tests: KF, KV100, PQ, PrtCount, VI) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Suncor - Terra Nova Projects Scotia Centre, 235 Water Strret St. John`s, NL CA A1C 1B6 Contact: Josh Hynes joshynes@suncor.com T: (709)778-3575 F: (709)724-2835

Page 4 of 4