



# OIL ANALYSIS REPORT

Sample Rating Trend

**OFF SPEC**



Machine Id  
**K604**  
Component  
**Natural Gas Engine - Hydraulic Actuator**  
Fluid  
**PETRO CANADA PRODURO TO-4+ XL SYN BLEND LOTEMP (--- LTR)**



## DIAGNOSIS

### Recommendation

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. The fluid was specified as PETRO CANADA PRODURO TO-4+ XL SYN BLEND LOTEMP, however, a fluid match indicates that this fluid is Petro-Canada Sentron LD 3000. Please confirm the oil type and grade on your next sample. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal.

### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

### Fluid Condition

Viscosity of sample indicates oil is within SAE 40 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PC0085492</b>	---	---
Sample Date	Client Info		<b>17 Jan 2024</b>	---	---
Machine Age	hrs	Client Info	<b>6606</b>	---	---
Oil Age	hrs	Client Info	<b>0</b>	---	---
Oil Changed	Client Info		<b>Not Chngd</b>	---	---
Sample Status			<b>ABNORMAL</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		<b>0</b>	---	---
Iron	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	---	---
Chromium	ppm	ASTM D5185(m) >20	<b>0</b>	---	---
Nickel	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	---	---
Titanium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Silver	ppm	ASTM D5185(m)	<b>0</b>	---	---
Aluminum	ppm	ASTM D5185(m) >20	<b>1</b>	---	---
Lead	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	---	---
Copper	ppm	ASTM D5185(m) >20	<b>6</b>	---	---
Tin	ppm	ASTM D5185(m) >20	<b>0</b>	---	---
Antimony	ppm	ASTM D5185(m)	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	---	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	<b>2</b>	---	---
Barium	ppm	ASTM D5185(m) 0	<b>0</b>	---	---
Molybdenum	ppm	ASTM D5185(m) 1	<b>0</b>	---	---
Manganese	ppm	ASTM D5185(m) 1	<b>0</b>	---	---
Magnesium	ppm	ASTM D5185(m) 9	<b>7</b>	---	---
Calcium	ppm	ASTM D5185(m) 3080	<b>▲ 1225</b>	---	---
Phosphorus	ppm	ASTM D5185(m) 1136	<b>▲ 264</b>	---	---
Zinc	ppm	ASTM D5185(m) 1269	<b>▲ 298</b>	---	---
Sulfur	ppm	ASTM D5185(m) 3614	<b>▲ 2102</b>	---	---
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---

## CONTAMINANTS


	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	<b>2</b>	---	---
Sodium	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Potassium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	---	---
Water	%	ASTM D6304* >0.05	<b>0.003</b>	---	---
ppm Water	ppm	ASTM D6304* >500	<b>27</b>	---	---

## FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>129</b>	---	---
Particles >6µm	ASTM D7647	>1300	<b>46</b>	---	---
Particles >14µm	ASTM D7647	>160	<b>6</b>	---	---
Particles >21µm	ASTM D7647	>40	<b>3</b>	---	---
Particles >38µm	ASTM D7647	>10	<b>1</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>1</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>14/13/10</b>	---	---

# OIL ANALYSIS REPORT


▲ Viscosity @ 100°C




▲ Additives




Water (KF)



PQ



Particle Trend



**FLUID DEGRADATION** method limit/base current history1 history2

Acid Number (AN)	mg KOH/g	ASTM D974*	3.95	<b>0.25</b>	---	---
------------------	----------	------------	------	-------------	-----	-----

**VISUAL** method limit/base current history1 history2

White Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	---	---
Silt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Debris	scalar	Visual*	NONE	<b>NONE</b>	---	---
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Appearance	scalar	Visual*	NORML	<b>NORML</b>	---	---
Odor	scalar	Visual*	NORML	<b>NORML</b>	---	---
Emulsified Water	scalar	Visual*	>0.05	<b>NEG</b>	---	---
Free Water	scalar	Visual*		<b>NEG</b>	---	---

**FLUID PROPERTIES** method limit/base current history1 history2

Visc @ 40°C	cSt	ASTM D7279(m)	35.1	▲ <b>119</b>	---	---
Visc @ 100°C	cSt	ASTM D7279(m)	7.4	▲ <b>13.2</b>	---	---
Viscosity Index (VI)	Scale	ASTM D2270*	184	▲ <b>105</b>	---	---

**SAMPLE IMAGES** method limit/base current history1 history2


Color		no image	no image
Bottom		no image	no image

**GRAPHS**


Ferrous Alloys




Non-ferrous Metals




Particle Count



▲ Viscosity @ 40°C



Acid Number



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0085492 **Received** : 02 Feb 2024  
**Lab Number** : **02613129** **Diagnosed** : 05 Feb 2024  
**Unique Number** : 5722224 **Diagnostician** : Bill Quesnel  
**Test Package** : PLANT ( Additional Tests: FT-IR(Diff), KV100, VI )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**NuVista Energy**  
 10508 67 Ave, #201  
 Grande Prairie, AB  
 CA T8W 0K8  
 Contact: Eldon Weaver  
 eweaver@nvaenergy.com

T:  
F: