

# **OIL ANALYSIS REPORT**

Sample Rating Trend


## NORMAL



Component

Reciprocating Compressor

PETRO CANADA SENTRON LD 3000 (--- LTR)





#### SAMPLE INFORMATION method PC0085491 PC90000904 Client Info PC90000913 Sample Number Client Info 17 Jan 2024 25 Oct 2023 02 Aug 2023 Sample Date 30149 Machine Age hrs **Client Info** 28203 26357 Oil Age hrs Client Info 0 1846 2876 Oil Changed **Client Info** N/A Not Changd Changed NORMAL Sample Status NORMAL NORMAL WEAR METALS 0 Iron ASTM D5185(m) >50 1 ppm <1 0 Chromium ppm ASTM D5185(m) >10 0 0 0 0 Nickel ppm ASTM D5185(m) 0 ASTM D5185(m) Titanium 0 0 0 ppm 0 0 Silver ppm ASTM D5185(m) 0 Aluminum ppm ASTM D5185(m) >25 1 1 1 >25 Lead ASTM D5185(m) <1 0 0 ppm 3 5 9 Copper ASTM D5185(m) >50 ppm Tin ppm ASTM D5185(m) >15 <1 0 0 Antimony ppm ASTM D5185(m) 0 0 0 Vanadium ppm ASTM D5185(m) 0 0 0 Beryllium ASTM D5185(m) 0 0 0 ppm Cadmium ASTM D5185(m) 0 0 0 ppm **ADDITIVES** 5 <1 1 2 Boron ppm ASTM D5185(m) 0 0 0 Barium ppm ASTM D5185(m) 1 2 0 0 0 Molybdenum ASTM D5185(m) ppm 0 0 0 Manganese ppm ASTM D5185(m) 1 6 6 Magnesium ppm ASTM D5185(m) 5 7 Calcium ppm ASTM D5185(m) 1220 1222 1148 1526 269 398 Phosphorus ASTM D5185(m) 298 260 ppm Zinc ppm ASTM D5185(m) 350 298 305 433 Sulfur 1995 2132 ppm ASTM D5185(m) 0 Lithium ppm ASTM D5185(m) <1 0

CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	1	2	3
Sodium	ppm	ASTM D5185(m)		<1	0	0
Potassium	ppm	ASTM D5185(m)	>20	<1	0	0
Water	%	ASTM D6304*	>0.1	0.002		
ppm Water	ppm	ASTM D6304*	>1000	23		

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		0		
Nitration	Abs/cm	ASTM D7624*		2.4		
Nitration(Diff)	Abs/cm	ASTM E2412*		0.4		
Sulfation	Abs/.1mm	ASTM D7415*		13.6		
Sulfation(Diff)	Abs/cm	ASTM E2412*		0.2		

DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

#### Contamination


The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.


#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




# **OIL ANALYSIS REPORT**









FLUID CLEANL	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>1300	145		
Particles >6µm		ASTM D7647	>640	54		
Particles >14µm		ASTM D7647	>160	6		
Particles >21µm		ASTM D7647	>40	2		
Particles >38µm		ASTM D7647	>10	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>17/16/14	14/13/10		
FLUID DEGRAD	)ATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*		6.6		
Oxidation(Diff)	Abs/cm	ASTM E2412*		0.8		
Acid Number (AN)	mg KOH/g	ASTM D974*	0.86	0.24		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		
Emulsified Water	scalar	Visual*	>0.1	NEG		
Free Water	scalar	Visual*		NEG		
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	124.3	118	120	119
Visc @ 100°C	cSt	ASTM D7279(m)	13.7	13.2	13.05	12.93
Viscosity Index (VI)	Scale	ASTM D2270*	106	106	102	101
SAMPLE IMAG	ES	method	limit/base	current	history1	history2

Color		no image	no image	
- Bottom		no image	no image	

	ISO 17025:2017 Accredited Laboratory	Laboratory Sample No. Lab Number Unique Number Test Package	: PC0085491 : <mark>02613133</mark> : 5722228	8-1175 Appleby Line, Burlington, ON L7L 5H9 <b>Recieved</b> : 02 Feb 2024 <b>Diagnosed</b> : 05 Feb 2024 <b>Diagnostician</b> : Bill Quesnel onal Tests: FT-IR, FT-IR(DIFF), KF, KV100, VI	)
	Test denoted	s sample report, c (*) outside scope	contact Customer S of accreditation, (m	Service at 1-800-268-2131. n) method modified, (e) tested at external lab. the sample and information as supplied.	,

#### NuVista Energy 10508 67 Ave, #201 Grande Prairie, AB CA T8W 0K8 Contact: Eldon Weaver eweaver@nvaenergy.com T: F:

Report Id: NUVGRA [WCAMIS] 02613133 (Generated: 02/05/2024 15:55:19) Rev: 3

Submitted By: Kris Dickmann Page 2 of 2