

OIL ANALYSIS REPORT

Sample Rating Trend





Component **Reciprocating Compressor**

PETRO CANADA SENTRON LD 3000 (--- LTR)

DIAGNOSIS	SAMPLE INFOR		method	limit/base	current	history1	history2
A Recommendation	Sample Number		Client Info		PC0085485	PC90000452	PC90000422
We recommend you service the filters on this	Sample Date		Client Info		17 Jan 2024	30 Oct 2023	11 Sep 2023
component. We recommend an early resample to	Machine Age	hrs	Client Info		19000	18685	18055
monitor this condition.	Oil Age	hrs	Client Info		0	2084	1454
Wear	Oil Changed		Client Info		Not Changd	Changed	Not Changd
All component wear rates are normal.	Sample Status				ABNORMAL	NORMAL	NORMAL
Contamination		S	method	limit/base		history1	history2
There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water	Iron	ppm	ASTM D5185(m)	>50	2	3	3
content is negligible.	Chromium	ppm	ASTM D5185(m)		0	0	0
Fluid Condition	Nickel	ppm	ASTM D5185(m)		<1	0	0
The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.	Titanium	ppm	ASTM D5185(m)		0	0	0
	Silver	ppm	ASTM D5185(m)		0	0	0
	Aluminum	ppm	ASTM D5185(m)	>25	1	2	1
	Lead	ppm	ASTM D5185(m)		1	0	1
	Copper	ppm	ASTM D5185(m)		17	23	21
	Tin	ppm	ASTM D5185(m)		<1	1	0
	Antimony	ppm	ASTM D5185(m)		0	0	0
	Vanadium	ppm	ASTM D5185(m)		0	0	0
	Beryllium	ppm	ASTM D5185(m)		0	0	0
	Cadmium	ppm	ASTM D5185(m)		0	0	0
	ADDITIVES		method	limit/base	current	history1	history2
	Boron	ppm	ASTM D5185(m)	5	1	1	1
	Barium	ppm	ASTM D5185(m)		0	0	0
	Molybdenum	ppm	ASTM D5185(m)		0	0	0
	Manganese	ppm	ASTM D5185(m)		0	0	0
	Magnesium	ppm	ASTM D5185(m)		6	6	7
	Calcium	ppm	ASTM D5185(m)		1303	1238	1252
	Phosphorus	ppm	ASTM D5185(m)		264	283	267
	Zinc	ppm	ASTM D5185(m)		256	298	303
	Sulfur	ppm	ASTM D5185(m)		2087		
	Lithium	ppm	ASTM D5185(m)		<1	0	0
	CONTAMINA	NTS	method	limit/base	current	history1	history2
	Silicon	ppm	ASTM D5185(m)	>25	4	2	1
	Sodium	ppm	ASTM D5185(m)		<1	0	0
	Potassium	ppm	ASTM D5185(m)	>20	1	0	0
	Water	%	ASTM D6304*		0.001		
	ppm Water	ppm	ASTM D6304*		7		
	INFRA-RED		method	limit/base	current	history1	history2
	Soot %	%	ASTM D7844*		0		
	Nitration	Abs/cm			2.5		0
	Nitration(Diff)	Abs/cm	ASTM D7024 ASTM E2412*		0.8		
	Sulfation	Abs/.1mm	ASTM 22412 ASTM D7415*		13.6		0
	Sulfation(Diff)	Abs/cm			0.2		
	Sullation(DIII)	AUS/CIT	AUTIVI E2412		0.2		





OIL ANALYSIS REPORT


FLUID CLEANLINESS method

Particles >4µm

Particles >6µm







+20 8				2040	207		
20 1406:1999 Cleanliness	Particles >14µm		ASTM D7647	>160	10		
	Particles >21µm		ASTM D7647	>40	3		
	Particles >38µm		ASTM D7647	>10	1		
	Particles >71µm		ASTM D7647	>3	1		
	Oil Cleanliness		ISO 4406 (c)	>17/16/14	 19/15/10		
	FLUID DEGRAD	OATION	method	limit/base	current	history1	history2
Oxid	ation	Abs/.1mm	ASTM D7414*		6.4		0
Oxida	ation(Diff)	Abs/cm	ASTM E2412*		1		
Ac	id Number (AN)	mg KOH/g	ASTM D974*	0.86	0.20		
	VISUAL		method	limit/base	current	history1	history2
W	hite Metal	scalar	Visual*	NONE	NONE		
Ye	ellow Metal	scalar	Visual*	NONE	NONE		
ł	Precipitate	scalar	Visual*	NONE	NONE		
	Silt	scalar	Visual*	NONE	NONE		
[Debris	scalar	Visual*	NONE	NONE		
ç	Sand/Dirt	scalar	Visual*	NONE	NONE		
,	Appearance	scalar	Visual*	NORML	NORML		
	Odor	scalar	Visual*	NORML	NORML		
E	Emulsified Water	scalar	Visual*	>0.1	NEG		
F	Free Water	scalar	Visual*		NEG		
	FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Vis	sc @ 40°C	cSt	ASTM D7279(m)	124.3	128	122	119
1	Visc @ 100°C	cSt	ASTM D7279(m)	13.7	13.8	13.14	13.23
	Viscosity Index (VI)	Scale	ASTM D2270*	106	104	101	105
	SAMPLE IMAG	ES	method	limit/base	current	history1	history2
Color	ſ					no image	no image
Bo	ottom					no image	no image

limit/base

ASTM D7647 >1300

ASTM D7647 >640

current

4837

267

history1

history2

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. : PC0085485 Recieved : 02 Feb 2024 Lab Number : 02613134 Diagnosed : 05 Feb 2024 ISO 17025:2017 Unique Number : 5722229 Accredited Diagnostician : Bill Quesnel Laboratory Test Package : PLANT (Additional Tests: FT-IR, FT-IR(Diff), KF, KV100, VI) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

NuVista Energy 10508 67 Ave, #201

Grande Prairie, AB CA T8W 0K8 Contact: Eldon Weaver eweaver@nvaenergy.com T: F: