


OIL ANALYSIS REPORT

Sample Rating Trend









Machine Id **K601** Component

Natural Gas Compression Engine

PETRO CANADA SENTRON LD 3000 (--- LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

KON LD 3000 (,	n2021 Jun20	021 Nov2021 Mar2022	Aug2022 Nov2022 Apr2023	Aug2023	
SAMPLE INFOR	RMATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC0085493	PC90000788	PC90000773
Sample Date		Client Info		17 Jan 2024	25 Oct 2023	11 Sep 2023
Machine Age	hrs	Client Info		29659	27671	26746
Oil Age	hrs	Client Info		0	4284	3359
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINA	ΓΙΟΝ	method	limit/base	current	history1	history2
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Glycol		WC Method		NEG	NEG	NEG
WEAR METAI	LS	method	limit/base	current	history1	history2
PQ		ASTM D8184*	>20	0		
ron	ppm	ASTM D5185(m)	>14	<1	3	3
Chromium	ppm	ASTM D5185(m)	>3	0	0	0
Nickel	ppm	ASTM D5185(m)	>5	<1	0	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)	>5	0	0	0
Aluminum	ppm	ASTM D5185(m)	>5	1	1	2
Lead	ppm	ASTM D5185(m)	>8	0	1	1
Copper	ppm	ASTM D5185(m)	>5	<1	0	0
Tin	ppm	ASTM D5185(m)	>3	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	5	<1	1	1
Barium	ppm	ASTM D5185(m)	1	0	0	0
Molybdenum	ppm	ASTM D5185(m)	2	0	1	1
Manganese	ppm	ASTM D5185(m)	1	0	0	0
Magnesium	ppm	ASTM D5185(m)	5	7	7	10
Calcium	ppm	ASTM D5185(m)	1220	1231	1465	1737
Phosphorus	ppm	ASTM D5185(m)	298	257	325	351
Zinc	ppm	ASTM D5185(m)	350	303	384	442
Sulfur	ppm	ASTM D5185(m)	1995	2068		
Lithium	ppm	ASTM D5185(m)		<1	0	0
CONTAMINA	NTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>180	1	2	2
Sodium	ppm	ASTM D5185(m)	>20	<1	1	1
Potassium	ppm	ASTM D5185(m)	>20	<1	0	0
Water	%	ASTM D6304*	>0.1	0.005		
ppm Water	ppm	ASTM D6304*	>1000	60		
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		0		
Nitration	Abs/cm	ASTM D7624*	>15	3.3	6	5.9
Sulfation	Abs/.1mm	ASTM D7415*	>25	14.8	21.1	20.2



OIL ANALYSIS REPORT





ISO 17025:2017 Accredited

Laboratory

Sample No. Lab Number **Unique Number**

: 02613138

: PC0085493

: 5722233

Recieved : 02 Feb 2024 Diagnosed : 05 Feb 2024

Diagnostician : Bill Quesnel

Test Package : PLANT (Additional Tests: FT-IR, FT-IR(Diff), KV100, TAN Man, VI)

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

10508 67 Ave, #201 Grande Prairie, AB CA T8W 0K8

Contact: Eldon Weaver eweaver@nvaenergy.com

T: F: