

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Component

Reciprocating Compressor

PETRO CANADA SENTRON LD 3000 (--- LTR)

Water

nom Water

%

nnm

ASTM D6304*

ASTM D6304*

>0.1

>1000





SAMPLE INFORMATION method PC0085484 PC90000456 Client Info PC90000473 Sample Number Client Info 17 Jan 2024 31 Oct 2023 Sample Date 11 Sep 2023 18212 Machine Age hrs **Client Info** 16657 16219 Oil Age hrs Client Info 3000 2236 1798 Oil Changed **Client Info** Changed Not Changd Changed NORMAL NORMAL Sample Status NORMAL WEAR METALS 2 ASTM D5185(m) >50 1 Iron ppm <1 0 Chromium ppm ASTM D5185(m) >10 0 0 Nickel ppm ASTM D5185(m) <1 0 0 Titanium ASTM D5185(m) 0 0 0 ppm 0 0 Silver ppm ASTM D5185(m) <1 Aluminum ASTM D5185(m) >25 1 2 1 ppm >25 Lead ASTM D5185(m) <1 0 0 ppm 10 Copper ASTM D5185(m) >50 15 14 ppm 0 Tin ppm ASTM D5185(m) >15 <1 0 Antimony ASTM D5185(m) 0 0 0 ppm Vanadium ppm ASTM D5185(m) 0 0 0 Beryllium ASTM D5185(m) 0 0 0 ppm Cadmium ASTM D5185(m) 0 0 0 ppm **ADDITIVES** 5 1 1 1 Boron ppm ASTM D5185(m) 0 0 Barium ppm ASTM D5185(m) 1 0 2 0 0 Molybdenum ASTM D5185(m) ppm <1 0 0 0 Manganese ppm ASTM D5185(m) 1 Magnesium ppm ASTM D5185(m) 5 7 7 7 ACTM D5185(m) 1220 Coloium 1000 1000 105

Calcium	ppm	ASTM D5185(m)	1220	1220	1293	1254
Phosphorus	ppm	ASTM D5185(m)	298	261	295	269
Zinc	ppm	ASTM D5185(m)	350	295	335	323
Sulfur	ppm	ASTM D5185(m)	1995	2108		
Lithium	ppm	ASTM D5185(m)		<1	0	0
CONTAMINAN	ITS	method	limit/base	current	history1	history2
CONTAMINAN Silicon	ITS ppm	method ASTM D5185(m)		current	history1 2	history2 1
				current 1 <1	,	history2 1 0

	ppin		21000	51		
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		0		
Nitration	Abs/cm	ASTM D7624*		2.4		
Nitration(Diff)	Abs/cm	ASTM E2412*		0.4		
Sulfation	Abs/.1mm	ASTM D7415*		13.7		
Sulfation(Diff)	Abs/cm	ASTM E2412*		0.7		

0.003

31

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination


The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.


Fluid Condition


The condition of the oil is acceptable for the time in service.




OIL ANALYSIS REPORT









FLUID CLEANL	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>1300	211		
Particles >6µm		ASTM D7647	>640	56		
Particles >14µm		ASTM D7647	>160	5		
Particles >21µm		ASTM D7647	>40	2		
Particles >38µm		ASTM D7647	>10	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>17/16/14	15/13/10		
FLUID DEGRAD)ATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*		7.0		
Oxidation(Diff)	Abs/cm	ASTM E2412*		1.3		
Acid Number (AN)	mg KOH/g	ASTM D974*	0.86	0.17		
VISUAL		method	limit/base	current	history1	history2
	scalar	method Visual*	limit/base	current	history1	history2
	scalar scalar				history1 	history2
White Metal		Visual*	NONE	NONE		
White Metal Yellow Metal	scalar	Visual* Visual*	NONE NONE	NONE NONE		
White Metal Yellow Metal Precipitate	scalar scalar	Visual* Visual* Visual*	NONE NONE NONE	NONE NONE NONE		
White Metal Yellow Metal Precipitate Silt	scalar scalar scalar	Visual* Visual* Visual* Visual*	NONE NONE NONE NONE	NONE NONE NONE NONE		
White Metal Yellow Metal Precipitate Silt Debris	scalar scalar scalar scalar	Visual* Visual* Visual* Visual* Visual*	NONE NONE NONE NONE	NONE NONE NONE NONE NONE		
White Metal Yellow Metal Precipitate Silt Debris Sand/Dirt	scalar scalar scalar scalar scalar	Visual* Visual* Visual* Visual* Visual* Visual*	NONE NONE NONE NONE NONE	NONE NONE NONE NONE NONE	 	
White Metal Yellow Metal Precipitate Silt Debris Sand/Dirt Appearance	scalar scalar scalar scalar scalar scalar	Visual* Visual* Visual* Visual* Visual* Visual* Visual*	NONE NONE NONE NONE NONE NORE	NONE NONE NONE NONE NONE NONE NORML	 	
White Metal Yellow Metal Precipitate Silt Debris Sand/Dirt Appearance Odor	scalar scalar scalar scalar scalar scalar scalar	Visual* Visual* Visual* Visual* Visual* Visual* Visual* Visual*	NONE NONE NONE NONE NONE NORML NORML	NONE NONE NONE NONE NONE NORML NORML		

I LOID I HOI L						
Visc @ 40°C	cSt	ASTM D7279(m)	124.3	118	118	118
Visc @ 100°C	cSt	ASTM D7279(m)	13.7	13.1	13.1	13.23
Viscosity Index (VI)	Scale	ASTM D2270*	106	105	105	107

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Sample No. : PC0085484 Recieved : 02 Feb 2024 Lab Number : 02613140 Diagnosed : 05 Feb 2024 ISO 17025:2017 Accredited Laboratory Unique Number : 5722235 Diagnostician : Bill Quesnel Test Package : PLANT (Additional Tests: FT-IR, FT-IR(DIFF), KF, KV100, VI) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

NuVista Energy 10508 67 Ave, #201 Grande Prairie, AB CA T8W 0K8 Contact: Eldon Weaver eweaver@nvaenergy.com T: F:

DESCRIPTION I est denoted (*) outside scope of accreditation, (m) method modified, (e) tested at externa Validity of results and interpretation are based on the sample and information as supplied.