


Area
Gas Compression
Machine Id
Compressor (HP2) - Lubrication System (S/N Sample Tag XX-23004-S1)
Component
Lube System
Fluid
PETRO CANADA TURBOFLO XL32 (10350 LTR)



DIAGNOSIS

Recommendation
We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MAR 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

Wear
Component wear rates appear to be normal (unconfirmed).

Contamination
There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition
The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | | PC | PC0076384 | PC |
| Sample Date | Client Info | | | 08 Feb 2024 | 05 Jan 2024 | 02 Mar 2022 |
| Machine Age | hrs | Client Info | | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | | 0 | 0 | 0 |
| Oil Changed | Client Info | | | N/A | N/A | N/A |
| Sample Status | | | | ABNORMAL | SEVERE | SEVERE |

| CONTAMINATION | | method | limit/base | current | history1 | history2 |
|---------------|-----------|--------|------------|------------|----------|----------|
| Water | WC Method | | >0.05 | NEG | NEG | NEG |






| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|---------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185(m) | >20 | 0 | <1 | 0 |
| Chromium | ppm | ASTM D5185(m) | >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) | >10 | 0 | <1 | <1 |
| Titanium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185(m) | >10 | <1 | <1 | 0 |
| Lead | ppm | ASTM D5185(m) | >20 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185(m) | >20 | <1 | 0 | <1 |
| Tin | ppm | ASTM D5185(m) | >10 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Beryllium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |

| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|---------------|------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185(m) | 0 | 0 | 0 | <1 |
| Barium | ppm | ASTM D5185(m) | 0 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185(m) | 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185(m) | 0 | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185(m) | 0 | <1 | 0 | 0 |
| Calcium | ppm | ASTM D5185(m) | 0 | 8 | <1 | <1 |
| Phosphorus | ppm | ASTM D5185(m) | 5 | 3 | 2 | 98 |
| Zinc | ppm | ASTM D5185(m) | 0 | 2 | <1 | <1 |
| Sulfur | ppm | ASTM D5185(m) | 750 | 692 | 674 | 187 |
| Lithium | ppm | ASTM D5185(m) | | <1 | <1 | <1 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|---------------|------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185(m) | >15 | 0 | 4 | 1 |
| Sodium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Potassium | ppm | ASTM D5185(m) | >20 | <1 | <1 | <1 |

| FLUID CLEANLINESS | | method | limit/base | current | history1 | history2 |
|-------------------|--|--------------|------------|-------------------|------------|------------|
| Particles >4µm | | ASTM D7647 | | 3526 | 94384 | 8386 |
| Particles >6µm | | ASTM D7647 | >320 | ▲ 1147 | ● 19560 | ● 2623 |
| Particles >14µm | | ASTM D7647 | >40 | ▲ 103 | ● 612 | ● 389 |
| Particles >21µm | | ASTM D7647 | >10 | ▲ 24 | ● 108 | ● 108 |
| Particles >38µm | | ASTM D7647 | >3 | 3 | 5 | ▲ 8 |
| Particles >71µm | | ASTM D7647 | >3 | 1 | 1 | 0 |
| Oil Cleanliness | | ISO 4406 (c) | >--/15/12 | ▲ 19/17/14 | ● 24/21/16 | ● 20/19/16 |

OIL ANALYSIS REPORT



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC
Lab Number : 02615032
Unique Number : 5724127
Test Package : MAR 2 (Additional Tests: KV100, TAN Man, VI)
Received : 12 Feb 2024
Tested : 13 Feb 2024
Diagnosed : 13 Feb 2024 - Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Suncor - Terra Nova Projects
 Scotia Centre, 235 Water Strret
 St. John's, NL
 CA A1C 1B6
 Contact: Josh Hynes
 joshynes@suncor.com
 T: (709)778-3575
 F: (709)724-2835

| FLUID DEGRADATION | | | | | | |
|-------------------|----------|------------|---------|--------------|----------|-------|
| | method | limit/base | current | history1 | history2 | |
| Acid Number (AN) | mg KOH/g | ASTM D974* | 0.04 | 0.04 | 0.06 | 0.06 |
| VISUAL | | | | | | |
| | method | limit/base | current | history1 | history2 | |
| White Metal | scalar | Visual* | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar | Visual* | NONE | NONE | NONE | NONE |
| Precipitate | scalar | Visual* | NONE | NONE | NONE | NONE |
| Silt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Debris | scalar | Visual* | NONE | NONE | NONE | VLITE |
| Sand/Dirt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Appearance | scalar | Visual* | NORML | NORML | NORML | NORML |
| Odor | scalar | Visual* | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | Visual* | >0.05 | NEG | .2% | ▲.2% |
| Free Water | scalar | Visual* | | NEG | NEG | ◆1% |

| FLUID PROPERTIES | | | | | | |
|----------------------|--------|---------------|---------|-------------|----------|------|
| | method | limit/base | current | history1 | history2 | |
| Visc @ 40°C | cSt | ASTM D7279(m) | 33.86 | 33.8 | 33.9 | 33.7 |
| Visc @ 100°C | cSt | ASTM D7279(m) | 5.60 | 5.7 | 5.7 | 5.7 |
| Viscosity Index (VI) | Scale | ASTM D2270* | 101 | 108 | 107 | 108 |

| SAMPLE IMAGES | | | | | | |
|---------------|--------|------------|---------|----------|----------|--|
| | method | limit/base | current | history1 | history2 | |
| Color | | | | | | |
| Bottom | | | | | | |

