


Area
Main Power Generation [450261625]
Machine Id
Generator MPG #1 (Stbd) - Atomizing Air Comp Crank Case (S/N Sample Tag XX-80101-S3)
Component
Air Compressor
Fluid
PETRO CANADA ENDURATEX EP 220 (2 LTR)



DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION method limit/base current history1 history2

Sample Number	Client Info	PC0076416	PC	PP
Sample Date	Client Info	07 Feb 2024	16 Dec 2023	17 Oct 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	NORMAL	NORMAL

WEAR METALS method limit/base current history1 history2

PQ	ASTM D8184*		0	0	0	
Iron	ppm	ASTM D5185(m)	>50	3	2	3
Chromium	ppm	ASTM D5185(m)	>4	0	0	0
Nickel	ppm	ASTM D5185(m)	>4	0	0	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	<1
Aluminum	ppm	ASTM D5185(m)	>10	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>20	0	0	0
Copper	ppm	ASTM D5185(m)	>40	1	1	2
Tin	ppm	ASTM D5185(m)	>5	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES method limit/base current history1 history2

Boron	ppm	ASTM D5185(m)	60	57	60	65
Barium	ppm	ASTM D5185(m)	0	0	0	<1
Molybdenum	ppm	ASTM D5185(m)	0	<1	<1	<1
Manganese	ppm	ASTM D5185(m)	0	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	<1	<1	<1
Calcium	ppm	ASTM D5185(m)	0	2	2	2
Phosphorus	ppm	ASTM D5185(m)	270	299	274	266
Zinc	ppm	ASTM D5185(m)	0	2	2	3
Sulfur	ppm	ASTM D5185(m)	11200	5734	5829	5433
Lithium	ppm	ASTM D5185(m)		<1	<1	<1






CONTAMINANTS method limit/base current history1 history2

Silicon	ppm	ASTM D5185(m)	>25	4	5	4
Sodium	ppm	ASTM D5185(m)		<1	0	0
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	0
Water	%	ASTM D6304*	>0.6	0.005	0.009	0.010
ppm Water	ppm	ASTM D6304*	>6000	52	96	104.0

FLUID CLEANLINESS method limit/base current history1 history2

Particles >4µm	ASTM D7647	>10000	160158	129776	148364
Particles >6µm	ASTM D7647	>2500	52429	45165	68076
Particles >14µm	ASTM D7647	>320	1082	762	2484
Particles >21µm	ASTM D7647	>80	144	80	290
Particles >38µm	ASTM D7647	>20	7	10	14
Particles >71µm	ASTM D7647	>4	1	7	3
Oil Cleanliness	ISO 4406 (c)	>20/18/15	25/23/17	24/23/17	24/23/18

OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.40	0.51	0.21	0.37

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	VLITE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.6	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	220	208	209	209
Visc @ 100°C	cSt	ASTM D7279(m)	19.35	20.1	19.4	---
Viscosity Index (VI)	Scale	ASTM D2270*	99	111	105	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0076416 **Received** : 12 Feb 2024
Lab Number : **02615035** **Tested** : 15 Feb 2024
Unique Number : 5724130 **Diagnosed** : 15 Feb 2024 - Kevin Marson
Test Package : MAR 2 (Additional Tests: KF, KV100, PQ, PrtCount, TAN Man, VI)

Suncor - Terra Nova Projects
 Scotia Centre, 235 Water Strret
 St. John's, NL
 CA A1C 1B6
 Contact: Josh Hynes
 joshynes@suncor.com
 T: (709)778-3575
 F: (709)724-2835

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.