


# PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id  
**K611**  
Component  
**Reciprocating Compressor**  
Fluid  
**PETRO CANADA SENTRON LD 3000 (--- LTR)**

## COMPONENT CONDITION SUMMARY

Particle Trend



## RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	NORMAL
Particles >4µm	ASTM D7647	>1300	30720	4837	---
Particles >6µm	ASTM D7647	>640	3133	267	---
Oil Cleanliness	ISO 4406 (c)	>17/16/14	22/19/12	19/15/10	---

Customer Id: NUVGRA  
Sample No.: PC0085499  
Lab Number: 02617664  
Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

## HISTORICAL DIAGNOSIS

17 Jan 2024 Diag: Bill Quesnel

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



30 Oct 2023 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

view report



11 Sep 2023 Diag: Wes Davis

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

view report





Machine Id  
**K611**  
Component  
**Reciprocating Compressor**  
Fluid  
**PETRO CANADA SENTRON LD 3000 (--- LTR)**



## DIAGNOSIS

### Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PC0085499</b>	PC0085485	PC90000452
Sample Date	Client Info		<b>16 Feb 2024</b>	17 Jan 2024	30 Oct 2023
Machine Age	hrs	Client Info	<b>19159</b>	19000	18685
Oil Age	hrs	Client Info	<b>0</b>	0	2084
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	Changed
Sample Status			<b>SEVERE</b>	ABNORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >50	<b>2</b>	2	3
Chromium	ppm	ASTM D5185(m) >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>&lt;1</b>	0	0
Aluminum	ppm	ASTM D5185(m) >25	<b>1</b>	1	2
Lead	ppm	ASTM D5185(m) >25	<b>&lt;1</b>	1	0
Copper	ppm	ASTM D5185(m) >50	<b>20</b>	17	23
Tin	ppm	ASTM D5185(m) >15	<b>&lt;1</b>	<1	1
Antimony	ppm	ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 5	<b>&lt;1</b>	1	1
Barium	ppm	ASTM D5185(m) 1	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m) 2	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m) 1	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m) 5	<b>7</b>	6	6
Calcium	ppm	ASTM D5185(m) 1220	<b>1383</b>	1303	1238
Phosphorus	ppm	ASTM D5185(m) 298	<b>272</b>	264	283
Zinc	ppm	ASTM D5185(m) 350	<b>239</b>	256	298
Sulfur	ppm	ASTM D5185(m) 1995	<b>2150</b>	2087	---
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	0

## CONTAMINANTS


	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >25	<b>6</b>	4	2
Sodium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	0
Potassium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	1	0
Water	%	ASTM D6304* >0.1	<b>0.003</b>	0.001	---
ppm Water	ppm	ASTM D6304* >1000	<b>36</b>	7	---

## FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>1300	<b>30720</b>	4837	---
Particles >6µm	ASTM D7647	>640	<b>3133</b>	267	---
Particles >14µm	ASTM D7647	>160	<b>40</b>	10	---
Particles >21µm	ASTM D7647	>40	<b>5</b>	3	---
Particles >38µm	ASTM D7647	>10	<b>1</b>	1	---
Particles >71µm	ASTM D7647	>3	<b>1</b>	1	---
Oil Cleanliness	ISO 4406 (c)	>17/16/14	<b>22/19/12</b>	19/15/10	---

# OIL ANALYSIS REPORT


## Particle Trend



## Water (KF)




## Viscosity @ 100°C



## Water (KF)



## Viscosity @ 100°C



## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN) mg KOH/g	ASTM D974*	0.86	<b>0.24</b>	0.20	---

## VISUAL

method	limit/base	current	history1	history2		
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	---
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	---
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	---
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	---
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	---
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	---
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	---
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	---
Emulsified Water	scalar	Visual*	>0.1	<b>NEG</b>	NEG	---
Free Water	scalar	Visual*		<b>NEG</b>	NEG	---

## FLUID PROPERTIES


method	limit/base	current	history1	history2		
Visc @ 40°C	cSt	ASTM D7279(m)	124.3	<b>134</b>	128	122
Visc @ 100°C	cSt	ASTM D7279(m)	13.7	<b>14.2</b>	13.8	13.14
Viscosity Index (VI)	Scale	ASTM D2270*	106	<b>103</b>	104	101

## SAMPLE IMAGES


method	limit/base	current	history1	history2
Color				no image
Bottom				no image

## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals



### Viscosity @ 40°C



### Particle Count



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0085499 **Received** : 23 Feb 2024  
**Lab Number** : **02617664** **Tested** : 27 Feb 2024  
**Unique Number** : 5734774 **Diagnosed** : 27 Feb 2024 - Wes Davis  
**Test Package** : PLANT ( Additional Tests: KF, KV100, VI )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**NuVista Energy**  
 10508 67 Ave, #201  
 Grande Prairie, AB  
 CA T8W 0K8  
 Contact: Eldon Weaver  
 eweaver@nvaenergy.com

T:  
F: