

Machine Id
Crane - Mid Ship Fuel Sample (S/N Sample Tag: MA-04002)
Component
Diesel Fuel
Fluid
No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

DIAGNOSIS

Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. We advise that you filter this fluid before use. We recommend you service the filters on this component. Resample at the next service interval to monitor.

Contaminants

There is a light amount of silt (particulates < 14 microns in size) present in the fuel. The water content is negligible.

Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PC	PC	PC
Sample Date	Client Info	07 Feb 2024	24 Jan 2024	06 Sep 2023
Machine Age	hrs	0	0	0
Sample Status		ATTENTION	ATTENTION	NORMAL

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2		
Specific Gravity	ASTM D1298*	0.839	0.851	0.850	0.844	
Fuel Color	text	Visual Screen*	Yellow	Yellow	Yellow	
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.8	2.8	3.1
Pensky-Martens Flash Point	°C	ASTM D7215*	52	64.7	64.1	62.2

SULFUR CONTENT

method	limit/base	current	history1	history2		
Sulfur	ppm	ASTM D5185(m)	10	13	14	14

DISTILLATION

method	limit/base	current	history1	history2		
Initial Boiling Point	°C	ASTM D2887*	165	177	176	173
5% Distillation Point	°C	ASTM D2887*		202	201	197
10% Distill Point	°C	ASTM D2887*	201	214	213	209
15% Distillation Point	°C	ASTM D2887*		222	221	218
20% Distill Point	°C	ASTM D2887*	216	231	229	227
30% Distill Point	°C	ASTM D2887*	230	245	243	243
40% Distill Point	°C	ASTM D2887*	243	256	254	256
50% Distill Point	°C	ASTM D2887*	255	268	266	268
60% Distill Point	°C	ASTM D2887*	267	280	278	282
70% Distill Point	°C	ASTM D2887*	280	292	290	295
80% Distill Point	°C	ASTM D2887*	295	306	304	311
85% Distillation Point	°C	ASTM D2887*		316	314	321
90% Distill Point	°C	ASTM D2887*	310	327	325	332
95% Distillation Point	°C	ASTM D2887*		345	343	350
Final Boiling Point	°C	ASTM D2887*	341	362	360	371

IGNITION QUALITY

method	limit/base	current	history1	history2	
API Gravity	ASTM D1298*	37.7	34	34	36
Cetane Index	ASTM D4737*	<40.0	46	46	49






CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185(m)	<1.0	0	0	0
Sodium	ppm	ASTM D5185(m)	<0.1	0	<1	0
Potassium	ppm	ASTM D5185(m)	<0.1	0	0	<1
Water	%	ASTM D6304*	<0.05	0.003	0.013	0.004
ppm Water	ppm	ASTM D6304*	<500	38	135	46.5

FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>2500	4281	4766	851
Particles >6µm	ASTM D7647	>640	1188	1192	163
Particles >14µm	ASTM D7647	>80	69	36	4
Particles >21µm	ASTM D7647	>20	12	5	1
Particles >38µm	ASTM D7647	>4	0	0	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	19/17/13	19/17/12	17/15/9




FUEL REPORT



HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	0	0	0
Nickel	ppm	ASTM D5185(m)	<0.1	0	0	0
Lead	ppm	ASTM D5185(m)	<0.1	0	0	0
Vanadium	ppm	ASTM D5185(m)	<0.1	0	0	0
Iron	ppm	ASTM D5185(m)	<0.1	0	0	<1
Calcium	ppm	ASTM D5185(m)	<0.1	0	0	0
Magnesium	ppm	ASTM D5185(m)	<0.1	0	0	<1
Phosphorus	ppm	ASTM D5185(m)	<0.1	<1	<1	0
Zinc	ppm	ASTM D5185(m)	<0.1	0	0	0

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC
Lab Number : 02618518
Unique Number : 5735628
Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PrtCount)

Suncor - Terra Nova Projects
 Scotia Centre, 235 Water Street
 St. John's, NL
 CA A1C 1B6
 Contact: Josh Hynes
 joshhynes@suncor.com
 T: (709)778-3575
 F: (709)724-2835

*To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.*