




Area
Fwd Machinery Space [WO 450327061]
Machine Id
Pump - Fire Water (Stbd) - Gearbox (S/N Sample Tag PA-71001B-S2)
Component
Starboard Gearbox
Fluid
PETRO CANADA PREMIUM R&O 220 (98 LTR)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please submit a sample of the new (unused) oil to establish a baseline.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE
Particles >4µm	ASTM D7647	>20000	▲ 134235	▲ 139168	▲ 177354
Particles >6µm	ASTM D7647	>5000	▲ 44139	▲ 47007	▲ 43611
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 24/23/17	▲ 24/23/17	▲ 25/23/17
MPC Varnish Potential	Scale	ASTM D7843(m)* >15	▲ 45	---	---

Customer Id: TERHAM
Sample No.: PC0080294
Lab Number: 02619452
Test Package: AOM 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation. Please submit a sample of the new (unused) oil to establish a baseline.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	---	---	?	We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level.

HISTORICAL DIAGNOSIS

16 Jan 2024 Diag: Kevin Marson

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



06 Dec 2023 Diag: Kevin Marson

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



13 Oct 2023 Diag: Kevin Marson

ISO




Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



Area
Fwd Machinery Space [WO 450327061]
 Machine Id
Pump - Fire Water (Stbd) - Gearbox (S/N Sample Tag PA-71001B-S2)
 Component
Starboard Gearbox
 Fluid
PETRO CANADA PREMIUM R&O 220 (98 LTR)



DIAGNOSIS

▲ Recommendation
 Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. We recommend that you use electrostatic filtration to remove insolubles from the oil and to reduce the levels of varnish in the system. Alternatively draining a percentage of the oil and topping up with fresh oil (sweetening the oil) may provide a reduction in the varnish potential level. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please submit a sample of the new (unused) oil to establish a baseline.

Wear
 All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system.

▲ Contaminants
 There is a high amount of silt (particulates < 14 microns in size) present in the oil. MPC (Membrane Patch Colorimetry) test indicates a moderate concentration of varnish present.

Oil Condition
 The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PC0080294	PC	PC0076275
Sample Date	Client Info	20 Feb 2024	16 Jan 2024	06 Dec 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		SEVERE	SEVERE	SEVERE

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	0	0	0
Iron	ppm ASTM D5185(m) >150	6	6	6
Chromium	ppm ASTM D5185(m) >10	0	0	0
Nickel	ppm ASTM D5185(m) >10	<1	<1	<1
Titanium	ppm ASTM D5185(m)	0	0	0
Silver	ppm ASTM D5185(m)	0	0	0
Aluminum	ppm ASTM D5185(m) >5	1	<1	<1
Lead	ppm ASTM D5185(m) >65	<1	<1	<1
Copper	ppm ASTM D5185(m) >80	<1	<1	<1
Tin	ppm ASTM D5185(m) >8	0	0	0
Antimony	ppm ASTM D5185(m) >5	0	0	0
Vanadium	ppm ASTM D5185(m)	0	0	0
Beryllium	ppm ASTM D5185(m)	0	0	0
Cadmium	ppm ASTM D5185(m)	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m)	3	3	4
Barium	ppm ASTM D5185(m)	0	0	0
Molybdenum	ppm ASTM D5185(m)	0	0	0
Manganese	ppm ASTM D5185(m)	0	0	0
Magnesium	ppm ASTM D5185(m) 0	<1	1	<1
Calcium	ppm ASTM D5185(m)	7	7	7
Phosphorus	ppm ASTM D5185(m) 0	31	32	31
Zinc	ppm ASTM D5185(m)	4	4	4
Sulfur	ppm ASTM D5185(m) 500	3374	3430	3489
Lithium	ppm ASTM D5185(m)	<1	<1	<1






CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >20	1	3	1
Sodium	ppm ASTM D5185(m)	0	0	<1
Potassium	ppm ASTM D5185(m) >20	1	<1	0
Water	% ASTM D6304* >0.2	0.002	---	---
ppm Water	ppm ASTM D6304* >2000	18	---	---

INFRA-RED

method	limit/base	current	history1	history2
Soot %	% ASTM D7844*	0	---	---
Nitration	Abs/cm ASTM D7624*	2.4	---	---
Sulfation	Abs/.1mm ASTM D7415*	12.0	---	---

OIL ANALYSIS REPORT



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0080294
Lab Number : 02619452
Unique Number : 5736562
Test Package : AOM 2
Received : 02 Mar 2024
Tested : 02 Mar 2024
Diagnosed : 02 Mar 2024 - Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Suncor - Terra Nova Projects
 Scotia Centre, 235 Water Street
 St. John's, NL
 CA A1C 1B6
 Contact: Josh Hynes
 joshhynes@suncor.com
 T: (709)778-3575
 F: (709)724-2835

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 134235	▲ 139168	▲ 177354
Particles >6µm	ASTM D7647	>5000	▲ 44139	▲ 47007	▲ 43611
Particles >14µm	ASTM D7647	>640	● 729	● 1091	● 807
Particles >21µm	ASTM D7647	>160	83	125	79
Particles >38µm	ASTM D7647	>40	7	2	2
Particles >71µm	ASTM D7647	>10	5	1	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 24/23/17	▲ 24/23/17	▲ 25/23/17

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm	ASTM D7414*	3.0	---	---
Acid Number (AN)	mg KOH/g	ASTM D974*	0.15	0.16	0.12
MPC Varnish Potential	Scale	ASTM D7843(m)*	▲ 45	---	---

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	NEG	NEG	NEG
Free Water	scalar	Visual*	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	206.5	212	212
Visc @ 100°C	cSt	ASTM D7279(m)	18.6	18.6	18.7
Viscosity Index (VI)	Scale	ASTM D2270*	96	97	98

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					
MPC					no image


FERROGRAPHY REPORT

Area
Fwd Machinery Space [WO 450327061]
Machine Id
Pump - Fire Water (Stbd) - Gearbox (S/N Sample Tag PA-71001B-S2)
Component
Starboard Gearbox
Fluid
PETRO CANADA PREMIUM R&O 220 (98 LTR)

Magn: 200x Illum: BC



Magn: 50x Illum: RW



Magn: 100x Illum: RW




DR-FERROGRAPHY		method	limit/base	current	history1	history2
Large Particles		DR-Ferr*		52.1	---	---
Small Particles		DR-Ferr*		24.7	---	---
Total Particles		DR-Ferr*	>---	76.8	---	---
Large Particles Percentage	%	DR-Ferr*		35.7	---	---
Severity Index		DR-Ferr*		1428	---	---


FERROGRAPHY		method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	ASTM D7684*		<div style="width: 40%; background-color: #55a868; height: 10px;"></div> 4		
Ferrous Sliding	Scale 0-10	ASTM D7684*				
Ferrous Cutting	Scale 0-10	ASTM D7684*				
Ferrous Rolling	Scale 0-10	ASTM D7684*		<div style="width: 20%; background-color: #55a868; height: 10px;"></div> 2		
Ferrous Break-in	Scale 0-10	ASTM D7684*				
Ferrous Spheres	Scale 0-10	ASTM D7684*				
Ferrous Black Oxides	Scale 0-10	ASTM D7684*		<div style="width: 10%; background-color: #55a868; height: 10px;"></div> 1		
Ferrous Red Oxides	Scale 0-10	ASTM D7684*				
Ferrous Corrosive	Scale 0-10	ASTM D7684*				
Ferrous Other	Scale 0-10	ASTM D7684*				
Nonferrous Rubbing	Scale 0-10	ASTM D7684*				
Nonferrous Sliding	Scale 0-10	ASTM D7684*				
Nonferrous Cutting	Scale 0-10	ASTM D7684*				
Nonferrous Rolling	Scale 0-10	ASTM D7684*				
Nonferrous Other	Scale 0-10	ASTM D7684*				
Carbonaceous Material	Scale 0-10	ASTM D7684*				
Lubricant Degradation	Scale 0-10	ASTM D7684*				
Sand/Dirt	Scale 0-10	ASTM D7684*		<div style="width: 10%; background-color: #55a868; height: 10px;"></div> 1		
Fibres	Scale 0-10	ASTM D7684*				
Spheres	Scale 0-10	ASTM D7684*				
Other	Scale 0-10	ASTM D7684*		<div style="width: 10%; background-color: #55a868; height: 10px;"></div> 1		

WEAR

All component wear rates are normal.
The ferrography results are normal indicating no abnormal wear in the system.



MPC (Varnish Test)



Sample Color & Clarity

