


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
#3 DEWATER CENTRIFUGE (S/N 0000203514)

Component
Bearing

Fluid
PETRO CANADA TURBOFLO R&O 46 (40 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PC0058388	PC0058166	PC0058430
Sample Date	Client Info	14 Feb 2024	08 Mar 2023	13 Sep 2022
Machine Age	hrs	14759	8463	5775
Oil Age	hrs	0	0	0
Oil Changed	Client Info	Not Chngd	Not Chngd	Not Chngd
Sample Status		NORMAL	NORMAL	ABNORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	0	0	0
Iron	ppm ASTM D5185(m) >20	1	2	<1
Chromium	ppm ASTM D5185(m) >20	0	0	0
Nickel	ppm ASTM D5185(m) >20	<1	0	<1
Titanium	ppm ASTM D5185(m)	0	0	0
Silver	ppm ASTM D5185(m)	0	0	0
Aluminum	ppm ASTM D5185(m) >20	<1	<1	<1
Lead	ppm ASTM D5185(m) >20	0	<1	<1
Copper	ppm ASTM D5185(m) >20	<1	1	<1
Tin	ppm ASTM D5185(m) >20	0	0	0
Antimony	ppm ASTM D5185(m)	0	<1	<1
Vanadium	ppm ASTM D5185(m)	0	0	0
Beryllium	ppm ASTM D5185(m)	0	0	0
Cadmium	ppm ASTM D5185(m)	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m)	0	<1	1
Barium	ppm ASTM D5185(m)	0	0	0
Molybdenum	ppm ASTM D5185(m)	0	0	<1
Manganese	ppm ASTM D5185(m)	0	0	0
Magnesium	ppm ASTM D5185(m)	<1	0	<1
Calcium	ppm ASTM D5185(m) 0	<1	0	3
Phosphorus	ppm ASTM D5185(m) 3	5	9	8
Zinc	ppm ASTM D5185(m) 0	2	7	4
Sulfur	ppm ASTM D5185(m)	170	166	161
Lithium	ppm ASTM D5185(m)	<1	<1	<1





CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >15	0	0	0
Sodium	ppm ASTM D5185(m)	2	1	2
Potassium	ppm ASTM D5185(m) >20	<1	1	0

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974* 0.12	0.06	0.08	0.06

OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	▲ WGOIL
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	.2%
Free Water	scalar	Visual*		NEG	▲ 5%

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	44.4	46.3	44.8
Visc @ 100°C	cSt	ASTM D7279(m)	6.72	6.9	6.7
Viscosity Index (VI)	Scale	ASTM D2270*	104	104	102

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS	method	limit/base	current	history1	history2
Ferrous Alloys					
Non-ferrous Metals					
Viscosity @ 40°C					
PQ					
Acid Number					



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **ONTARIO CLEAN WATER AGENCY- SOUTH PEEL FACILITIES**
Sample No. : PC0058388 **Received** : 05 Mar 2024 **1300 LAKESHORE RD**
Lab Number : 02619927 **Tested** : 05 Mar 2024 **MISSISSAUGA, ON**
Unique Number : 5737037 **Diagnosed** : 05 Mar 2024 - Wes Davis **CA L5E 1E9**
Test Package : IND 2 (Additional Tests: KV100, TAN Man, VI) **Contact: Angelo Magnifico**
amagnifico@ocwa.com
To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.
T: (905)274-1223
F: (905)274-2076