

Machine Id
THICKENING NO#5 (S/N 800054-2005)

Component
Centrifugal Compressor

Fluid
PETRO CANADA TURBOFLO R&O 46 (30 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PC0058392	PC349263	PC340131
Sample Date	Client Info		14 Feb 2024	07 Oct 2014	24 Sep 2012
Machine Age	hrs	Client Info	49216	24719	20579
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		Not Changed	N/A	N/A
Sample Status			NORMAL	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	0	9
Iron	ppm	ASTM D5185(m) >50	1	<1	<1
Chromium	ppm	ASTM D5185(m) >10	0	0	0
Nickel	ppm	ASTM D5185(m)	0	0	0
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >25	<1	0	<1
Lead	ppm	ASTM D5185(m) >25	3	2	4
Copper	ppm	ASTM D5185(m) >50	2	<1	<1
Tin	ppm	ASTM D5185(m) >15	0	0	0
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	0	<1
Barium	ppm	ASTM D5185(m)	2	0	0
Molybdenum	ppm	ASTM D5185(m)	0	<1	0
Manganese	ppm	ASTM D5185(m)	0	<1	0
Magnesium	ppm	ASTM D5185(m)	<1	0	<1
Calcium	ppm	ASTM D5185(m) 0	1	<1	<1
Phosphorus	ppm	ASTM D5185(m) 3	6	2	1
Zinc	ppm	ASTM D5185(m) 0	5	6	10
Sulfur	ppm	ASTM D5185(m)	145	24	59
Lithium	ppm	ASTM D5185(m)	<1	<1	<1






CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >25	3	0	<1
Sodium	ppm	ASTM D5185(m)	3	8	17
Potassium	ppm	ASTM D5185(m) >20	1	0	<1
Water	%	ASTM D6304* >0.1	0.001	---	---
ppm Water	ppm	ASTM D6304* >1000	4	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974* 0.12	0.07	0.087	0.09

OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	VLITE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	44.4	45.9	46.5
Visc @ 100°C	cSt	ASTM D7279(m)	6.72	6.8	6.9
Viscosity Index (VI)	Scale	ASTM D2270*	104	101	103

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0058392
Lab Number : 02619930
Unique Number : 5737040
Test Package : IND 2 (Additional Tests: KF, KV100, TAN Man, VI)

ONTARIO CLEAN WATER AGENCY- SOUTH PEEL FACILITIES
 1300 LAKESHORE RD
 MISSISSAUGA, ON
 CA L5E 1E9
 Contact: Angelo Magnifico
 amagnifico@ocwa.com
 T: (905)274-1223
 F: (905)274-2076

*To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.*