



Area  
**1311**  
Machine Id  
**CRUSHER HYDROSET SYSTEM**  
Component  
**Hydraulic Power Pack**  
Fluid  
**PETRO CANADA ENDURATEX EP 320 (379 LTR)**



**COMPONENT CONDITION SUMMARY**

**▲ Particle Trend**



**RECOMMENDATION**

We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

**PROBLEMATIC TEST RESULTS**

Sample Status				SEVERE	SEVERE	SEVERE
Particles >4µm	ASTM D7647	>5000	▲ <b>328801</b>	▲ 256468	▲ 154418	
Particles >6µm	ASTM D7647	>1300	▲ <b>160221</b>	▲ 153188	▲ 44586	
Particles >14µm	ASTM D7647	>160	▲ <b>6120</b>	▲ 5055	▲ 2597	
Particles >21µm	ASTM D7647	>40	▲ <b>612</b>	▲ 464	▲ 448	
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ <b>26/25/20</b>	▲ 25/24/20	▲ 24/23/19	
White Metal	scalar	Visual*	NONE	▲ <b>VLITE</b>	▲ VLITE	NONE
PrtFilter						no image

Customer Id: INCVOS  
Sample No.: PC0070691  
Lab Number: 02620941  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Check For Visual Metal	---	---	?	We advise that you check for visible metal particles in the oil.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

### 05 Dec 2023 Diag: Kevin Marson

#### WEAR PARTICLES



We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Wear particle analysis indicates that the ferrous spheres particles are abnormal. Light concentration of visible metal present. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

[view report](#)



### 01 Nov 2023 Diag: Wes Davis

#### ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



### 11 Sep 2023 Diag: Wes Davis

#### ISO




We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



Area  
**1311**  
Machine Id  
**CRUSHER HYDROSET SYSTEM**  
Component  
**Hydraulic Power Pack**  
Fluid  
**PETRO CANADA ENDURATEX EP 320 (379 LTR)**



**DIAGNOSIS**

**Recommendation**

We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

**Wear**

Light concentration of visible metal present.

**Contamination**

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

**Fluid Condition**

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

Particle Filter (Magn: 200 x)



**SAMPLE INFORMATION**

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC0070691</b>	PC0070723	PC0058532
Sample Date	Client Info	<b>27 Feb 2024</b>	05 Dec 2023	01 Nov 2023
Machine Age	days	<b>0</b>	0	0
Oil Age	days	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>SEVERE</b>	SEVERE	SEVERE

**CONTAMINATION**

method	limit/base	current	history1	history2
Water	WC Method >0.05	<b>NEG</b>	NEG	NEG

**WEAR METALS**

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185(m) >20	<b>4</b>	2	1
Chromium	ppm ASTM D5185(m) >20	<b>0</b>	0	0
Nickel	ppm ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1
Titanium	ppm ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm ASTM D5185(m)	<b>0</b>	0	<1
Aluminum	ppm ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1
Lead	ppm ASTM D5185(m) >20	<b>4</b>	1	2
Copper	ppm ASTM D5185(m) >20	<b>9</b>	5	4
Tin	ppm ASTM D5185(m) >20	<b>2</b>	1	<1
Antimony	ppm ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm ASTM D5185(m)	<b>0</b>	0	0

**ADDITIVES**

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m) 55	<b>31</b>	33	33
Barium	ppm ASTM D5185(m) 0	<b>0</b>	0	<1
Molybdenum	ppm ASTM D5185(m) 0	<b>0</b>	0	0
Manganese	ppm ASTM D5185(m) 0	<b>0</b>	0	0
Magnesium	ppm ASTM D5185(m) 0	<b>&lt;1</b>	<1	<1
Calcium	ppm ASTM D5185(m) 0	<b>1</b>	<1	<1
Phosphorus	ppm ASTM D5185(m) 240	<b>206</b>	204	200
Zinc	ppm ASTM D5185(m) 1	<b>3</b>	3	3
Sulfur	ppm ASTM D5185(m) 13700	<b>8334</b>	8096	7916
Lithium	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	<1






**CONTAMINANTS**

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >15	<b>7</b>	7	7
Sodium	ppm ASTM D5185(m)	<b>0</b>	0	<1
Potassium	ppm ASTM D5185(m) >20	<b>1</b>	<1	0

**FLUID CLEANLINESS**

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	<b>▲ 328801</b>	▲ 256468	▲ 154418
Particles >6µm	ASTM D7647 >1300	<b>▲ 160221</b>	▲ 153188	▲ 44586
Particles >14µm	ASTM D7647 >160	<b>▲ 6120</b>	▲ 5055	▲ 2597
Particles >21µm	ASTM D7647 >40	<b>▲ 612</b>	▲ 464	▲ 448
Particles >38µm	ASTM D7647 >10	<b>10</b>	4	9
Particles >71µm	ASTM D7647 >3	<b>1</b>	1	3
Oil Cleanliness	ISO 4406 (c) >19/17/14	<b>▲ 26/25/20</b>	▲ 25/24/20	▲ 24/23/19

# OIL ANALYSIS REPORT



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0070691  
**Lab Number** : 02620941  
**Unique Number** : 5746060  
**Test Package** : IND 2 ( Additional Tests: Bottom, BottomAnalysis, FilterPatch, KV100, PrtFilter, TAN M&M)

**Vale - Voisey's Bay**  
 Voisey's Bay Mine Site, P.O. Box 7001, Str. C Happy Valley  
 Goose Bay, NL  
 CA A0P 1C0  
 Contact: Robert Feltham  
 robert.feltham@vale.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN) mg KOH/g	ASTM D974*	0.4	<b>0.57</b>	0.46	0.56

## VISUAL

method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	▲ VLITE	▲ VLITE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML
Emulsified Water	scalar	Visual*	>0.05	<b>NEG</b>	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG

## FLUID PROPERTIES

method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	325	<b>311</b>	314
Visc @ 100°C	cSt	ASTM D7279(m)	25.22	<b>24.4</b>	24.4
Viscosity Index (VI)	Scale	ASTM D2270*	100	<b>99</b>	98

## SAMPLE IMAGES

