




Area
Gas Compression
Machine Id
Compressor (HP2) - Lubrication System (S/N Sample Tag XX-23004-S1)
Component
Lube System
Fluid
PETRO CANADA TURBOFLO XL32 (10350 LTR)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. No other corrective action is recommended at this time. Diagnostician's Note: The debris on the bottom of the sample combined with the ferrous red & black oxides present in the ferrogram indicate this was an improperly taken sample (dead pipe line, or low on the bottom of the reservoir). There was a very light amount of insoluble material present. Suggest taking a resample from a suitable sampling port to validate the results before taking any serious maintenance actions.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	ATTENTION
Ferrous Black Oxides	Scale 0-10	ASTM D7684*	▲ 3		
Ferrous Red Oxides	Scale 0-10	ASTM D7684*	▲ 3		
Particles >6µm		ASTM D7647 >320	▲ 24570	▲ 1147	● 432
Particles >14µm		ASTM D7647 >40	▲ 1988	▲ 103	● 52
Particles >21µm		ASTM D7647 >10	▲ 620	▲ 24	● 16
Particles >38µm		ASTM D7647 >3	▲ 57	3	1
Particles >71µm		ASTM D7647 >3	▲ 6	1	0
Oil Cleanliness		ISO 4406 (c) >--/15/12	▲ 24/22/18	▲ 19/17/14	● 17/16/13
MPC Varnish Potential	Scale	ASTM D7843(m)* >15	▲ 16	---	---

Customer Id: TERHAM
Sample No.: PC0082750
Lab Number: 02622711
Test Package: AOM 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Bill Quesnel CLS, OMA II, MLA-III, LLA-I +1
(289)291-4641 x4641
Bill.Quesnel@wearcheck.com


To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS


ISO




08 Feb 2024 Diag: Kevin Marson

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MAR 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Component wear rates appear to be normal (unconfirmed). There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report




ISO




29 Jan 2024 Diag: Kevin Marson

We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report




ISO




05 Jan 2024 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MAR 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Component wear rates appear to be normal (unconfirmed). There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



Area
Gas Compression
Machine Id
Compressor (HP2) - Lubrication System (S/N Sample Tag XX-23004-S1)
Component
Lube System
Fluid
PETRO CANADA TURBOFLO XL32 (10350 LTR)



DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. No other corrective action is recommended at this time. Diagnostician's Note: The debris on the bottom of the sample combined with the ferrous red & black oxides present in the ferrogram indicate this was an improperly taken sample (dead pipe line, or low on the bottom of the reservoir). There was a very light amount of insoluble material present. Suggest taking a resample from a suitable sampling port to validate the results before taking any serious maintenance actions.

Wear

Wear particle analysis indicates that the ferrous black oxides and ferrous red oxides particles are marginal. All other component wear rates are normal.

Contaminants

There is a high amount of particulates (2 to 100 microns in size) present in the oil. MPC (Membrane Patch Colorimetry) test indicates a light concentration of varnish present. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

Oil Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PC0082750	PC	PC0076669
Sample Date	Client Info	01 Mar 2024	08 Feb 2024	29 Jan 2024
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		SEVERE	ABNORMAL	ATTENTION

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	0	---	---
Iron	ppm	ASTM D5185(m) >20	<1	0
Chromium	ppm	ASTM D5185(m) >10	0	0
Nickel	ppm	ASTM D5185(m) >10	<1	0
Titanium	ppm	ASTM D5185(m)	0	0
Silver	ppm	ASTM D5185(m)	0	0
Aluminum	ppm	ASTM D5185(m) >10	<1	<1
Lead	ppm	ASTM D5185(m) >20	0	0
Copper	ppm	ASTM D5185(m) >20	0	<1
Tin	ppm	ASTM D5185(m) >10	0	0
Antimony	ppm	ASTM D5185(m)	0	0
Vanadium	ppm	ASTM D5185(m)	0	0
Beryllium	ppm	ASTM D5185(m)	0	0
Cadmium	ppm	ASTM D5185(m)	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	0	0
Barium	ppm	ASTM D5185(m) 0	0	0
Molybdenum	ppm	ASTM D5185(m) 0	0	0
Manganese	ppm	ASTM D5185(m) 0	0	0
Magnesium	ppm	ASTM D5185(m) 0	<1	<1
Calcium	ppm	ASTM D5185(m) 0	<1	8
Phosphorus	ppm	ASTM D5185(m) 5	2	3
Zinc	ppm	ASTM D5185(m) 0	<1	2
Sulfur	ppm	ASTM D5185(m) 750	667	692
Lithium	ppm	ASTM D5185(m)	<1	<1






CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	<1	0
Sodium	ppm	ASTM D5185(m)	0	0
Potassium	ppm	ASTM D5185(m) >20	<1	<1
Water	%	ASTM D6304* >0.05	0.003	---
ppm Water	ppm	ASTM D6304* >500	27	23

INFRA-RED

method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	0	---
Nitration	Abs/cm	ASTM D7624*	1.9	---
Sulfation	Abs/.1mm	ASTM D7415*	10.7	---

OIL ANALYSIS REPORT



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0082750 **Received** : 18 Mar 2024
Lab Number : **02622711** **Tested** : 22 Mar 2024
Unique Number : 5747830 **Diagnosed** : 22 Mar 2024 - Bill Quesnel
Test Package : AOM 2

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		80490	3526	1227
Particles >6µm	ASTM D7647	>320	▲ 24570	▲ 1147	● 432
Particles >14µm	ASTM D7647	>40	▲ 1988	▲ 103	● 52
Particles >21µm	ASTM D7647	>10	▲ 620	▲ 24	● 16
Particles >38µm	ASTM D7647	>3	▲ 57	3	1
Particles >71µm	ASTM D7647	>3	▲ 6	1	0
Oil Cleanliness	ISO 4406 (c)	>--/15/12	▲ 24/22/18	▲ 19/17/14	● 17/16/13

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm ASTM D7414*		1.9	---	---
Acid Number (AN)	mg KOH/g ASTM D974*	0.04	0.06	0.04	0.06
Anti-Oxidant 1	% ASTM D6971*	<25	87	---	---
Anti-Oxidant 2	% ASTM D6971*	<25	90	---	---
MPC Varnish Potential	Scale ASTM D7843(m)*	>15	▲ 16	---	---





VISUAL	method	limit/base	current	history1	history2
White Metal	scalar Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar Visual*	NONE	NONE	NONE	NONE
Silt	scalar Visual*	NONE	NONE	NONE	NONE
Debris	scalar Visual*	NONE	LIGHT	NONE	NONE
Sand/Dirt	scalar Visual*	NONE	NONE	NONE	NONE
Appearance	scalar Visual*	NORML	NORML	NORML	NORML
Odor	scalar Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar Visual*	>0.05	NEG	NEG	.2%
Free Water	scalar Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D7279(m)	33.86	33.9	33.8	33.8
Visc @ 100°C	cSt ASTM D7279(m)	5.60	5.6	5.7	5.7
Viscosity Index (VI)	Scale ASTM D2270*	101	102	108	108

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					
MPC					no image

Suncor - Terra Nova Projects
 Scotia Centre, 235 Water Street
 St. John's, NL
 CA A1C 1B6
 Contact: Josh Hynes
 joshhynes@suncor.com
 T: (709)778-3575
 F: (709)724-2835

Area
Gas Compression
 Machine Id
Compressor (HP2) - Lubrication System (S/N Sample Tag XX-23004-S1)
 Component
Lube System
 Fluid
PETRO CANADA TURBOFLO XL32 (10350 LTR)




DR-FERROGRAPHY		method	limit/base	current	history1	history2
Large Particles		DR-Ferr*		9.8	---	---
Small Particles		DR-Ferr*		1.5	---	---
Total Particles		DR-Ferr*	>---	11.3	---	---
Large Particles Percentage	%	DR-Ferr*		73.5	---	---
Severity Index		DR-Ferr*		81	---	---


FERROGRAPHY		method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	ASTM D7684*		2		
Ferrous Sliding	Scale 0-10	ASTM D7684*		2		
Ferrous Cutting	Scale 0-10	ASTM D7684*				
Ferrous Rolling	Scale 0-10	ASTM D7684*		1		
Ferrous Break-in	Scale 0-10	ASTM D7684*				
Ferrous Spheres	Scale 0-10	ASTM D7684*				
Ferrous Black Oxides	Scale 0-10	ASTM D7684*		3		
Ferrous Red Oxides	Scale 0-10	ASTM D7684*		3		
Ferrous Corrosive	Scale 0-10	ASTM D7684*		2		
Ferrous Other	Scale 0-10	ASTM D7684*				
Nonferrous Rubbing	Scale 0-10	ASTM D7684*				
Nonferrous Sliding	Scale 0-10	ASTM D7684*				
Nonferrous Cutting	Scale 0-10	ASTM D7684*				
Nonferrous Rolling	Scale 0-10	ASTM D7684*				
Nonferrous Other	Scale 0-10	ASTM D7684*				
Carbonaceous Material	Scale 0-10	ASTM D7684*				
Lubricant Degradation	Scale 0-10	ASTM D7684*		3		
Sand/Dirt	Scale 0-10	ASTM D7684*		2		
Fibres	Scale 0-10	ASTM D7684*				
Spheres	Scale 0-10	ASTM D7684*				
Other	Scale 0-10	ASTM D7684*				

WEAR


Wear particle analysis indicates that the ferrous black oxides and ferrous red oxides particles are marginal. All other component wear rates are normal.

DR Ferrography





MPC (Varnish Test)



Sample Color & Clarity

