

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id 426013 Component

Diesel Engine

PETRO CANADA DURON SHP 15W40 (--- GAL)

	SAMPLE INFOR	MATION	method	limi <u>t/base</u>	current	historv1	historv2
	Sample Number		Client Info		GEI 0102901	GEL 0097327	GEL 0065880
em.	Sample Nate		Client Info		18 Mar 2024	19 Dec 2023	25 Sep 2023
	Machine Age	hrs	Client Info		0	0	0
е	Oil Age	hrs	Client Info		18310	17903	17303
	Oil Changed	1110	Client Info		N/A	N/A	N/A
	Sample Status				SEVERE	SEVERE	
				11 11 11	OLVENE	OLVENE	y1 history2 NEG 0.0 y1 history2 5 0 0 0 0 0 <1 1 1 2 2 <1
	CONTAMINAT	ION	method	limit/base	current	nistory I	nistory2
	Water		WC Method	>0.2	NEG	NEG	NEG
	Glycol		WC Method		NEG	NEG	0.0
cant	WEAR METAL	S	method	limit/base	current	history1	history2
	Iron	ppm	ASTM D5185(m)	>120	4	5	5
	Chromium	ppm	ASTM D5185(m)	>20	0	0	0
	Nickel	ppm	ASTM D5185(m)	>5	<1	<1	0
	Titanium	ppm	ASTM D5185(m)	>2	0	0	0
the	Silver	ppm	ASTM D5185(m)	>2	0	0	<1
	Aluminum	ppm	ASTM D5185(m)	>20	3	3	1
	Lead	ppm	ASTM D5185(m)	>40	<1	<1	2
	Copper	ppm	ASTM D5185(m)	>330	1	<1	<1
	Tin	ppm	ASTM D5185(m)	>15	<1	<1	0
	Antimony	ppm	ASTM D5185(m)		0	0	0
	Vanadium	ppm	ASTM D5185(m)		0	0	0
	Beryllium	ppm	ASTM D5185(m)		0	0	0
	Cadmium	ppm	ASTM D5185(m)		0	0	0
	ADDITIVES		method	limit/base	current	history1	history2
	Boron	ppm	ASTM D5185(m)	0	113	22	25
	Barium	ppm	ASTM D5185(m)	0	0	0	<1
	Molybdenum	ppm	ASTM D5185(m)	60	4	39	38
	Manganese	ppm	ASTM D5185(m)	0	0	0	0
	Magnesium	ppm	ASTM D5185(m)	1010	54	481	480
	Calcium	ppm	ASTM D5185(m)	1070	2066	1633	1661
	Phosphorus	ppm	ASTM D5185(m)	1150	911	702	705
	Zinc	ppm	ASTM D5185(m)	1270	1052	818	839
	Sulfur	ppm	ASTM D5185(m)	2060	2881	2033	2019
	Lithium	ppm	ASTM D5185(m)		<1	<1	<1
	CONTAMINAN	ITS	method	limit/base	current	history1	history2
	Silicon	ppm	ASTM D5185(m)	>25	3	4	4
	Sodium	ppm	ASTM D5185(m)		3	2	3
	Potassium	ppm	ASTM D5185(m)	>20	5	<1	12
	Fuel	%	ASTM D7593*	>3.0	5 .4	▲ 5	4 .1
	INFRA-RED		method	limit/base	current	history1	history2
	Soot %	%	ASTM D7844*	>4	0	0.1	0
	Nitration	Abs/cm	ASTM D7624*	>20	8.9	8.7	7.8
	Sulfation	Abs/.1mm	ASTM D7415*	>30	21.5	21.7	22.1

DIAGNOSIS

Recommendation

We advise that you check the fuel injection system. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Elevated aluminum (Al) and/or lead (Pb) and potassium (K) levels in your metals analysis are likely a result of solder flux release into the lubricant and is common on new equipment/components. There is a high amount of fuel present in the oil. Tests confirm the presence of fuel in the oil.

Fluid Condition

Fuel is present in the oil and is lowering the viscosity. The oil is no longer serviceable due to the presence of contaminants.



OIL ANALYSIS REPORT



	FLUID DEGRA	ADATION	DATION method		se ci	urrent	history1		1	history2	
	Oxidation	Abs/.1mm	ASTM D7414*	>25	17.	5	21	.1		20.8	
	VISUAL		method	limit/bas	e ci	urrent	ł	nistory ⁻	1	histor	ry2
	Emulsified Water	scalar	Visual*	>0.2	NE	G	NE	EG		NEG	
	Free Water	scalar	Visual*		NE	G	NE	EG		NEG	
/23	FLUID PROP	ERTIES	method	limit/bas	se ci	urrent	ł	history ⁻	1	histor	y2
Sep 25 Mar 18	Visc @ 100°C	cSt	ASTM D7279(m)	15.4	<mark>▲</mark> 12.2	2	1 0	.3		10.4	
	GRAPHS				Lood	(000)					
	³⁰⁰				100	(ppin)					
	250 - Gevere				80 - Severe	1		1	1		
/	E 150 - Abnormal				60						
	100 -				40-40-				1		
	50				20				1		
Sep25/2	28/21	21/22	20/23 -	18/24	18/20	28/21-	11/22	21/22	20/23 -	25/23	18/24
		Oct	Apr	Mar	- Chra	ā A	윤 	Oct	Apr	Sep	Mar
	⁵⁰ Severe) 			50 T	mum (p	pm)				
	40				40 - Severe						
	30				30-						
	20 - Abnormal				20 - Abnom	al					
	10				10-						
	11/22 - 28/21	21/22	20/23	8/24	18/20	28/21-	1/22 -	21/22	20/23	25/23	8/24
	Apr Febi	Octí	Aprá	Mar	-7 	Apr	Feb	Oct	Apri	Sept	Mar
	Copper (ppm)				SIIICO	n (ppm)					
	350 - Abnormal 300 -				70						
	250 - 토 200 -				50- 5.40-						
	150-				30 - Abnom	al	Λ				_
	50 -				10		/				
	11/22	21/22	20/23 -	8/24	18/20	28/21-	- 1/22	21/22	20/23	25/23	18/24
		Oct	Apri Sepi	Mar	-7 - E1	Apr	Feb	Octi	Apr	Sep	Mar
					16.0	Dilution					
	18 - Abnormal 16 - Base				14.0			1			
	00 14 - Abnormal				10.0 8.0			1			
	ස් ¹² - 10-	\neg		/ *	6.0 Severe		-	1	+		
					2.0 Abnom		1				
	8 -				0.0		¥				
	8/20 +	1/22	20/23	8/24 -	18/20	28/21	1/22	21/22	20/23	5/23	8/2

To discuss this sample r Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Report Id: GFL246 [WCAMIS] 02622941 (Generated: 03/20/2024 09:36:02) Rev: 1

CALA

ISO 17025:2017 Accredited Laboratory

Submitted By: Dave Varga Page 2 of 2

F: