




# OIL ANALYSIS REPORT

Sample Rating Trend

**WATER**



Machine Id  
**831011**  
Component  
**Diesel Engine**  
Fluid  
**RDL-3647 (--- GAL)**



## DIAGNOSIS

### Recommendation

Nous vous recommandons de vérifier la source de l'infiltration d'eau. Nous avons pris note que la vidange d'huile a été effectuée au moment de l'échantillonnage. Nous vous recommandons d'échantillonner de nouveau dès que possible afin de contrôler la situation.

### Wear

Les taux d'usure de tous les composants sont normaux.

### Contamination

Légère concentration d'eau dans l'huile. Le test de glycol est négatif.

### Fluid Condition

l'huile ne peut plus être utilisée en raison de la présence de contaminants.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>GFL0107580</b>	GFL0087608	GFL0079406
Sample Date	Client Info	<b>08 Mar 2024</b>	17 Aug 2023	26 Apr 2023
Machine Age	kms Client Info	<b>121232</b>	95295	81264
Oil Age	kms Client Info	<b>0</b>	0	0
Oil Changed	Client Info	<b>Changed</b>	Changed	Changed
Sample Status		<b>ABNORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

method	limit/base	current	history1	history2
Fuel	WC Method >5	<b>&lt;1.0</b>	<1.0	<1.0

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185(m) >80	<b>20</b>	10	27
Chromium	ppm ASTM D5185(m) >5	<b>3</b>	1	3
Nickel	ppm ASTM D5185(m) >2	<b>&lt;1</b>	0	2
Titanium	ppm ASTM D5185(m)	<b>0</b>	0	<1
Silver	ppm ASTM D5185(m) >3	<b>0</b>	0	0
Aluminum	ppm ASTM D5185(m) >30	<b>3</b>	2	3
Lead	ppm ASTM D5185(m) >30	<b>8</b>	<1	7
Copper	ppm ASTM D5185(m) >150	<b>2</b>	2	2
Tin	ppm ASTM D5185(m) >5	<b>&lt;1</b>	<1	<1
Antimony	ppm ASTM D5185(m)	<b>0</b>	0	<1
Vanadium	ppm ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m) 50	<b>4</b>	7	8
Barium	ppm ASTM D5185(m) 5	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185(m) 50	<b>119</b>	96	58
Manganese	ppm ASTM D5185(m) 0	<b>&lt;1</b>	<1	1
Magnesium	ppm ASTM D5185(m) 560	<b>185</b>	349	935
Calcium	ppm ASTM D5185(m) 1510	<b>2038</b>	1766	1492
Phosphorus	ppm ASTM D5185(m) 780	<b>685</b>	774	833
Zinc	ppm ASTM D5185(m) 870	<b>845</b>	890	950
Sulfur	ppm ASTM D5185(m) 2040	<b>2220</b>	2308	2162
Lithium	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	<1

## CONTAMINANTS




method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >20	<b>5</b>	5	14
Sodium	ppm ASTM D5185(m)	<b>4</b>	2	5
Potassium	ppm ASTM D5185(m) >20	<b>2</b>	<1	<1
Water	% ASTM D6304* >0.2	<b>▲ 0.317</b>	---	---
ppm Water	ppm ASTM D6304* >2000	<b>▲ 3170</b>	---	---
Glycol	% ASTM D7922*	<b>0.0</b>	NEG	NEG

## INFRA-RED

method	limit/base	current	history1	history2
Soot %	% ASTM D7844* >3	<b>0</b>	0	0
Nitration	Abs/cm ASTM D7624* >20	<b>10.1</b>	9.1	14.8
Sulfation	Abs./1mm ASTM D7415* >30	<b>24.3</b>	23.4	27.6



# OIL ANALYSIS REPORT











FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs./1mm	ASTM D7414*	>25	<b>15.6</b>	15.2	24.8

VISUAL		method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.2	▲ <b>.2%</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	15.1	<b>13.9</b>	14.1	13.7

## GRAPHS



ISO 17025:2017  
Accredited  
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
 Sample No. : GFL0107580  
 Lab Number : 02622990  
 Unique Number : 5748109  
 Test Package : MOB 1 ( Additional Tests: Glycol, KF )

GFL Environmental - 747 - GMA - Solid Waste  
 4 Chemin du Tremblay,  
 Boucherville, QC  
 CA J4B 6Z5  
 Contact: Steve Voyer  
 svoyer@matrec.ca

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

T:  
F: