




Machine Id
SPARTAN 25041 (P331)
Component
Right Diesel Engine
Fluid
CASTROL HYPURON 15W40 (28 LTR)



DIAGNOSIS

Recommendation
We advise that you check for the source of the coolant leak. The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Wear
All component wear rates are normal.

Contamination
Test for glycol is positive. There is a light concentration of glycol present in the oil.

Fluid Condition
The oil is no longer serviceable due to the presence of contaminants.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | | PC0088420 | AP100894 | AP96425 |
| Sample Date | Client Info | | | 21 Mar 2024 | 22 Jan 2016 | 15 Jan 2015 |
| Machine Age | mths | Client Info | | 0 | 82043 | 4551 |
| Oil Age | mths | Client Info | | 6 | 0 | 0 |
| Oil Changed | Client Info | | | Changed | Changed | Changed |
| Sample Status | | | | ABNORMAL | NORMAL | NORMAL |

| CONTAMINATION | | method | limit/base | current | history1 | history2 |
|---------------|-----------|--------|------------|----------------|----------|----------|
| Fuel | WC Method | >3.0 | | <1.0 | <1.0 | <1.0 |
| Water | WC Method | >0.2 | | NEG | NEG | NEG |




| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|---------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185(m) | >75 | 29 | 16 | 17 |
| Chromium | ppm | ASTM D5185(m) | >5 | <1 | <1 | <1 |
| Nickel | ppm | ASTM D5185(m) | >4 | 0 | <1 | <1 |
| Titanium | ppm | ASTM D5185(m) | >2 | 0 | <1 | <1 |
| Silver | ppm | ASTM D5185(m) | >2 | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185(m) | >15 | 2 | 4 | 4 |
| Lead | ppm | ASTM D5185(m) | >25 | 0 | 2 | 2 |
| Copper | ppm | ASTM D5185(m) | >100 | 4 | 3 | 9 |
| Tin | ppm | ASTM D5185(m) | >4 | 0 | <1 | <1 |
| Antimony | ppm | ASTM D5185(m) | | 0 | 2 | 2 |
| Vanadium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Beryllium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185(m) | | 0 | 0 | <1 |

| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|---------------|------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185(m) | | 5 | 30 | 29 |
| Barium | ppm | ASTM D5185(m) | | 0 | <1 | <1 |
| Molybdenum | ppm | ASTM D5185(m) | | 63 | <1 | <1 |
| Manganese | ppm | ASTM D5185(m) | | 0 | <1 | <1 |
| Magnesium | ppm | ASTM D5185(m) | | 878 | 11 | 18 |
| Calcium | ppm | ASTM D5185(m) | | 1073 | 2504 | 2420 |
| Phosphorus | ppm | ASTM D5185(m) | | 882 | 1015 | 1009 |
| Zinc | ppm | ASTM D5185(m) | | 1117 | 1231 | 1237 |
| Sulfur | ppm | ASTM D5185(m) | | 2423 | 3386 | 3548 |
| Lithium | ppm | ASTM D5185(m) | | <1 | <1 | <1 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|---------------|------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185(m) | >25 | 10 | 5 | 6 |
| Sodium | ppm | ASTM D5185(m) | | 65 | 3 | 2 |
| Potassium | ppm | ASTM D5185(m) | >20 | 22 | 7 | 6 |
| Glycol | % | ASTM D7922* | | 0.032 | 0.0 | 0.0 |

| INFRA-RED | | method | limit/base | current | history1 | history2 |
|-----------|----------|-------------|------------|-------------|----------|----------|
| Soot % | % | ASTM D7844* | >6 | 0.7 | 0.5 | 0.5 |
| Nitration | Abs/cm | ASTM D7624* | >20 | 11.5 | 10.9 | 10.3 |
| Sulfation | Abs.:1mm | ASTM D7415* | >30 | 25.5 | 26.6 | 25.3 |

OIL ANALYSIS REPORT











| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|-------------|------------|-------------|----------|----------|
| Oxidation | Abs./1mm | ASTM D7414* | >25 | 23.9 | 22.7 | 22.8 |

| VISUAL | | method | limit/base | current | history1 | history2 |
|------------------|--------|---------|------------|------------|----------|----------|
| Emulsified Water | scalar | Visual* | >0.2 | NEG | NEG | NEG |
| Free Water | scalar | Visual* | | NEG | NEG | NEG |

| FLUID PROPERTIES | | method | limit/base | current | history1 | history2 |
|----------------------|-------|---------------|------------|-------------|----------|----------|
| Visc @ 40°C | cSt | ASTM D7279(m) | 110 | 100 | --- | --- |
| Visc @ 100°C | cSt | ASTM D7279(m) | 15.0 | 13.7 | 15.9 | 14.8 |
| Viscosity Index (VI) | Scale | ASTM D2270* | 140 | 137 | --- | --- |

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0088420 **Received** : 26 Mar 2024
Lab Number : **02624574** **Tested** : 26 Mar 2024
Unique Number : 5749693 **Diagnosed** : 26 Mar 2024 - Wes Davis
Test Package : MOB 1 (Additional Tests: Glycol, KV40, VI)

TORONTO FIRE SERVICES
 40 TORYORK DRIVE
 TORONTO, ON
 CA M9L 1X6
 Contact: Antonio Rodrigues
 antonio.rodrigues@toronto.ca
 T:
 F: (416)338-9207

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.