


Machine Id
2007 SPARTAN 27036 PL432
Component
Front Diesel Engine
Fluid
PETRO CANADA 15W40 (40 LTR)



DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			PC0085019	AP105610	AP104629
Sample Date	Client Info			29 Feb 2024	20 Mar 2018	17 May 2017
Machine Age	mths	Client Info		6	105800	0
Oil Age	mths	Client Info		6	0	0
Oil Changed	Client Info			Changed	Changed	Not Changed
Sample Status				NORMAL	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>3.0		<1.0	<1.0	<1.0
Water	WC Method	>0.2		NEG	NEG	NEG
Glycol	WC Method			NEG	0.0	0.0



WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>90	23	21	15
Chromium	ppm	ASTM D5185(m)	>4	<1	<1	<1
Nickel	ppm	ASTM D5185(m)	>4	0	<1	<1
Titanium	ppm	ASTM D5185(m)	>2	0	<1	<1
Silver	ppm	ASTM D5185(m)	>2	0	<1	0
Aluminum	ppm	ASTM D5185(m)	>15	2	3	2
Lead	ppm	ASTM D5185(m)	>50	<1	5	2
Copper	ppm	ASTM D5185(m)	>55	3	14	5
Tin	ppm	ASTM D5185(m)	>4	0	<1	<1
Antimony	ppm	ASTM D5185(m)		0	2	1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		5	41	63
Barium	ppm	ASTM D5185(m)		0	0	<1
Molybdenum	ppm	ASTM D5185(m)		64	11	6
Manganese	ppm	ASTM D5185(m)		0	<1	<1
Magnesium	ppm	ASTM D5185(m)		998	11	10
Calcium	ppm	ASTM D5185(m)		1059	2504	2440
Phosphorus	ppm	ASTM D5185(m)		1024	1018	995
Zinc	ppm	ASTM D5185(m)		1218	1251	1170
Sulfur	ppm	ASTM D5185(m)		2535	3452	3410
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	8	6	3
Sodium	ppm	ASTM D5185(m)		38	134	17
Potassium	ppm	ASTM D5185(m)	>20	8	95	10

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	>6	0.8	0.6	0.2
Nitration	Abs/cm	ASTM D7624*	>20	9.4	9.6	8.2
Sulfation	Abs./1mm	ASTM D7415*	>30	22.0	23.4	23.2

OIL ANALYSIS REPORT











FLUID DEGRADATION	method	limit/base	current	history1	history2	
Oxidation	Abs./1mm	ASTM D7414*	>25	17.6	19.2	16.7

VISUAL	method	limit/base	current	history1	history2	
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	101	---	---
Visc @ 100°C	cSt	ASTM D7279(m)	13.9	14.5	14.6
Viscosity Index (VI)	Scale	ASTM D2270*	139	---	---

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0085019 **Received** : 26 Mar 2024
Lab Number : **02624582** **Tested** : 26 Mar 2024
Unique Number : 5749701 **Diagnosed** : 26 Mar 2024 - Wes Davis
Test Package : MOB 1 (Additional Tests: KV40, VI)

TORONTO FIRE SERVICES
 40 TORYORK DRIVE
 TORONTO, ON
 CA M9L 1X6
 Contact: Antonio Rodrigues
 antonio.rodrigues@toronto.ca
 T:
 F: (416)338-9207

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.