



OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
K603
Component
Natural Gas Compression Engine
Fluid
PETRO CANADA SENTRON LD SYNTHETIC BLEND (--- LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PC0089505	PC0085501	PC0085486
Sample Date	Client Info		27 Mar 2024	16 Feb 2024	22 Jan 2024
Machine Age	hrs	Client Info	28977	28238	27655
Oil Age	hrs	Client Info	27655	0	0
Oil Changed	Client Info		N/A	Not Changd	Changed
Sample Status			NORMAL	NORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>0.1	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >14	1	<1	3
Chromium	ppm	ASTM D5185(m) >3	0	0	0
Nickel	ppm	ASTM D5185(m) >5	0	0	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m) >5	0	0	0
Aluminum	ppm	ASTM D5185(m) >5	1	2	2
Lead	ppm	ASTM D5185(m) >8	0	0	<1
Copper	ppm	ASTM D5185(m) >5	<1	<1	<1
Tin	ppm	ASTM D5185(m) >3	0	0	0
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	1	<1	1
Barium	ppm	ASTM D5185(m) 0	0	0	0
Molybdenum	ppm	ASTM D5185(m) 0	0	0	<1
Manganese	ppm	ASTM D5185(m) 0	0	0	0
Magnesium	ppm	ASTM D5185(m) 3	6	6	7
Calcium	ppm	ASTM D5185(m) 1402	1419	1335	1645
Phosphorus	ppm	ASTM D5185(m) 246	253	247	301
Zinc	ppm	ASTM D5185(m) 305	321	297	376
Sulfur	ppm	ASTM D5185(m) 2310	2219	2277	2648
Lithium	ppm	ASTM D5185(m)	<1	<1	<1




CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >180	0	<1	2
Sodium	ppm	ASTM D5185(m)	<1	<1	<1
Potassium	ppm	ASTM D5185(m) >20	<1	<1	<1

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	0	0	0
Nitration	Abs/cm	ASTM D7624* >20	4.5	4.0	5.2
Nitration(Diff)	Abs/cm	ASTM E2412*	4.5	3.2	6.2
Sulfation	Abs./1mm	ASTM D7415* >30	16.7	15.9	20.7
Sulfation(Diff)	Abs/cm	ASTM E2412*	5	3.6	12.1

OIL ANALYSIS REPORT







FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs./1mm	ASTM D7414*	>25	10.2	9.4	12.8
Oxidation(Diff)	Abs/cm	ASTM E2412*		5.5	3.5	9.9
Acid Number (AN)	mg KOH/g	ASTM D974*	1.0	1.40	1.12	0.98

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	106.0	95.7	99.3	▲ 91.4
Visc @ 100°C	cSt	ASTM D7279(m)	15.6	13.5	14.2	▲ 12.9
Viscosity Index (VI)	Scale	ASTM D2270*	153	141	146	139

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0089505 **Received** : 01 Apr 2024
Lab Number : **02625652** **Tested** : 01 Apr 2024
Unique Number : 5750771 **Diagnosed** : 02 Apr 2024 - Bill Quesnel
Test Package : GEO 2 (Additional Tests: FT-IR, FT-IR(Diff), TAN Man)

NuVista Energy
 10508 67 Ave, #201
 Grande Prairie, AB
 CA T8W 0K8
 Contact: Eldon Weaver
 eweaver@nvaenergy.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
F: