


FUEL REPORT

Sample Rating Trend



ISO



Area
CRANES
Machine Id
Crane - Fwd Fuel Sample (S/N Sample Tag: MA-04003)
Component
Diesel Fuel
Fluid
No.2 DIESEL FUEL (LOW-SULPHUR) (--- GAL)

DIAGNOSIS

▲ Recommendation

We advise that you check all areas where contaminants can enter the system. Laboratory test indicate that this fuel is suitable for use and meets all test requirements. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you filter this fluid before use. Resample in 30-45 days to monitor this situation.

▲ Contaminants

There is a high amount of particulates (2 to 100 microns in size) present in the fuel. The water content is negligible.

Fuel Condition

The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PC	PC	PC0076303
Sample Date	Client Info	31 Mar 2024	07 Feb 2024	24 Jan 2024
Machine Age	hrs	0	0	0
Sample Status		SEVERE	SEVERE	ABNORMAL

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2		
Specific Gravity	ASTM D1298*	0.839	0.849	0.851	0.853	
Fuel Color	text	Visual Screen*	Yellow	Yellow	Yellow	
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	3	3	2.9
Pensky-Martens Flash Point	°C	ASTM D7215*	52	63	64.7	64.3

SULFUR CONTENT

method	limit/base	current	history1	history2		
Sulfur	ppm	ASTM D5185(m)	250	7	8	8

DISTILLATION

method	limit/base	current	history1	history2		
Initial Boiling Point	°C	ASTM D2887*	165	174	176	176
5% Distillation Point	°C	ASTM D2887*		199	203	202
10% Distill Point	°C	ASTM D2887*	201	211	215	214
15% Distillation Point	°C	ASTM D2887*		219	223	222
20% Distill Point	°C	ASTM D2887*	216	228	232	231
30% Distill Point	°C	ASTM D2887*	230	243	246	245
40% Distill Point	°C	ASTM D2887*	243	256	258	256
50% Distill Point	°C	ASTM D2887*	255	269	270	268
60% Distill Point	°C	ASTM D2887*	267	283	283	280
70% Distill Point	°C	ASTM D2887*	280	297	296	293
80% Distill Point	°C	ASTM D2887*	295	312	310	307
85% Distillation Point	°C	ASTM D2887*		323	321	318
90% Distill Point	°C	ASTM D2887*	310	334	331	329
95% Distillation Point	°C	ASTM D2887*		352	348	347
Final Boiling Point	°C	ASTM D2887*	341	377	363	377

IGNITION QUALITY

method	limit/base	current	history1	history2	
API Gravity	ASTM D1298*	37.7	35	34	34
Cetane Index	ASTM D4737*	<40.0	47	47	45






CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185(m)	<1.0	0	0	0
Sodium	ppm	ASTM D5185(m)	<0.1	<1	<1	<1
Potassium	ppm	ASTM D5185(m)	<0.1	0	0	0
Water	%	ASTM D6304*	<0.05	0.005	0.006	0.009
ppm Water	ppm	ASTM D6304*	<500	58	70	95

FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>2500	▲ 9241	▲ 24039	▲ 7747
Particles >6µm	ASTM D7647	>640	▲ 3401	▲ 8059	● 1050
Particles >14µm	ASTM D7647	>80	▲ 520	▲ 960	34
Particles >21µm	ASTM D7647	>20	▲ 213	▲ 223	8
Particles >38µm	ASTM D7647	>4	▲ 24	5	1
Particles >71µm	ASTM D7647	>3	1	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 20/19/16	▲ 22/20/17	▲ 20/17/12




FUEL REPORT



HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	0	0	0
Nickel	ppm	ASTM D5185(m)	<0.1	0	0	0
Lead	ppm	ASTM D5185(m)	<0.1	0	0	0
Vanadium	ppm	ASTM D5185(m)	<0.1	0	0	0
Iron	ppm	ASTM D5185(m)	<0.1	0	0	0
Calcium	ppm	ASTM D5185(m)	<0.1	0	0	0
Magnesium	ppm	ASTM D5185(m)	<0.1	0	0	0
Phosphorus	ppm	ASTM D5185(m)	<0.1	<1	<1	0
Zinc	ppm	ASTM D5185(m)	<0.1	0	0	0

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						

GRAPHS



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC **Received** : 01 Apr 2024
Lab Number : 02625825 **Tested** : 03 Apr 2024
Unique Number : 5750944 **Diagnosed** : 03 Apr 2024 - Kevin Marson
Test Package : FUEL (Additional Tests: CC Flash, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Suncor - Terra Nova Projects
 Scotia Centre, 235 Water Street
 St. John's, NL
 CA A1C 1B6
 Contact: Josh Hynes
 joshhynes@suncor.com
 T: (709)778-3575
 F: (709)724-2835