




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**731071**  
 Component  
**Natural Gas Engine**  
 Fluid  
**PETRO CANADA DURON GEO LD 15W40 (--- LTR)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>GFL0117153</b>	GFL0060979	GFL0044185
Sample Date	Client Info		<b>03 Apr 2024</b>	05 Oct 2022	23 Mar 2022
Machine Age	hrs	Client Info	<b>5506</b>	2726	1688
Oil Age	hrs	Client Info	<b>600</b>	1200	500
Oil Changed	Client Info		<b>Changed</b>	Changed	Not Changed
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>50	<b>15</b>	10	20
Chromium	ppm	ASTM D5185(m)	>4	<b>1</b>	<1	<1
Nickel	ppm	ASTM D5185(m)	>2	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	<1	<1
Silver	ppm	ASTM D5185(m)	>3	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185(m)	>9	<b>2</b>	2	2
Lead	ppm	ASTM D5185(m)	>30	<b>8</b>	2	<1
Copper	ppm	ASTM D5185(m)	>35	<b>1</b>	2	3
Tin	ppm	ASTM D5185(m)	>4	<b>&lt;1</b>	<1	<1
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	50	<b>7</b>	20	13
Barium	ppm	ASTM D5185(m)	5	<b>0</b>	0	<1
Molybdenum	ppm	ASTM D5185(m)	50	<b>60</b>	62	61
Manganese	ppm	ASTM D5185(m)	0	<b>0</b>	<1	2
Magnesium	ppm	ASTM D5185(m)	560	<b>635</b>	582	599
Calcium	ppm	ASTM D5185(m)	1510	<b>1764</b>	1622	1522
Phosphorus	ppm	ASTM D5185(m)	780	<b>755</b>	751	728
Zinc	ppm	ASTM D5185(m)	870	<b>1002</b>	908	933
Sulfur	ppm	ASTM D5185(m)	2040	<b>2114</b>	2113	2048
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>+100	<b>3</b>	4	6
Sodium	ppm	ASTM D5185(m)		<b>9</b>	7	6
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	<1

## INFRA-RED



	method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844*		<b>0</b>	0	0
Nitration	Abs/cm	ASTM D7624*	>20	<b>12.6</b>	10.4	11.2
Sulfation	Abs/.1mm	ASTM D7415*	>30	<b>25.7</b>	21.6	22.2

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	ASTM D7414*	>25	<b>20.2</b>	17.7	17.7











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	15.1	14.2	14.4

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : GFL0117153  
**Lab Number** : 02626850  
**Unique Number** : 5759982  
**Test Package** : MOB 1  
**Received** : 05 Apr 2024  
**Tested** : 05 Apr 2024  
**Diagnosed** : 05 Apr 2024 - Wes Davis

**GFL Environmental - 209 - Hamilton**  
 560 Seaman Street  
 Stoney Creek, ON  
 CA L8E 3X7  
 Contact: Fred Carleton  
 fred.carleton@gflenv.com  
 T: (289)925-6693  
 F: (905)664-9008

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.