OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Area
Gas Compression [450264293]
Machine Id
Pump - Crude Oil Recirc - DE Bearing (S/N Sample Tag PA-22001-DE)
Component
Pump
Fluid
PETRO CANADA TURBOFLO XL32 (1 LTR)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**PC0080246**	PC	PC
Sample Date		Client Info		**27 Mar 2024**	22 Dec 2019	03 Apr 2019
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**NORMAL**	ABNORMAL	SEVERE

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>.1	**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>75	**3**	2	9
Chromium	ppm	ASTM D5185(m)	>5	**0**	0	<1
Nickel	ppm	ASTM D5185(m)		**0**	0	<1
Titanium	ppm	ASTM D5185(m)		**<1**	0	0
Silver	ppm	ASTM D5185(m)		**0**	0	0
Aluminum	ppm	ASTM D5185(m)	>5	**0**	0	<1
Lead	ppm	ASTM D5185(m)	>10	**8**	<1	6
Copper	ppm	ASTM D5185(m)	>15	**14**	4	▲ 23
Tin	ppm	ASTM D5185(m)		**<1**	0	1
Antimony	ppm	ASTM D5185(m)		**0**	<1	0
Vanadium	ppm	ASTM D5185(m)		**0**	0	0
Beryllium	ppm	ASTM D5185(m)		**0**	0	0
Cadmium	ppm	ASTM D5185(m)		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	**0**	<1	<1
Barium	ppm	ASTM D5185(m)	0	**0**	0	0
Molybdenum	ppm	ASTM D5185(m)	0	**0**	0	0
Manganese	ppm	ASTM D5185(m)	0	**0**	0	<1
Magnesium	ppm	ASTM D5185(m)	0	**0**	<1	1
Calcium	ppm	ASTM D5185(m)	0	**<1**	<1	● 28
Phosphorus	ppm	ASTM D5185(m)	5	**2**	3	● 149
Zinc	ppm	ASTM D5185(m)	0	**4**	3	● 34
Sulfur	ppm	ASTM D5185(m)	750	**615**	571	363
Lithium	ppm	ASTM D5185(m)		**<1**	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>20	**17**	0	10
Sodium	ppm	ASTM D5185(m)		**0**	<1	1
Potassium	ppm	ASTM D5185(m)	>20	**0**	<1	0

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	**136419**	---	---
Particles >6µm		ASTM D7647	>1300	**37256**	---	---
Particles >14µm		ASTM D7647	>160	**230**	---	---
Particles >21µm		ASTM D7647	>40	**32**	---	---
Particles >38µm		ASTM D7647	>10	**1**	---	---
Particles >71µm		ASTM D7647	>3	**0**	---	---
Oil Cleanliness		ISO 4406 (c)	>19/17/14	**24/22/15**	---	---

OIL ANALYSIS REPORT









FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.04	**0.06**	0.063	0.060

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Precipitate	scalar	Visual*	NONE	**NONE**	NONE	▲ LIGHT
Silt	scalar	Visual*	NONE	**NONE**	VLITE	NONE
Debris	scalar	Visual*	NONE	**NONE**	VLITE	NONE
Sand/Dirt	scalar	Visual*	NONE	**VLITE**	NONE	NONE
Appearance	scalar	Visual*	NORML	**NORML**	NORML	NORML
Odor	scalar	Visual*	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	Visual*	>.1	**NEG**	1%	▲ 1%
Free Water	scalar	Visual*		**NEG**	▲ 1%	▲ 1%

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	33.86	**33.9**	33.8	▲ 15.9
Visc @ 100°C	cSt	ASTM D7279(m)	5.60	**5.7**	5.5	3.6
Viscosity Index (VI)	Scale	ASTM D2270*	101	**107**	97	108

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0080246 **Received** : 24 Apr 2024
Lab Number : 02631149 **Tested** : 25 Apr 2024
Unique Number : 5772302 **Diagnosed** : 25 Apr 2024 - Kevin Marson
Test Package : MAR 2 (Additional Tests: KV100, PrtCount, TAN Man, VI)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

Suncor - Terra Nova Projects
Scotia Centre, 235 Water Strret
St. John`s, NL
CA A1C 1B6
Contact: Josh Hynes
joshynes@suncor.com
T: (709)778-3575
F: (709)724-2835