Sample Rating Trend



## **PROBLEM SUMMARY**

Mav14/24

DEGRADATION


## Machine Id


SKPR P-12


Hydraulic System


PETRO CANADA TURBOFLO R&O 46 (--- GAL)

### COMPONENT CONDITION SUMMARY









### RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you drain the oil from the component if this has not already been done. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

## PROBLEMATIC TEST RESULTS

PROBLEMATIC	S IESI	RESULT	8			
Sample Status				SEVERE		
Iron	ppm	ASTM D5185(m)	>20	<u> </u>		
Particles >4µm		ASTM D7647	>5000	<b>130017</b>		
Particles >6µm		ASTM D7647	>1300	<b>▲</b> 19424		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<b>4</b> 24/21/14		
Acid Number (AN)	mg KOH/g	ASTM D974*	0.12	<b>A</b> 22.7		
Visc @ 40°C	cSt	ASTM D7279(m)	44.4	<u> </u>		
Visc @ 100°C	cSt	ASTM D7279(m)	6.72	<b>10.3</b>		
Viscosity Index (VI)	Scale	ASTM D2270*	104	<b>  172</b>		
PrtFilter					no image	no image

Customer Id: PCA\_129713 Sample No.: PC Lab Number: 02635707 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS					
Action	Status	Date	Done By	Description	
Change Fluid			?	We recommend that you drain the oil from the component if this has not already been done.	
Change Filter			?	We recommend you service the filters on this component.	
Resample			?	Resample in 30-45 days to monitor this situation.	
Information Required			?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.	
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.	
Check Fluid Source			?	Confirm the source of the lubricant being utilized for top-up/fill.	
Check Seals			?	Check seals and/or filters for points of contaminant entry.	

## HISTORICAL DIAGNOSIS





## **OIL ANALYSIS REPORT**



Machine Id

SKPR P-12

Hydraulic System Fluid PETRO CANADA TURBOFLO R&O 46 (--- GAL)

#### DIAGNOSIS

#### A Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you drain the oil from the component if this has not already been done. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

#### 📥 Wear

Iron ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion.


#### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

#### Fluid Condition

The oil viscosity is higher than normal. The high AN level of the oil indicates the presence of oxipolymerized products. The AN level is much higher than the recommended limit. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The oil is no longer serviceable as a result of the abnormal and/or severe wear.









# **OIL ANALYSIS REPORT**

1,520 T	ticle Coun	t			T26	
22,880					24	F
Severe 30,720					22 8	F
7,680 Abnon	nal				-20 4406	F
1,920					10 999	
480 - 120 -		1			-16 Cleanliness Code -12 Code	F
30-					-12	F
8-					-10 6	F
2 -						(
0 4µ	6µ	14µ	21µ	38µ	71µ	
🔺 Aci	d Number					
25						
Acid Number (mg KOH(g) 12 12 2						
15						١
a g 10-						`
id Nu						
						:
<b>Base</b>					4	
May14/24					May14/24	
Ma					Ma	
🔺 Par	ticle Trend	ł				
140k T						
120k -	4μm 6μm					
120k	14μm					
80k						
60k						
40k -						
20k	ormal	*****		*****		
UK					24	,
May14/24					May14/24	
W					W	
🔺 Vis	cosity @ 1	00°C				
12 T						
11-						
10- 						
(0.001) 8 Abn	ormal					
to 7- Base						
6 - Abn						
5						
4 42					24	
May14/24					lay14/24	I
S					Ň	1
	cosity @ 4	0°C				
<sup>60</sup>						
55-						
Abn	ormal					
t (40°						
ਤੋਂ 45 <b>- Base</b>						
	ormal					
40 - Abn						
1010					5	
40 - Abn 35 +2					2	
35 42/4					ay14/2	
35					May14/24	
35 42/4			041.4	l abr	~	· w
35 42/4		0	CALA		oratory ple No.	: W

Particles >4µm	INESS	method	limit/base	current	history1	history2
. αποίου > τμπ		ASTM D7647	>5000	<b>130017</b>		
Particles >6µm		ASTM D7647	>1300	<b>19424</b>		
Particles >14µm		ASTM D7647	>160	122		
Particles >21µm		ASTM D7647	>40	14		
Particles >38µm		ASTM D7647	>10	2		
Particles >71µm		ASTM D7647	>3	1		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<b>4</b> 24/21/14		
FLUID DEGRAD	ATION		limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.12	<b>22.7</b>		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	VLITE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		
Emulsified Water	scalar	Visual*	>0.05	NEG		
Free Water	scalar	Visual*		NEG		
FLUID PROPER	RTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	44.4	<b>6.8</b>		
Visc @ 100°C	cSt	ASTM D7279(m)	6.72	<u> </u>		
Viscosity Index (VI)	Scale	ASTM D2270*	104	<b>172</b>		
SAMPLE IMAG	ES	method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image
PrtFilter					no image	no image

635707 : 21 May 2024 Mississauga, ON Tested Accredited Laboratory Unique Number : 5776860 Diagnosed : 21 May 2024 - Kevin Marson CA L5J 1K2 Test Package : IND 2 (Additional Tests: Bottom, BottomAnalysis, FilterPatch, KV100, PQ, PrtFilter, TAN MaonWact: Behshad Sabah To discuss this sample report, contact Customer Service at 1-800-268-2131. Behshad.Sabah@hfsinclair.com Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (905)716-2158 Validity of results and interpretation are based on the sample and information as supplied. F: (905)403-6740

Contact/Location: PETMISTM - Behshad Sabah - PCA\_129713