


# **PROBLEM SUMMARY**

# Aft Machinery Space [450323116]


Thruster Aft Port - Seal Oil System (S/N Sample Tag CL-06002-S3)


Sealing System


PETRO CANADA ENERGOL GR-XP ISO 150 (65 LTR)




### COMPONENT CONDITION SUMMARY









### RECOMMENDATION

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you drain the fluid from the component if this has not already been done. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS							
Sample Status				SEVERE	ABNORMAL	SEVERE	
Iron	ppm	ASTM D5185(m)	>100	<u> </u>	3	8	
Chromium	ppm	ASTM D5185(m)	>3	<b>1</b> 4	0	<1	
Nickel	ppm	ASTM D5185(m)	>8	<u> </u>	0	<1	
Water	%	ASTM D6304*		<b>0.507</b>		<b>1.209</b>	
ppm Water	ppm	ASTM D6304*		<u> </u>		<b>12096</b>	
Particles >4µm		ASTM D7647	>5000	<b>403992</b>	<u> </u>		
Particles >6µm		ASTM D7647	>1300	<b>102076</b>	<u>^</u> 2713		
Particles >14µm		ASTM D7647	>160	<b>3801</b>	72		
Particles >21µm		ASTM D7647	>40	<b>1053</b>	10		
Particles >38µm		ASTM D7647	>10	<b>△</b> 33	1		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<b>26/24/19</b>	<u>^</u> 21/19/13		
<b>Emulsified Water</b>	scalar	Visual*		<b>.2</b> %	NEG	<u>.5%</u>	

**Customer Id: TERHAM** Sample No.: PC Lab Number: 02636025 Test Package: MAR 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	We recommend that you drain the fluid from the component if this has not already been done.		
Resample			?	Resample in 30-45 days to monitor this situation.		
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.		
Check Dirt Access			?	We advise that you check all areas where contaminants can enter the system.		
Check Seals			?	Check seals and/or filters for points of contaminant entry.		

### HISTORICAL DIAGNOSIS

### 21 Apr 2024 Diag: Kevin Marson

ISO

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the fluid. The AN level is acceptable for this fluid. The fluid is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



#### WATER



31 Mar 2024 Diag: Kevin Marson
We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We recommend that you change the oil. We recommend an early resample to monitor this condition. NOTE: Test values may be askew due high concentration of free water present in sample.All component wear rates are normal. There is a high concentration of water present in the fluid. Excessive free water present. Abnormal water content and sodium(Na) level indicate possible sea water contamination. The white residue present in the sample is fluid additive precipitate. The AN level is acceptable for this fluid. The fluid is no longer serviceable due to the presence of contaminants.



## 30 Mar 2024 Diag: Kevin Marson




We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the fluid. The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend





# Aft Machinery Space [450323116]

Thruster Aft Port - Seal Oil System (S/N Sample Tag CL-06002-S3)

**Sealing System** 

PETRO CANADA ENERGOL GR-XP ISO 150 (65 LTR)

## **DIAGNOSIS**

#### Recommendation

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you drain the fluid from the component if this has not already been done. Resample in 30-45 days to monitor this situation.

#### Wear

Chromium ppm levels are severe. Nickel and iron ppm levels are abnormal.

#### Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the fluid. There is a moderate concentration of water present in the fluid. Abnormal water content and sodium(Na) level indicate possible sea water contamination.

### Fluid Condition


The AN level is acceptable for this fluid. The fluid is no longer serviceable as a result of the abnormal and/or severe wear.

0 (65 LTR) 1/2018 UniZ018 JunZ019 NovZ019 NovZ019 NovZ020 SngZ020 MuzZ023 FnbZ024						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC	PC	PC0081643
Sample Date		Client Info		26 Apr 2024	21 Apr 2024	31 Mar 2024
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	0	Client Info		N/A	N/A	N/A
Sample Status				SEVERE	ABNORMAL	SEVERE
WEAR METAL	S	method	limit/base	current	history1	history2
PQ		ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m)	>100	<u> </u>	3	8
Chromium	ppm	ASTM D5185(m)	>3	<b>1</b> 4	0	<1
Nickel	ppm	ASTM D5185(m)	>8	<u> 10</u>	0	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>3	<1	0	0
Lead	ppm	ASTM D5185(m)		0	0	0
Copper	ppm	ASTM D5185(m)	>3	<1	0	<1
Tin	ppm	ASTM D5185(m)		0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		2	13	1
Barium	ppm	ASTM D5185(m)		0	0	0
Molybdenum	ppm	ASTM D5185(m)		2	0	0
Manganese	ppm	ASTM D5185(m)		2	0	0
Magnesium	ppm	ASTM D5185(m)		5	<1	3
Calcium	ppm	ASTM D5185(m)		4	<1	2
Phosphorus	ppm	ASTM D5185(m)		157	161	128
Zinc	ppm	ASTM D5185(m)		13	4	6
Sulfur	ppm	ASTM D5185(m)		8577	7683	7787
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	2	2	2
Sodium	ppm	ASTM D5185(m)		<b>32</b>	<1	<b>16</b>
Potassium	ppm	ASTM D5185(m)	>20	2	<1	<1
Water	%	ASTM D6304*		<u> </u>		<b>1.209</b>
ppm Water	ppm	ASTM D6304*		<u>▲</u> 5072		<b>12096</b>
FLUID CLEANL	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<b>4</b> 03992	<u></u> 11241	
Particles >6µm		ASTM D7647	>1300	<b>1</b> 02076	<u>^</u> 2713	
Particles >14μm		ASTM D7647	>160	▲ 3801	72	
Particles >21µm		ASTM D7647	>40	<b>1053</b>	10	
Particles >38μm		ASTM D7647	>10	<b>33</b>	1	
Particles >71μm		ASTM D7647	>3	1	1	
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ 26/24/19 Contact/I	△ 21/19/13	vnes - TERHAM


Contact/Location: Josh Hynes - TERHAM





# **OIL ANALYSIS REPORT**



FLUID DEGRAD	OITAC	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.9	0.35	0.45	0.35
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	▲ HEAVY
Silt	scalar	Visual*	NONE	LIGHT	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	▲ HAZY
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	Visual*		<b>.2</b> %	NEG	<u>.5%</u>
Free Water	scalar	Visual*		NEG	NEG	<b>△</b> 5%
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	149	148	144	143
Visc @ 100°C	cSt	ASTM D7279(m)	14.5	14.3	14.1	13.2
Viscosity Index (VI)	Scale	ASTM D2270*		93	94	83
SAMPLE IMAG	iES	method	limit/base	current	history1	history2
Color						









**CALA** ISO 17025:2017 Accredited Laboratory

Sample No.

Laboratory

: PC Lab Number : 02636025 Unique Number : 5785187

**Bottom** 

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received : 16 May 2024

**Tested** : 17 May 2024 Diagnosed : 17 May 2024 - Kevin Marson

Test Package : MAR 2 ( Additional Tests: KF, KV100, PQ, PrtCount, VI ) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

**Suncor - Terra Nova Projects** Scotia Centre, 235 Water Strret

St. John's, NL CA A1C 1B6

Contact: Josh Hynes joshynes@suncor.com

T: (709)778-3575 F: (709)724-2835

Report Id: TERHAM [WCAMIS] 02636025 (Generated: 05/17/2024 11:37:56) Rev: 1

Contact/Location: Josh Hynes - TERHAM