

Area

Water Injection [450328022]

Machine Id


Pump Sea Water Injection (B) - Lube System (S/N Sample Tag PA-29002B-S1)

Component

Pump

Fluid

PETRO CANADA TURBOFLO 46 (1264 LTR)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MAR 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

Wear

Component wear rates appear to be normal (unconfirmed).

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION method limit/base current history1 history2

Sample Number	Client Info	PC	PC	PC
Sample Date	Client Info	28 Apr 2024	09 Apr 2024	23 Mar 2024
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	ABNORMAL	ABNORMAL

CONTAMINATION method limit/base current history1 history2

Water	WC Method	>.1	NEG	NEG	NEG
-------	-----------	-----	------------	-----	-----

WEAR METALS method limit/base current history1 history2

PQ		ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m)	>75	0	<1	0
Chromium	ppm	ASTM D5185(m)	>5	0	0	0
Nickel	ppm	ASTM D5185(m)		0	0	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>5	0	0	0
Lead	ppm	ASTM D5185(m)	>10	0	0	0
Copper	ppm	ASTM D5185(m)	>15	<1	<1	<1
Tin	ppm	ASTM D5185(m)		0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0






ADDITIVES method limit/base current history1 history2

Boron	ppm	ASTM D5185(m)	0	<1	0	<1
Barium	ppm	ASTM D5185(m)	0	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	<1	2	0
Calcium	ppm	ASTM D5185(m)	0	0	2	0
Phosphorus	ppm	ASTM D5185(m)	110	171	174	169
Zinc	ppm	ASTM D5185(m)	0.0	<1	3	<1
Sulfur	ppm	ASTM D5185(m)		413	332	319
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS method limit/base current history1 history2

Silicon	ppm	ASTM D5185(m)	>20	<1	3	7
Sodium	ppm	ASTM D5185(m)		0	0	0
Potassium	ppm	ASTM D5185(m)	>20	<1	0	<1

OIL ANALYSIS REPORT



FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647			3708	15740	21847
Particles >6µm	ASTM D7647	>1300		1021	▲ 4524	▲ 8315
Particles >14µm	ASTM D7647	>160		64	▲ 361	▲ 849
Particles >21µm	ASTM D7647	>40		14	▲ 104	▲ 244
Particles >38µm	ASTM D7647	>10		1	9	● 20
Particles >71µm	ASTM D7647	>3		0	0	1
Oil Cleanliness	ISO 4406 (c)	>--/17/14		19/17/13	▲ 21/19/16	▲ 22/20/17

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.05	0.02	0.02	0.05

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	VLITE	▲ LIGHT	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	VLITE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>.1	NEG	.5%	NEG
Free Water	scalar	Visual*		NEG	▲ 1%	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46.6	45.3	45.3	45.3
Visc @ 100°C	cSt	ASTM D7279(m)	7.04	6.7	6.7	6.8
Viscosity Index (VI)	Scale	ASTM D2270*	107	100	100	104

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC
Lab Number : 02636167
Unique Number : 5785329
Test Package : MAR 2 (Additional Tests: KV100, PQ, TAN Man, VI)
Received : 16 May 2024
Tested : 21 May 2024
Diagnosed : 21 May 2024 - Kevin Marson

Suncor - Terra Nova Projects
 Scotia Centre, 235 Water Street
 St. John's, NL
 CA A1C 1B6
 Contact: Josh Hynes
 joshynes@suncor.com
 T: (709)778-3575
 F: (709)724-2835

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.