


PROBLEM SUMMARY


Area
PROPULSION EQUIPMENT
 Machine Id
SIMPLEX STERN TUBE/ PROPELLER HUB (CAL012) (S/N CALVERT13)
 Component
Stern tube
 Fluid
VICKERS HYDROX BIO 100 (400 LTR)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	ABNORMAL
Titanium	ppm	ASTM D5185(m) >8	▲ 12	▲ 11	▲ 12
Particles >4µm		ASTM D7647 >10000	▲ 113301	▲ 75724	---
Particles >6µm		ASTM D7647 >2500	▲ 52577	▲ 14188	---
Particles >14µm		ASTM D7647 >160	▲ 569	● 193	---
Particles >21µm		ASTM D7647 >40	▲ 107	45	---
Particles >71µm		ASTM D7647 >3	▲ 11	4	---
Oil Cleanliness		ISO 4406 (c) >20/18/14	▲ 24/23/16	▲ 23/21/15	---

Customer Id: MVCALVERT
 Sample No.: PC0080229
 Lab Number: 02638001
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

WEAR



07 Nov 2023 Diag: Kevin Marson

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Titanium ppm levels are abnormal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



WEAR



09 Aug 2023 Diag: Kevin Marson

We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MOB 3 test kits, this testkit includes Particle Count to determine the ISO cleanliness of the fluid. this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Iron and titanium ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

[view report](#)



WATER



03 May 2023 Diag: Kevin Marson

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend an early resample to monitor this condition. Iron and titanium ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. There is a moderate concentration of water present in the oil. The oil viscosity is lower than typical, possibly indicating the addition of lighter grade oil. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



Area

PROPULSION EQUIPMENT


Machine Id
SIMPLEX STERN TUBE/ PROPELLER HUB (CAL012) (S/N CALVERT13)

Component

Stern tube

Fluid

VICKERS HYDROX BIO 100 (400 LTR)



DIAGNOSIS

▲ Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

▲ Wear

Titanium ppm levels are abnormal.

▲ Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil.

Fluid Condition

The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			PC0080229	PC0076335	PC0011627
Sample Date	Client Info			17 May 2024	07 Nov 2023	09 Aug 2023
Machine Age	hrs	Client Info		24544	21847	20530
Oil Age	hrs	Client Info		21847	21847	2802
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				SEVERE	ABNORMAL	ABNORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.1	NEG	NEG	NEG






WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	11	14	▲ 17
Chromium	ppm	ASTM D5185(m)	>2	0	0	<1
Nickel	ppm	ASTM D5185(m)	>2	0	<1	<1
Titanium	ppm	ASTM D5185(m)	>8	▲ 12	▲ 11	▲ 12
Silver	ppm	ASTM D5185(m)		0	0	<1
Aluminum	ppm	ASTM D5185(m)	>4	<1	1	<1
Lead	ppm	ASTM D5185(m)	>15	5	5	6
Copper	ppm	ASTM D5185(m)	>25	4	5	6
Tin	ppm	ASTM D5185(m)	>10	1	1	1
Antimony	ppm	ASTM D5185(m)		0	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		2	2	3
Barium	ppm	ASTM D5185(m)		0	0	<1
Molybdenum	ppm	ASTM D5185(m)		0	0	0
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)		4	4	4
Calcium	ppm	ASTM D5185(m)		4	5	7
Phosphorus	ppm	ASTM D5185(m)		642	662	666
Zinc	ppm	ASTM D5185(m)		5	5	7
Sulfur	ppm	ASTM D5185(m)		1354	1601	1497
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	3	4	4
Sodium	ppm	ASTM D5185(m)		13	16	14
Potassium	ppm	ASTM D5185(m)	>20	<1	2	<1

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 113301	▲ 75724	---	
Particles >6µm	ASTM D7647	>2500	▲ 52577	▲ 14188	---	
Particles >14µm	ASTM D7647	>160	▲ 569	● 193	---	
Particles >21µm	ASTM D7647	>40	▲ 107	45	---	
Particles >38µm	ASTM D7647	>10	● 19	10	---	
Particles >71µm	ASTM D7647	>3	▲ 11	4	---	
Oil Cleanliness	ISO 4406 (c)	>20/18/14	▲ 24/23/16	▲ 23/21/15	---	

OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		1.42	1.39	---

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	100	95.0	93.8	92.8
Visc @ 100°C	cSt	ASTM D7279(m)		15.9	15.6	15.3
Viscosity Index (VI)	Scale	ASTM D2270*	205	179	177	174

SAMPLE IMAGES



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC0080229
Lab Number : **02638001**
Unique Number : 5787163
Test Package : IND 2 (Additional Tests: KV100, VI)

Ocean Choice International - MV Calvert
 1315 Topsail Rd, P.O. Box 8190
 St. John's, NL
 CA A1B 3N4

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Contact: Calvert Engine Control Room
 calvertengine@oceanchoice.com
 T:
 F: