

COOLANT REPORT

Area **Cranes** Machine Id **Crane - Fwd Engine Coolant (62 L Tank) (S/N Sample Tag: MA-04003)** Coolant Fluid

EXTENDED LIFE COOLANT (62 LTR)

DIAGNOSIS

Recommendation

The fluid is suitable for further service. Resample at the next service interval to monitor.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants


There is no indication of any contamination in the coolant.

Coolant Condition

The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC	PC	PC
Sample Date		Client Info		16 May 2024	01 Apr 2024	04 Oct 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR		UNK	UNK	
Specific Gravity		ASTM D1298*		1.068	1.068	1.068
рН	Scale 0-14	ASTM D1287*	9.0	8.23	8.32	8.36
Nitrites	ppm	Alcan Test Kit*		520	520	920
Reserve Alkalinity	Scale 0-20	ASTM D1121*		4.6	5.2	1.6
Percentage Glycol	%	ASTM D3321*	50	50.4	50.5	50.3
Freezing Point	°C	ASTM D3321*	-40	-37	-37	-35
Carboxylate						
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		1	4	3
Phosphorus	ppm	ASTM D5185(m)		2	4	1
Boron	ppm	ASTM D5185(m)		5	16	11
Molybdenum	ppm	ASTM D5185(m)		143	178	171
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	0	0	0
Aluminum	ppm	ASTM D5185(m)	>10	<1	1	<1
Copper	ppm	ASTM D5185(m)	>10	0	0	0
Lead	ppm	ASTM D5185(m)	>10	0	0	0
Tin	ppm	ASTM D5185(m)	>10	0	0	0
Silver	ppm	ASTM D5185(m)	>10	<1	<1	<1
Zinc	ppm	ASTM D5185(m)		<1	3	0
CARRIER SAL	TS	method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		4556	4795	5708
Potassium	ppm	ASTM D5185(m)		3967	4644	7833
SCALE POTEN	ITIAL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	4	8	3
Magnesium	ppm	ASTM D5185(m)	>40	2	5	2
Hardness	mg/L CaCO3	In-house*	<75	17	40	17

Sample Rating Trend






NORMAL



COOLANT REPORT








Image: Construction of the state of the

Suncor - Terra Nova Projects Scotia Centre, 235 Water Strret St. John`s, NL CA A1C 1B6 Contact: Josh Hynes joshynes@suncor.com T: (709)778-3575 F: (709)724-2835

Report Id: TERHAM [WCAMIS] 02639720 (Generated: 06/05/2024 10:03:13) Rev: 1

Contact/Location: Josh Hynes - TERHAM Page 2 of 2